THE SCHOOL BOARD OF BROWARD COUNTY, FLORIDA ENVIRONMENTAL HEALTH & SAFETY DEPARTMENT

TELEPHONE (754) 321-4200

FACSIMILE: (754) 321-4285

January 7	, 2016 Signature on File	For Custodial Supervisor Use Only
ТО	Michelle Garcia, Principal Oakland Park Elementary	Custodial Issues Addressed Custodial Issues Not Addressed
FROM:	Robert Krickovich, Coordinator, LEA Environmental Health & Safety Department	
SUBJECT:	Indoor Air Quality (IAQ) Assessment	

On January 7, 2016, I conducted an assessment at **Oakland Park Elementary School.** Attached are findings and recommendations for further assessment, remediation, or corrective actions needed.

The IAQ Assessment did not identify any existing conditions significantly impacting IAQ or presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to allergens and / or conditions noted during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of any item/s identified and noted in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-4200.

cc: Shelley Meloni, Director, Pre-Construction Mark Dorsett, Manager, Zone 1, Physical Plant Operations Division Broward Teachers Union Federation of Public Employees Gerald Devio, Supervisor II Custodial Benjamin Osborne, Supervisor II Custodial Rich Volipi, Supervisor II Custodial Mark Murray, Supervisor II Custodial Sam Bays, Director, Maintenance Operations Kurt Wirz, Area Manager Trades

ES/je Enc.

IAQ Assessment							
Oakland Park	Elementary Evaluation Date	e January 7, 2016	Time of Day 11:	30 AM			
Outdoor Conditions Tempera	ature 73.8 Relative	Humidity 64.8	Ambient CO2 4	51			
		Range CO ² % - 60% 876	Range # Oo MAX 700 > Ambient	21			
Noticeable Odor No	Visible water damage / staining?	Visible microbial growth?	Amount of material affected				
Ceiling2' X 4' Lay inWallsDrywallFloor12" x 12" Vinyl	No No No	No No					
Ceiling Clean Yes Walls Clean Yes Flooring Clean Yes	HVAC Supply Grills Clean Inside of Supply Duct Clean	Yes	HVAC Return Grills Clean Inside of Return Duct Clean	Yes Yes			
Room Surfaces Yes Clean	Ceiling at Supply Grills Clean	Yes					
Trash RemovedYesSigns of PestsNoRoom ClutteredYes	Exhaust Fans Working Drain Traps Wet Food if Stored in Room is in Sealed Containers	Yes Yes	Unapproved Chemicals / Cleaners in Room Air Fresheners in Room	No No			
Mechanical Equipment Location Filters Installed Properly			Mechanical Room Clean Inside of HVAC Unit Clean	Yes Yes			
Condensate Pan Clean Yes Fresh Air Intake Location Pollutant Sources Near Air Intake	Cooling Coil Clean Outside of room None	Yes V	Fresh Air Intake Free of Obstruction	Yes			
Observations 1 Fan,1 Air purifier, and dehumid restroom) and dehumidifier. Em on Friday's.							

Corrective Actions to be Completed by Site Based Staff

Change HVAC filters	▼
Coordinate high dust cleaning with teacher to	▼
declutter room	▼
	▼
	▼
	▼
	▼
	▼

Corrective Actions to be Completed by PPO

▼
▼
▼
▼
▼
▼
▼
▼