

Report: Site

OAKLAND PARK ELEMENTARY

Walkthrough Date: 03/23/2007 Temp RH CO2

Outdoor Parameters: 76.7 69.7 474

Room	Priority	Responsible	Answer	Recommendation
121	Inside Parameters:	Temp	RH	CO2
		73.9	46.5	808

- 2 Site Excessive dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
1302	Inside Parameters:	Temp	RH	CO2
		74.2	42.7	922

- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
1304	Inside Parameters:	Temp	RH	CO2
		72.6	49.1	693

- 2 Site General cleanliness of the room at the time of assessment was not acceptable. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
- 2 Site Minor staining on throw rug. Facilities serviceperson to thoroughly clean and sanitize or discard.

Room	Priority	Responsible	Answer	Recommendation

1311	Inside Parameters:	Temp	RH	CO2
		74.1	46	874

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
1312	Inside Parameters:	Temp	RH	CO2
		74.4	47	754

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
1322	Inside Parameters:	Temp	RH	CO2
		74.5	44.6	1296

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Minor staining on throw rug. Facilities serviceperson to thoroughly clean and sanitize or discard rug.

Room	Priority	Responsible	Answer	Recommendation
1323	Inside Parameters:	Temp	RH	CO2
		74.5	51.7	1019

2 Site Minor staining on throw rug. Facilities serviceperson to thoroughly clean and sanitize or discard rug.

1 Site Temperature was acceptable at the time of the assessment.

Room	Priority	Responsible	Answer	Recommendation
1324	Inside Parameters:	Temp	RH	CO2
		71	59.8	1711

2	Site	Excessive dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2	Site	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
1333	Inside Parameters:	Temp	RH	CO2
		73.8	47.4	1041

2	Site	Heavy staining on throw rug.	Facilities serviceperson to thoroughly clean and sanitize or discard rug.
---	------	------------------------------	---

Room	Priority	Responsible	Answer	Recommendation
1334	Inside Parameters:	Temp	RH	CO2
		74.4	43.7	1559

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--	---

2	Site	Minor dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
---	------	--	--

Room	Priority	Responsible	Answer	Recommendation
1336	Inside Parameters:	Temp	RH	CO2
		74.3	47.6	892

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--	---

2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
---	------	--------------------------------------	--

Room	Priority	Responsible	Answer	Recommendation
202	Inside Parameters:	Temp	RH	CO2
		67.5	66.8	724

2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low and humidity level was slightly elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature and humidity does not improve.

Room	Priority	Responsible	Answer	Recommendation
302	Inside Parameters:	Temp	RH	CO2
		71.2	55.5	775

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
---	------	---	--

Room	Priority	Responsible	Answer	Recommendation
303	Inside Parameters:	Temp	RH	CO2
		70.8	63.8	725

2	Site	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	Temperature was low and humidity level was slightly elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature and humidity does not improve.
2	Site	Environmental parameters were not within acceptable range at the time of assessment..	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature and humidity does not improve.

Room	Priority	Responsible	Answer	Recommendation
304	Inside Parameters:	Temp	RH	CO2
		69.8	58.0	812

2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

Room	Priority	Responsible	Answer	Recommendation
401	Inside Parameters:	Temp	RH	CO2
		69.3	54.5	788

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
403	Inside Parameters:	Temp	RH	CO2
		69.5	53.1	729

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Environmental parameters were not within Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate

Room	Priority	Responsible	Answer	Recommendation
404	Inside Parameters:	Temp	RH	CO2
		70.7	71.3	729

2	Site	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	Temperature was low and humidity level was slightly elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature and humidity does not improve.
2	Site	Temperature was low and humidity level was slightly elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature and humidity does not improve.
2	Site	Environmental parameters were not within acceptable range at the time of assessment..	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature and humidity does not improve.

Room	Priority	Responsible	Answer	Recommendation
405	Inside Parameters:	Temp	RH	CO2
		69.2	56	907

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate

2 Site Environmental parameters were not within acceptable range at the time of assessment.. the HVAC system if temperature does not improve.
Site based administration to encourage facility serviceperson staff to adjust the thermostat.
Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
501	Inside Parameters:	Temp	RH	CO2
		76.2	46.0	874

2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
601	Inside Parameters:	Temp	RH	CO2
		74.2	59.9	535

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
802	Inside Parameters:	Temp	RH	CO2
		72.2	53.2	1250

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
803	Inside Parameters:	Temp	RH	CO2
		71.9	55.7	1135

Slight dust accumulation was observed on

- 2 Site environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
804	Inside Parameters:	Temp	RH	CO2
		70.8	56	1218

- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
905	Inside Parameters:	Temp	RH	CO2
		71.1	52	639

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
907	Inside Parameters:	Temp	RH	CO2
		68.4	55.9	653

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
910	Inside Parameters:	Temp	RH	CO2
		68.6	54.6	867

- 2 Site General cleanliness of the room at the time of assessment was not acceptable. Site based administration should address general cleanliness with facility serviceperson staff.

3	Site		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
Room	Priority	Responsible	Answer	Recommendation
911	Inside Parameters:	Temp	RH	CO2
		77.2	64.1	828
2	Site		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site		Environmental parameters were not within acceptable range at the time of assessment..	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
Room	Priority	Responsible	Answer	Recommendation
913	Inside Parameters:	Temp	RH	CO2
		76.4	63.2	833
3	Site		Industrial supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.
2	Site		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
3	Site		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.