

Orange Brook Elementary

IAQ Walkthrough 5/11/2005

0711

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
073C	Temp <input type="text" value="77.5"/> RH% <input type="text" value="50.2"/> CO2 <input type="text" value="929"/>	Occupants: <input type="text"/>			
LOCAL EXHAUST FANS					
Bathroom exhaust fan is functioning properly?	This room does not have a bathroom.	Portable 1073C No bathroom	None		
101	Temp <input type="text" value="75.5"/> RH% <input type="text" value="53.3"/> CO2 <input type="text" value="983"/>	Occupants: <input type="text"/>			
AIR CONDITIONING					
Room is free of smell of mold or mildew?	At times, there is a smell of mold/mildew but this is infrequent (usually on Mondays or after the area has been closed/no air for a period of time)	No microbial growth identified. No odor identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS					
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	3 areas on ceiling have stained tiles from prior leaks	No issues identified at the time of assessment.	None		
GENERAL CLEANLINESS					
Classroom is dusted/vacuumed thoroughly and regularly?	Floors in back room were we eat lunch and supplies are kept need to be cleaned., Room 101 is front office area. Floor is carpeted. Carpeting is old and frayed and difficult to clean. Some rodent infestation previously - improvement seen with recent s	Carpet rippled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	3
Floor is cleaned on a regular basis?	Floors in back room were we eat lunch and supplies are kept need to be cleaned., Room 101 is front office area. Floor is carpeted. Carpeting is old and frayed and difficult to clean. Some rodent infestation previously - improvement seen with recent s	Carpet is rippled	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	3
Room is free of pests?	Floors in back room were we eat lunch and supplies are kept need to be cleaned., Room 101 is front office area. Floor is carpeted. Carpeting is old and frayed and difficult to clean. Some rodent infestation previously - improvement seen with recent s	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101	Temp	<input type="text" value="75.5"/>	RH% <input type="text" value="53.3"/>	CO2 <input type="text" value="983"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Room 101 is office -- windows are kept closed/locked - outside air is continually introduced to the room because the outside door is used by students, staff and parents. In spite of this, the humidity seems to stay within an acceptable range.		No issues identified at the time of assessment.	None		
101B	Temp	<input type="text" value="74.1"/>	RH% <input type="text" value="53.3"/>	CO2 <input type="text" value="1025"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Room is free of smell of kitchen/food?	When teachers lounge is used for cooking odor comes into my area.		No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Indoor surfaces of exterior walls free of continuous condensation?	Have found mold on books in my room .		No issues identified at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply register at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	
	Classroom is dusted/vacuumed thoroughly and regularly?			No issues identified at the time of assessment.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Room with air vent open is generally too cold but when closed is too hot and stuffy. So, I usually leave it open.		No issues identified at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Room with air vent open is generally too cold but when closed is too hot and stuffy. So, I usually leave it open.		No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Room with air vent open is generally too cold but when closed is too hot and stuffy. So, I usually leave it open.		No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Room with air vent open is generally too cold but when closed is too hot and stuffy. So, I usually leave it open.		No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101E	Temp	<input type="text" value="72.5"/>	RH% <input type="text" value="51.7"/>	CO2 <input type="text" value="1065"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		VERY, VERY, VERY COLD!!!!!!!	Adjust air temp, as the day progresses temp gets very cold.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)		VERY, VERY, VERY COLD!!!!!!!	Adjust air temp, as the day progresses temp get very cold.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?		VERY, VERY, VERY COLD!!!!!!!	Adjust air temp, as the day progresses temp gets very cold.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
101G	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="53.7"/>	CO2 <input type="text" value="1080"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		There are many months when it is either warm or freezing in many of the rooms	Adjust air temp, as the day progresses, temp gets very cold.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		There are many months when it is either warm or freezing in many of the rooms	Adjust air temp, as the day progresses, temp gets very cold.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)		There are many months when it is either warm or freezing in many of the rooms	Adjust air temp, as the day progresses, temp gets very cold.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?		There are many months when it is either warm or freezing in many of the rooms	Adjust air temp, as the progresses temp gets very cold.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
102	Temp	<input type="text" value="73"/>	RH% <input type="text" value="53.3"/>	CO2 <input type="text" value="982"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			No issues identified at the time of assessment.	None		
106D	Temp	<input type="text" value="75.7"/>	RH% <input type="text" value="54.4"/>	CO2 <input type="text" value="1033"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)		Very cold for me at least.	Adjust air temp, very cold as day progresses.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?		Very cold for me at least.	Adjust air temp, very cold as day progresses.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
121	Temp	74.6	RH% 61	CO2 2196	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No microbial growth identified. No odor identified at the time of assessment.	None		
	Room is free of smell of vehicle exhaust?			No issues identified at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None		
	Water run in sinks at least once per week (about 2 cups of water).			No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?			No issues identified at the time of assessment.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	3
	Classroom lavatories/water fountains free of leaks?			No issues identified at the time of assessment.	None		
	Cold water pipes free of continuous condensation?			No issues identified at the time of assessment.	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No issues identified at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No issues identified at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	3
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	3
	Classrooms general appearance is clean and acceptable?			No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
121	Temp	74.6	RH% 61	CO2 2196	Occupants:		
	Floor is cleaned on a regular basis?			No issues identified at the time of assessment.	None		
	Room is free of pests?			No issues identified at the time of assessment.	None		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			Exhaust fan is functioning properly.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			Exhaust fan is functioning properly.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			No issues identified at the time of assessment.	None		
122	Temp	70.6	RH% 49-2	CO2 1354	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
	Classroom lavatories/water fountains free of leaks?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	3
	GENERAL CLEANLINESS						
	Room is free of pests?			lizards get into the room often	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
123	Temp	71.1	RH% 52.9	CO2 1667	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	GENERAL CLEANLINESS						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
123	Temp	71.1	RH% 52.9	CO2 1667	Occupants:		
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	3
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			Exhaust fan is functioning properly.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Often too cold, When the is cold we do not get heat		Adjust temp for proper function.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Often too cold, When the is cold we do not get heat		Adjust temp for proper funtion.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)		Often too cold, When the is cold we do not get heat		Adjust temp for proper function.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 2
	Temperature in my classroom is generally comfortable (72F-76F)?		Often too cold, When the is cold we do not get heat		Adjust temp for proper function.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 2
134	Temp	64.5	RH% 62.3	CO2 2146	Occupants:		
	GENERAL CLEANLINESS						
	Room is free of pests?			No issues identified at the time of assessment.	None		
	LOCAL EXHAUST FANS						
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			No issues identified at the time of assessment.	None		
135	Temp	71.8	RH% 51.4	CO2 1960	Occupants:		
	GENERAL CLEANLINESS						
	Room is free of pests?			No pests observed at the time of assessment.	None		
143	Temp	72.9	RH% 59.2	CO2 1649	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Indoor surfaces of exterior walls free of continuous condensation?			No issues identified at the time of assessment.	None		
	GENERAL CLEANLINESS						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
143	Temp	72.9	RH%	59.2	CO2	1649	Occupants:	<input type="text"/>			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No issues identified at the time of assessment.					None		
	Room is free of pests?			No pests observed at the time of assessment.					None		
145	Temp	71.9	RH%	51.7	CO2	1565	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Room is free of pests?			No pests observed at the time of assessment.					None		
146	Temp	77.1	RH%	46.2	CO2	811	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Floor is cleaned on a regular basis?			No issues identified at the time of assessment.					None		
161	Temp	75.3	RH%	50.2	CO2	1315	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			Item 2 on the REVIEW SURVEY under General Cleanliness, does not read the same as Item B on this page (General Cleanliness). Custodians are very good about emptying the trash and replacing with new bags!	No issues identified at the time of assessment.				None		
	Room is free of pests?			Item 2 on the REVIEW SURVEY under General Cleanliness, does not read the same as Item B on this page (General Cleanliness). Custodians are very good about emptying the trash and replacing with new bags!	No pests observed at the time of assessment.				None		
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?			There are no bathrooms in this location.	No bathroom. Identified in error.				None		
	Other exhaust fans that may exist in the classroom are functioning properly?			There are no bathrooms in this location.	No bathroom. Identified in error.				None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

163

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew? Classroom has a moldy, meldwish smell. No microbial growth identified. No odor identified at the time of assessment. None

ANIMALS IN THE CLASSROOM

Classroom is free of animals and pets? There is an infestation of rats and ants at my school. Daily, rat droppings are found all around classroom. No animals identified at the time of assessment. None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation? The school had a terrible rat problem. The rats ate my new AR books, \$1,000 from a grant that I wrote. No issues identified at the time of assessment. None

Room is free of pests? The school had a terrible rat problem. The rats ate my new AR books, \$1,000 from a grant that I wrote. No pests observed at the time of assessment. None

THERMAL COMFORT

Classroom is free of significant temperature shifts? One part of school freeezes while the other part is extremely humid. No issues identified at the time of assessment. None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) One part of school freeezes while the other part is extremely humid. No issues identified at the time of assessment. None

Room is free of the introduction of outdoor air? (Gaps in window/door frames.) One part of school freeezes while the other part is extremely humid. Gaps in windows or doors identified at the time of assessment. Physical Plant Operations to evaluate and repair as appropriate. Physical Plant Operations 2

Room is usually comfortable? (If no, please explain in the notes below.) One part of school freeezes while the other part is extremely humid. No issues identified at the time of assessment. None

Temperature in my classroom is generally comfortable (72F-76F)? One part of school freeezes while the other part is extremely humid. No issues identified at the time of assessment. None

164

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment. None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly? No issues identified at the time of assessment. None

Room is free of pests? Pests observed at the time of assessment. Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action. Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
165	Temp	73.5	RH% 45.9	CO2 1203	Occupants:		
AIR CONDITIONING							
Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?			There are no classroom pets but there are lizard droppings and vermon issues at the school.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No issues identified at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?				No issues identified at the time of assessment.	None		
Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
173	Temp	75.2	RH% 46	CO2 2124	Occupants:		
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
176	Temp	72.5	RH% 49.3	CO2 2079	Occupants:		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None		
181	Temp	72.2	RH% 49.4	CO2 1305	Occupants:		
AIR CONDITIONING							
Air flowing from air supply?				No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

181

Temp RH% CO2

Occupants:

Room is free of smell of mold or mildew?

No microbial growth identified. No odor identified at the time of assessment.

None

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No issues identified at the time of assessment.

None

Classroom is dusted/vacuumed thoroughly and regularly?

No issues identified at the time of assessment.

None

Classrooms general appearance is clean and acceptable?

No issues identified at the time of assessment.

None

Floor is cleaned on a regular basis?

No issues identified at the time of assessment.

None

Room is free of pests?

No pests observed at the time of assessment.

None

182

Temp RH% CO2

Occupants:

AIR CONDITIONING

Air is flowing without obstruction?

No issues identified at the time of assessment.

None

Room is free of smell of mold or mildew?

No microbial growth identified. No odor identified at the time of assessment.

None

ANIMALS IN THE CLASSROOM

Classroom is free of animals and pets?

No animals identified at the time of assessment.

None

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No issues identified at the time of assessment.

None

GENERAL CLEANLINESS

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
182	Temp	77.6	RH% 60	CO2 1573	Occupants: <input type="text"/>		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				No issues identified at the time of assessment.	None	
	Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
183	Temp	73.3	RH% 48.9	CO2 1614	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No microbial growth identified. No odor identified at the time of assessment.	None	
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
	THERMAL COMFORT						
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
184	Temp	74.6	RH% 51	CO2 1386	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Room is free of pests?		Blinds are not dusted regularly.		No pests observed at the time of assessment.	None	
	THERMAL COMFORT						
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
192	Temp	74.7	RH% 51.8	CO2 1488	Occupants:		
AIR CONDITIONING							
Air flowing from air supply?					No issues identified at the time of assessment.	None	
Air is flowing without obstruction?					No issues identified at the time of assessment.	None	
Room is free of smell of vehicle exhaust?					Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations 2
ART SUPPLIES							
Science supplies okay?					No issues identified at the time of assessment.	None	
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					No leaks or signs of water intrusion identified.	None	
Windows, windowsills and window frames free of continuous condensation?					No condensation on windows at the time of assessment.	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No issues identified at the time of assessment.	None	
Room is free of pests?					Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?					Exhaust fan is functioning properly.	None	
193B	Temp	72.3	RH% 55.6	CO2 1057	Occupants:		
AIR CONDITIONING							
Room is free of smell of vehicle exhaust?					Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations 2
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)					Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
206	Temp	74.3	RH% 50.9	CO2 1908	Occupants:		
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 3
	Room is free of pests?				No pests observed at the time of assessment.	None	
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is to cold., TO COLD		No issues identified at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is to cold., TO COLD		No issues identified at the time of assessment.	None	
208	Temp	70.9	RH% 51.3	CO2 1733	Occupants:		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 3
	Floor is cleaned on a regular basis?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 3
	Room is free of pests?				No pests observed at the time of assessment.	None	
209	Temp	72.5	RH% 48.2	CO2 1833	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Windows, windowsills and window frames free of continuous condensation?				Delaminating mica.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 2
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				No issues identified at the time of assessment.	None	
	Floor is cleaned on a regular basis?				No issues identified at the time of assessment.	None	
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		Often times, it is too cold.		Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Often times, it is too cold.		Temperature was acceptable at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

210

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

No issues identified at the time of assessment.

None

Room is free of pests?

No pests observed at the time of assessment.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Room is frequently extremely cold. Students must wear sweaters every single day, including on warm weather days.

No issues identified at the time of assessment.

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Room is frequently extremely cold. Students must wear sweaters every single day, including on warm weather days.

No issues identified at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

Room is frequently extremely cold. Students must wear sweaters every single day, including on warm weather days.

No issues identified at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

Room is frequently extremely cold. Students must wear sweaters every single day, including on warm weather days.

No issues identified at the time of assessment.

None

211

Temp RH% CO2 Occupants:

AIR CONDITIONING

Air flowing from air supply?

No issues identified at the time of assessment.

None

Air is flowing without obstruction?

No issues identified at the time of assessment.

None

Windows/doors are operable and are kept closed?

No issues identified at the time of assessment.

None

GENERAL CLEANLINESS

Room is free of pests?

Excessive dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

1

LOCAL EXHAUST FANS

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
211	Temp	79.1	RH% 54.4	CO2 703	Occupants:		
	Bathroom exhaust fan is functioning properly?				Exhaust fan is functioning properly.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		I am in a storage room no air nor heat.		No issues identified at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		I am in a storage room no air nor heat.		No issues identified at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		I am in a storage room no air nor heat.		No issues identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		I am in a storage room no air nor heat.		No issues identified at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		I am in a storage room no air nor heat.		No issues identified at the time of assessment.	None	
215	Temp	74.6	RH% 63.2	CO2 1303	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
	GENERAL CLEANLINESS						
	Room is free of pests?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None	
216	Temp	74.5	RH% 61.6	CO2 1227	Occupants:		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
216	Temp	74.5	RH% 61.6	CO2 1227	Occupants: <input type="text"/>			
	Classrooms general appearance is clean and acceptable?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None		
217	Temp	72.3	RH% 65.6	CO2 1203	Occupants: <input type="text"/>			
	Classroom is free of significant temperature shifts?		somedays, the classroom is extremely hot, and other days it is extremely cold, therefore making it uncomfortable		No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		somedays, the classroom is extremely hot, and other days it is extremely cold, therefore making it uncomfortable		No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		somedays, the classroom is extremely hot, and other days it is extremely cold, therefore making it uncomfortable		No issues identified at the time of assessment.	None		
218	Temp	73.7	RH% 64.5	CO2 1276	Occupants: <input type="text"/>			
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?		It is either too hot or too cold-there is no happy medium.		No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		It is either too hot or too cold-there is no happy medium.		No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		It is either too hot or too cold-there is no happy medium.		No issues identified at the time of assessment.	None		