

Oriole Elementary

IAQ Walkthrough 5/6/2005

1831

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
<i>101E</i>	Temp <input type="text" value="68.9"/> RH% <input type="text" value="62.8"/> CO2 <input type="text" value="753"/>	Occupants: <input type="text"/>			
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	There is no bathroom in this office.	No bathroom. Identified in error.	None	
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low and humidity level was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
<i>122</i>	Temp <input type="text" value="69.6"/> RH% <input type="text" value="65.5"/> CO2 <input type="text" value="1068"/>	Occupants: <input type="text"/>			
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Changes in temperature - sometimes hot, other times freezing.	Temperature was low and humidity level was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)	Changes in temperature - sometimes hot, other times freezing.	See other recommendation.		
Walkthrough		Occupant advised that cloth in hallway on walls is stained.	Facilities serviceperson should remove cloth in hallway.	Site Based	2
<i>124</i>	Temp <input type="text" value="70.2"/> RH% <input type="text" value="61"/> CO2 <input type="text" value="967"/>	Occupants: <input type="text"/>			
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
124	Temp	70.2	RH% 61	CO2 967	Occupants:		
	Classroom is free of significant temperature shifts?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?			See other recommendation.			
	Walkthrough			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Signs of water intrusion above emergency exit.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
126	Temp	70.4	RH% 62.3	CO2 837	Occupants:	3	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			I HAVE NEVER SEEN THE REGISTER BE CLEANED THOUGH IT COULD HAVE BEEN DONE WAS I WAS NOT PRESENT (E)	Air supply register is broken.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)			NO, MY ROOM IS ALWAYS TOO COLD	Temperature was low and humidity level was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Temperature in my classroom is generally comfortable (72F-76F)?			NO, MY ROOM IS ALWAYS TOO COLD	See other recommendation.		
128	Temp	71	RH% 63.2	CO2 975	Occupants:	27	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

129

Temp RH% CO2 Occupants:

THERMAL COMFORT

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

the room is always very very very cold. the coldest day we had this year the room was freezing and blew cold air

Humidity was slightly elevated at the time of assessment.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Physical Plant Operations

2

Room is usually comfortable? (If no, please explain in the notes below.)

the room is always very very very cold. the coldest day we had this year the room was freezing and blew cold air

Temperature was low at the time of assessment.

Physical Plant Operations to evaluate HVAC system for proper operation.

Physical Plant Operations

2

Temperature in my classroom is generally comfortable (72F-76F)?

the room is always very very very cold. the coldest day we had this year the room was freezing and blew cold air

See other recommendation.

Walkthrough

Dust observed on supply register at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Signs of water intrusion. Stained ceiling tiles.

Physical Plant Operations to evaluate for roof leaks and repair as appropriate.

Physical Plant Operations

1

130

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

ART SUPPLIES

Industrial supplies okay?

No issues identified at the time of assessment.

None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Room is too cold.

Temperature was low at the time of assessment.

Physical Plant Operations to evaluate HVAC system for proper operation.

Physical Plant Operations

2

Room is usually comfortable? (If no, please explain in the notes below.)

Room is too cold.

Humidity was slightly elevated at the time of assessment.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Physical Plant Operations

2

Temperature in my classroom is generally comfortable (72F-76F)?

Room is too cold.

Temperature was low at the time of assessment.

See other recommendation.

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
130	Temp	71.6	RH% 67	CO2 790	Occupants: 5		
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
				Items being stored in handicapped restroom.	Facilities serviceperson should remove items from restroom.	Site Based	1
137	Temp	71.3	RH% 65.4	CO2 958	Occupants: 25		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		none	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
	Walkthrough						
				Signs of water intrusion. Leak identified at sink faucets.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
141	Temp	72.1	RH% 72.2	CO2 717	Occupants: 3		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		room is too cold; hands and feet stiffen and tingle, body shakes with chill, must wear winter clothing everyday, normal classroom activities are affected	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	1
	Temperature in my classroom is generally comfortable (72F-76F)?		room is too cold; hands and feet stiffen and tingle, body shakes with chill, must wear winter clothing everyday, normal classroom activities are affected	Temperature was acceptable at the time of assessment.	None		
	Walkthrough						
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
142	Temp	72	RH% 63.8	CO2 725	Occupants:	3	
DRAIN TRAPS IN THE CLASSROOM							
Water run in sinks at least once per week (about 2 cups of water).				No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Classroom lavatories/water fountains free of leaks?				Signs of water intrusion.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				No issues identified at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	1
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No issues identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		

143

Temp 71.5 RH% 69.3 CO2 698 Occupants: 3

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?	Classroom does not have a bathroom.	No bathroom. Identified in error.	None
Other exhaust fans that may exist in the classroom are functioning properly?	Classroom does not have a bathroom.	No issues identified at the time of assessment.	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
143	Temp	71.5	RH%	69.3	CO2	698	Occupants:	3			
THERMAL COMFORT											
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None					
Room is usually comfortable? (If no, please explain in the notes below.)					Temperature was acceptable at the time of assessment.	None					
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was acceptable at the time of assessment.	None					
Walkthrough											
					Humidity was slightly elevated at the time of assessment	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.		Physical Plant Operations		2	
					Signs of water intrusion.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.		Physical Plant Operations		1	
144	Temp	71	RH%	67.5	CO2	734	Occupants:	3			
GENERAL CLEANLINESS											
Room is free of pests?					No pests observed at the time of assessment.	None					
Walkthrough											
					Signs of water intrusion above teacher's desk.	Physical Plant Operations to evaluate for leaks and repair as appropriate.		Physical Plant Operations		1	
					Air supply register is damaged.	Physical Plant Operations to evaluate and repair/replace as appropriate.		Physical Plant Operations		2	
					Humidity was slightly elevated at the time of assessment	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.		Physical Plant Operations		2	
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.		Site Based		1	
145	Temp	70.7	RH%	69.3	CO2	695	Occupants:	3			
AIR CONDITIONING											
Air is flowing without obstruction?					Air flowing without obstruction at the time of assessments.	None					
LOCAL EXHAUST FANS											

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
145	Temp	70.7	RH% 69.3	CO2 695	Occupants: 3		
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None	
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				No issues identified at the time of assessment.	None	
	Walkthrough						
					Humidity was slightly elevated at the time of assessment	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
					Signs of water intrusion above emergency escape area.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations 1
158	Temp	70.6	RH% 58.8	CO2 795	Occupants: 3		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
190	Temp	72.3	RH% 58.6	CO2 1981	Occupants: 26		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?	The bathroom has a funky smell all the time			Odor detected in restroom.	Facilities serviceperson to evaluate cause of odor. Exhaust fan is working properly.	Site Based 2
	ANIMALS IN THE CLASSROOM						
	Classroom is free of animals and pets?	Fish dont have fur, dander, etc			No animals identified at the time of assessment.	None	
	You are informed about the potential allergies of your students?	Fish dont have fur, dander, etc				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	DRAIN TRAPS IN THE CLASSROOM						
	Water poured down floor drains once per week (approx. 1 quart of water).	I put n/a as I have no clue what the custodians do when I leave. My classroom sink is constantly backing up and the bathroom smells (not sure if it is the sink)			No issues identified at the time of assessment.	None	
	Water run in sinks at least once per week (about 2 cups of water).	I put n/a as I have no clue what the custodians do when I leave. My classroom sink is constantly backing up and the bathroom smells (not sure if it is the sink)			No issues identified at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

190

Temp RH% CO2 Occupants:

EXCESS MOISTURE IN CLASSROOMS

Area around and under classroom sinks free of leaks?

No leaks or signs of water intrusion identified. None

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks or signs of water intrusion identified. None

Classroom lavatories/water fountains free of leaks?

No leaks or signs of water intrusion identified. None

GENERAL CLEANLINESS

Room is free of pests?

We are not given School Board approved cleaners to help in cleaning our rooms. We cannot bring in store bought items. We are not given brooms either and must purchase these with our salary checks among many other things.

Pests observed at the time of assessment.

Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.

Physical Plant Operations

1

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

Exhaust fan is functioning properly. None

THERMAL COMFORT

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

Our air conditioning unit on my side of the building kept going out at the beginning of the year and it took several days with no air to get it fixed. I think my room needs to be a bit cooler.

No issues identified at the time of assessment. None

Room is usually comfortable? (If no, please explain in the notes below.)

Our air conditioning unit on my side of the building kept going out at the beginning of the year and it took several days with no air to get it fixed. I think my room needs to be a bit cooler.

Environmental parameters were within acceptable range at the time of assessment.. None

191

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

No odor detected at the time of assessment. None

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

DRAIN TRAPS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority						
191	Temp	<input type="text" value="72.3"/>	RH%	<input type="text" value="56.2"/>	CO2	<input type="text" value="1919"/>	Occupants:	<input type="text" value="23"/>					
	Water poured down floor drains once per week (approx. 1 quart of water).						No issues identified at the time of assessment.		None				
	Water run in sinks at least once per week (about 2 cups of water).						No issues identified at the time of assessment.		None				
	GENERAL CLEANLINESS												
	Classroom is dusted/vacuumed thoroughly and regularly?						There does not appear to be a dusting issue within this room.		None				
192	Temp	<input type="text" value="72"/>	RH%	<input type="text" value="55.9"/>	CO2	<input type="text" value="1887"/>	Occupants:	<input type="text" value="27"/>					
	ART SUPPLIES												
	Art supplies okay?						The small amount of art supplies que dry quickly.		No issues identified at the time of assessment.		None		
	Industrial supplies okay?						The small amount of art supplies que dry quickly.		No issues identified at the time of assessment.		None		
	Science supplies okay?						The small amount of art supplies que dry quickly.		No issues identified at the time of assessment.		None		
	GENERAL CLEANLINESS												
	Room is free of pests?						I think each classroom should have simple cleaning materials like broom and cleaners.		Pests observed at the time of assessment.		Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
	Trash is removed daily and trash bags are changed as appropriate?						I think each classroom should have simple cleaning materials like broom and cleaners.		No issues identified regarding trash removal practices.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT												
	Room is usually comfortable? (If no, please explain in the notes below.)						Sometimes it can get a hot.		Environmental parameters were within acceptable range at the time of assessment..		None		
	Temperature in my classroom is generally comfortable (72F-76F)?						Sometimes it can get a hot.		Temperature was acceptable at the time of assessment.		None		
192A	Temp	<input type="text"/>	RH%	<input type="text"/>	CO2	<input type="text"/>	Occupants:	<input type="text"/>					
	Walkthrough												
									Exhaust fan is not functioning properly.		Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
194	Temp	72.6	RH% 58.8	CO2 1208	Occupants: 26		
EXCESS MOISTURE IN CLASSROOMS							
	Classroom lavatories/water fountains free of leaks?	After toilet is flushed, it continues to run for a few minutes, even after the handle is shaken up and down and side to side.		Toilet continues to run after flushing.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	The bathroom always smells like urine.		Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	The bathroom always smells like urine.		No issues identified at the time of assessment.	None		
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)	The room s usually freezing.		Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	The room s usually freezing.		Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Signs of water intrusion at wall.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
195	Temp	72.6	RH% 60.5	CO2 1061	Occupants: 23		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?	The bathroom has a terrible odor.		No odor from mold and mildew detected at the time of assessment. Bathroom has a strong odor.	Facilities serviceperson to evaluate cause of odor and inspect exhaust fans/fume hoods for proper operation.	Site Based	1
	Windows/doors are operable and are kept closed?	The bathroom has a terrible odor.		No issues identified at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
195	Temp	72.6	RH%	60.5	CO2	1061	Occupants:	23			
	Classroom lavatories/water fountains free of leaks?						Signs of water intrusion. Leak identified.		Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	Indoor surfaces of exterior walls free of continuous condensation?						no visible condensation at the time of assessment.		None		
	Windows, windowsills and window frames free of continuous condensation?						No visible condensation at the time of assessment.		None		
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						Dust observed on supply/return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?						Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?						Pests observed at the time of assessment.		Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
	Walkthrough										
							Signs of water intrusion at sink.		Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
196	Temp	72.6	RH%	59.4	CO2	1085	Occupants:	19			
	EXCESS MOISTURE IN CLASSROOMS										
	Windows, windowsills and window frames free of continuous condensation?						No visible condensation at the time of assessment.		None		
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?						There does not appear to be a dusting issue within this room.		None		
	Walkthrough										
							Dust observed on bathroom exhaust fan at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
							Occupant complained of odors in bathroom.		Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
198	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
Walkthrough		Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
198B	Temp <input type="text" value="72.4"/> RH% <input type="text" value="59.4"/> CO2 <input type="text" value="907"/>	Occupants: <input type="text" value="25"/>			
GENERAL CLEANLINESS					
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		
Room is free of pests?		No pests observed at the time of assessment.	None		
301	Temp <input type="text" value="73.5"/> RH% <input type="text" value="57.8"/> CO2 <input type="text" value="855"/>	Occupants: <input type="text" value="3"/>			
AIR CONDITIONING					
Air flowing from air supply?		Air flowing without obstruction at the time of assessments.	None		
Air is flowing without obstruction?		Air flowing without obstruction at the time of assessments.	None		
GENERAL CLEANLINESS					
Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		
Classrooms general appearance is clean and acceptable?		General cleanliness of the room at the time of assessment was acceptable.	None		
Room is free of pests?		Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
LOCAL EXHAUST FANS					
My classroom has sufficient exhaust systems based on the activities/functionality of the room?		No issues identified at the time of assessment.	None		
Walkthrough		Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
		Bean bag chair and stuffed animals in classroom.	Occupant should remove bean bag chair and stuffed animals.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
302	Temp	73.8	RH% 60.1	CO2 1040	Occupants:	23	
AIR CONDITIONING							
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None	
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None	
	Room is free of smell of mold or mildew?				Odor detected.	Facilities serviceperson to evaluate cause of odor and inspect exhaust fans/fume hoods for proper operation.	Site Based 2
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				I have horrible allergies to dust and mold. My allergies are always 2x as bad when I am in my classroom. Almost as soon as I leave the symptoms will go away sometimes.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?				I have horrible allergies to dust and mold. My allergies are always 2x as bad when I am in my classroom. Almost as soon as I leave the symptoms will go away sometimes.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	
	Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				The floors are not thoroughly mopped. A child threw up in my room and it was not cleaned until the next morning when I came in and still found it. The tables that the children sit at are full of dirt and never get cleaned.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				The floors are not thoroughly mopped. A child threw up in my room and it was not cleaned until the next morning when I came in and still found it. The tables that the children sit at are full of dirt and never get cleaned.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff. Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
302	Temp	73.8	RH% 60.1	CO2 1040	Occupants: 23			
	Classrooms general appearance is clean and acceptable?	The floors are not thoroughly mopped. A child threw up in my room and it was not cleaned until the next morning when I came in and still found it. The tables that the children sit at are full of dirt and never get cleaned.			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	The floors are not thoroughly mopped. A child threw up in my room and it was not cleaned until the next morning when I came in and still found it. The tables that the children sit at are full of dirt and never get cleaned.			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?	The floors are not thoroughly mopped. A child threw up in my room and it was not cleaned until the next morning when I came in and still found it. The tables that the children sit at are full of dirt and never get cleaned.			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	The floors are not thoroughly mopped. A child threw up in my room and it was not cleaned until the next morning when I came in and still found it. The tables that the children sit at are full of dirt and never get cleaned.			There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	our air conditioning unit has been broken since October. A piece of the air conditioning that controls the temperature was broken and had to be ordered. It has not been fixed yet. The air conditioning it not even on in our room right now. When it is o			Environmental parameters were within acceptable range at the time of assessment..	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	our air conditioning unit has been broken since October. A piece of the air conditioning that controls the temperature was broken and had to be ordered. It has not been fixed yet. The air conditioning it not even on in our room right now. When it is o			Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	our air conditioning unit has been broken since October. A piece of the air conditioning that controls the temperature was broken and had to be ordered. It has not been fixed yet. The air conditioning it not even on in our room right now. When it is o			Environmental parameters were within acceptable range at the time of assessment..	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
302	Temp	73.8	RH%	60.1	CO2	1040	Occupants:	23			
	Temperature in my classroom is generally comfortable (72F-76F)?			our air conditioning unit has been broken since October. A piece of the air conditioning that controls the temperature was broken and had to be ordered. It has not been fixed yet. The air conditioning it not even on in our room right now. When it is o	Temperature was acceptable at the time of assessment.	None					
	Walkthrough										
					Live plants in room.	facilities serviceperson should remove live plants.	Site Based				1
					Stuffed animals in room.	Occupant should remove stuffed animals.	Site Based				2
					Cloth chairs in room.	Facilities serviceperson should remove cloth chairs.	Site Based				2
					Signs of water intrusion along West wall at exit door.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations				1
303	Temp	74.6	RH%	64.3	CO2	773	Occupants:	23			
	ANIMALS IN THE CLASSROOM										
	You are informed about the potential allergies of your students?								Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	DRAIN TRAPS IN THE CLASSROOM										
	Water poured down floor drains once per week (approx. 1 quart of water).				No issues identified at the time of assessment.	None					
	Water run in sinks at least once per week (about 2 cups of water).				No issues identified at the time of assessment.	None					
	EXCESS MOISTURE IN CLASSROOMS										
	Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None					
	GENERAL CLEANLINESS										
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None					
	THERMAL COMFORT										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
303	Temp	74.6	RH%	64.3	CO2	773	Occupants:	23			
	Classroom is free of significant temperature shifts?			Humidity was slightly elevated at the time of assessment .	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations					2
304	Temp	75.2	RH%	66.7	CO2	878	Occupants:	24			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?			Room is normally too cold.	Temperature was acceptable at the time of assessment and humidity level was slightly elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations				2
	Room is usually comfortable? (If no, please explain in the notes below.)			Room is normally too cold.	Temperature was acceptable at the time of assessment.	None					
	Temperature in my classroom is generally comfortable (72F-76F)?			Room is normally too cold.	Temperature was acceptable at the time of assessment.	None					
	Walkthrough										
				Air supply register is damaged.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations					2
				Signs of water intrusion. Leak identified under sink.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations					1
753	Temp	74.5	RH%	59.4	CO2	851	Occupants:	21			
	GENERAL CLEANLINESS										
	Room is free of pests?			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations					1
755	Temp	74.2	RH%	49.1	CO2	1285	Occupants:	24			
	EXCESS MOISTURE IN CLASSROOMS										
	Windows, windowsills and window frames free of continuous condensation?			No visible condensation at the time of assessment.	None						
	Walkthrough										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
755	Temp	74.2	RH% 49.1	CO2 1285	Occupants: 24		
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
758	Temp	75	RH% 41.6	CO2 1239	Occupants: 3		
DRAIN TRAPS IN THE CLASSROOM							
				If not regularly used, toilets flushed once each week.	No issues identified at the time of assessment.	None	
EXCESS MOISTURE IN CLASSROOMS							
				Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.	None	
				Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.	None	
				Windows, windowsills and window frames free of continuous condensation?	No visible condensation at the time of assessment.	None	
LOCAL EXHAUST FANS							
				My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No issues identified at the time of assessment.	None	
Walkthrough							
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
759	Temp	75.1	RH% 44.1	CO2 1674	Occupants: 4		
LOCAL EXHAUST FANS							
				Bathroom exhaust fan is functioning properly?	No issues identified at the time of assessment.	None	
THERMAL COMFORT							
				Classroom is free of significant temperature shifts?	Environmental parameters were within acceptable range at the time of assessment..	None	
Walkthrough							
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
760	Temp	74.8	RH% 47.7	CO2 1509	Occupants: 4		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)					No issues identified at the time of assessment.	None	
Walkthrough							
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
761	Temp	75.3	RH% 48.3	CO2 1455	Occupants: 3		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?		(Item B) There are no carpets to be vacuumed on a regular basis			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
Room is free of pests?		(Item B) There are no carpets to be vacuumed on a regular basis			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 1
Walkthrough							
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. Water was from cleaning floor on the second floor.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
764	Temp	77	RH% 44.3	CO2 1427	Occupants: 6		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	
Walkthrough							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
764	Temp	77	RH% 44.3	CO2 1427	Occupants: 6		
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
766	Temp	77.2	RH% 45.5	CO2 1204	Occupants: 22		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
Walkthrough							
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
767	Temp	74.9	RH% 64.2	CO2 1765	Occupants: 15		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Walkthrough							
				Occupant had A/C unit off.	Facilities serviceperson should ensure that A/C unit remains on.	Site Based	2
				Signs of water intrusion. Leak identified at fan coil unit. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
				Humidity was slightly elevated at the time of assessment .	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
769	Temp	74.6	RH% 46.8	CO2 1160	Occupants: 20		
GENERAL CLEANLINESS							
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Food, if any, is stored in tightly sealed containers?			No issues identified at the time of assessment.	None		
Walkthrough							
				Items are stored in restroom.	Facilities serviceperson should remove items from restroom.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
-----------	----------------------	----------	----------------	-------------	----------

770

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

None

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

Room is free of pests?

No pests observed at the time of assessment.

None

Walkthrough

No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.

Facilities serviceperson to replace stained ceiling tiles.

Site Based

2

774

Temp RH% CO2 Occupants:

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Temperature was elevated at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Walkthrough

No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.

Facilities serviceperson to replace stained ceiling tiles.

Site Based

2