

# Tools for Schools Phase II - Indoor Air Quality

## Follow-up Action Plan for Physical Plant Operations



Park Lakes Elementary

84.2 44.2 377

Principal: Mr. Chandar Anderson

Walkthrough Date: 5/10/2005

Temp RH Co2  
**Outside Measurements**

Room	Priority	Responsible	Response	Recommendation
007	2	Physical Plant Operations	Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.
101A	2	Physical Plant Operations	Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.
116	1	Physical Plant Operations	Occupant advised that room gets warm and they cannot control the thermostat. Air supply and return ductwork needs to be installed.	Physical Plant Operations to evaluate and repair as appropriate and install supply and return ductwork.
116	2	Physical Plant Operations	Install air supply ductwork and air supply return.	Physical Plant Operations to evaluate and repair as appropriate.
135	2	Physical Plant Operations	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.