

RISK MANAGEMENT...

managing risk with responsibility

Aston A. Henry, Supervisor
Risk Management Department

Telephone: 754 321-1900
Fax: 754 321-1917

October 22, 2010

Signature on File

TO: Mr. Michael Walker, Principal
Park Ridge Elementary School

FROM: Edward See, Project Manager
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 150 and 151

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed

On October 15, 2010 I conducted an assessment of FISH 150 and 151 at **Park Ridge Elementary School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-1900.

cc: Sharon Airaghi, Area Superintendent
Anne Dilgen, Area Director
Jeffrey S. Moquin, Executive Director, Support Operations
Aston Henry, Supervisor, Risk Management
Dave Archer, Project Manager, Facilities and Construction Management
Lynn Cavall, Broward Teachers Union
Roy Jarrett, Federation of Public Employees
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

ES/tc
Enc.

IAQ Assessment

Location Number 1951

Park Ridge Elementary School

Evaluation Requested September 16, 2010

Time of Day 8:30 am

Evaluation Date October 15, 2010

Outdoor Conditions Temperature 78.2 Relative Humidity 69 Ambient CO2 415

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
150	77.5	72 - 78	56.3	30% - 60%	521	Max 700 > Ambient	2
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
No		No		No		None	
Ceiling Type	2 x 4 Lay In		No	No	None		
Wall Type	Drywall		No	No	None		
Flooring	12 x 12 Vinyl		No	No	None		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	Yes	No	No	
Walls	Yes	No	No	
Flooring	Yes	No	No	
HVAC Supply Grills	Yes	No	No	
HVAC Return Grills	Yes	No	No	
Ceiling at Supply Grills	Yes	No	No	
Surfaces in Room	Yes	No	No	

Observations

Findings

- Occupant not present at the time of the assessment. Previous concerns with musty odors.
- Odor in room from air fresheners - 2 plug in units and 1 Glade air freshener - site based staff removed
- No signs of water intrusion or microbial growth

Site Based Maintenance:

- Remove non-approved chemicals (air fresheners) from the room. Avoid use of air fresheners as they contain chemicals that are a source of allergies.
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Location Number
 Evaluation Requested
 Evaluation Date

Park Ridge Elementary School

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="151"/>	<input type="text" value="77.3"/>	<input type="text" value="72 - 78"/>	<input type="text" value="57.1"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="578"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="15"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings

- Previous water damage from sink leak was recently repaired by PPO
- No signs of water intrusion or microbial growth
- Observed pest droppings under sink

Site Based Maintenance:

- Contact COMPASS to generate a work order for pest control
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate