

Report: PPO

PARK RIDGE ELEMENTARY

Walkthrough Date: 05/09/2006 Temp RH CO2

Outdoor Parameters: 85.2 58.5 503

Room	Priority	Responsible	Answer	Recommendation
047P	Inside Parameters:	Temp	RH	CO2
		76.1	45.9	1009

2 PPO Exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
135	Inside Parameters:	Temp	RH	CO2
		72.5	74.2	766

2 PPO Environmental parameters were not within acceptable range at the time of assessment.. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Room	Priority	Responsible	Answer	Recommendation
149	Inside Parameters:	Temp	RH	CO2
		73.7	69.1	714

2 PPO Environmental parameters were not within acceptable range at the time of assessment. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Room	Priority	Responsible	Answer	Recommendation
152	Inside Parameters:	Temp	RH	CO2
		74.1	66.7	782

1 PPO Signs of water intrusion. Stained ceiling tiles. Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.

2

PPO

Environmental parameters were not within acceptable range at the time of assessment. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Room	Priority	Responsible	Answer	Recommendation
754	Inside Parameters:	Temp	RH	CO2
		76.2	55.0	1170

3

PPO

Windows are not operable. Open doors and windows allow humid untreated air into occupied environment. Physical Plant Operations to evaluate and repair as appropriate. However site based administration to encourage staff to keep doors and windows closed.