Report: Site

PARK RIDGE ELEMENTARY

Walkthrough Date: 05/09/2006 Temp RH CO2
Outdoor Parameters: 85.2 58.5 503

Room	Priority	Responsible	Answer	Recommendation
047P	Inside Parameters:	Temp	RH	CO2
		76.1	459	1009
	2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
Room	Priority	Responsible	Answer	Recommendation
135	Inside Parameters:	Temp	RH	CO2
		72.5	74.2	766
	2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	2	Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
Room	Priority	Responsible	Answer	Recommendation
204	Inside Parameters:	Temp	RH	CO2
		74.4	60.3	1179
	2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
Room	Priority	Responsible	Answer	Recommendation
208	Inside Parameters:	Temp	RH	CO2
	l l		l l	III I

		73.5	58.2	1218
	3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
	1	Site	Stuffed animals and rug in the room.	Remove stuffed animals and rugs.
Room	Priority	Responsible	Answer	Recommendation
754	Inside Parameters:	Тетр	RH	CO2
754	Parameters:	<u> </u>		CO2 1170
754	Parameters:	<u> </u>		