

Report: *Walk Through Summary***PARK RIDGE ELEMENTARY**

Walkthrough Date: 05/09/2006 Temp RH CO2

Outdoor Parameters: 85.2 58.5 503

Room	Section	Question	Answer	Recommendation	Responsible
047P	Inside Parameters:	Temp	RH	CO2	
		76.1	45..9	1009	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
135	Inside Parameters:	Temp	RH	CO2	
		72.5	74.2	766	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
THERMAL	Temperature in my	Temperature was		

COMFORT classroom is generally comfortable (72F-78F)? acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were not within acceptable range at the time of assessment.. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level. PPO

Room	Section	Question	Answer	Recommendation	Responsible
149	Inside Parameters:	Temp 73.7	RH 69.1	CO2 714	

EXCESS MOISTURE IN CLASSROOMS Indoor surfaces of exterior walls free of continuous condensation? No visible condensation or signs of water intrusion identified at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were not within acceptable range at the time of assessment. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level. PPO

Room	Section	Question	Answer	Recommendation	Responsible
152	Inside Parameters:	Temp 74.1	RH 66.7	CO2 782	

EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? Signs of water intrusion. Stained ceiling tiles. Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate. PPO

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were not within acceptable range at the time of assessment. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level. PPO

explain in the notes below.) range at the time of assessment. repair as appropriate to lower humidity level.

Room	Section	Question	Answer	Recommendation	Responsible
204	Inside Parameters:	Temp	RH	CO2	
		74.4	60.3	1179	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff. Site

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
208	Inside Parameters:	Temp	RH	CO2	
		73.5	58.2	1218	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Trash is removed daily and trash bags are changed as appropriate? No issues identified regarding trash removal practices.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? Stuffed animals and rug in the room. Remove stuffed animals and rugs. Site

THERMAL Temperature in my Temperature was

COMFORT classroom is generally comfortable (72F-78F)? acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
754	Inside Parameters:	Temp	RH	CO2	
		76.2	55.0	1170	

GENERAL CLEANLINESS Room is free of the use of scented cleaners and air fresheners? No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? Rug in the room. Remove rug from the room. Site

THERMAL COMFORT Room is free of the introduction of outdoor air? (Gaps in window/door frames.) No gaps in windows or doors identified at the time of assessment.

AIR CONDITIONING Windows/doors are operable and are kept closed? Windows are not operable. Open doors and windows allow humid untreated air into occupied environment. Physical Plant Operations to evaluate and repair as appropriate. However site based administration to encourage staff to keep doors and windows closed. PPO