

Park Springs Elementary
TfS IAQ Walkthrough
4-11-2008

Temp 80 RH 62 CO2 402

FISH	Answer	Recommendation
104	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
108	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	Stuffed animals in room.	Thoroughly clean stuffed animals regularly or remove from room. Stuffed animals are a source of allergens.
131	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
	Window was open at the time of the assessment.	Site based administration to advise staff to keep doors and windows closed. Open doors and windows allow untreated humid air into the environment.
138	Large stuffed bear in room.	Thoroughly clean stuffed animals regularly or remove from room. Stuffed animals are a source of allergens.
146	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
201	Occupant advised that sinks are clogged on a regular basis.	Site based administration to advise occupant to monitor what is put down the drains.
301	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
404	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.

Park Springs Elementary
TfS IAQ Walkthrough
4-11-2008

Temp 80 RH 62 CO2 402

	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
	Dust and dirt accumulation on floor.	Facilities Serviceperson to thoroughly clean and sanitize floor.
406	Room was slightly cluttered.	Site based administration to encourage occupant to reduce clutter to assist with cleaning efforts.
	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
407	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
409	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize floor.
420	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
509	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
510	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.

Park Springs Elementary
TfS IAQ Walkthrough
4-11-2008

Temp 80 RH 62 CO2 402

	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
601	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
602	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
604	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
608	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
850	Room was slightly cluttered.	Site based administration to encourage occupant to reduce clutter to assist with cleaning efforts.
	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
	Objects blocking return air vent.	Facilities serviceperson to remove object to prevent obstruction of return vent.
854	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment. Ant bait.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
862	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	Objects blocking return air vent.	Facilities serviceperson to remove object to prevent obstruction of return vent.
	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
864	Objects blocking return air vent.	Facilities serviceperson to remove object to prevent obstruction of return vent.
	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
865	Objects blocking return air vent.	Facilities serviceperson to remove object to prevent obstruction of return vent.

Site

**Park Springs Elementary
TfS IAQ Walkthrough
4-11-2008**

Temp 80 RH 62 CO2 402

885	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	Objects blocking return air vent.	Facilities serviceperson to remove object to prevent obstruction of return vent.