

Park Trails Elementary TfS IAQ Walkthrough 4-15-08

Outdoor Parameters: Temp 63.5 RH 42 CO2 0

FISH	Answer	Recommendation
101R	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
Submit		
	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
138	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
149	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
164	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
201	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
203	Dust observed on supply and registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
	Dust observed on supply and registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
205		
215	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	Dust observed on supply and registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Park Trails Elementary TfS IAQ Walkthrough 4-15-08

Outdoor Parameters: Temp 63.5 RH 42 CO2 0

FISH	Answer	Recommendation
	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
301	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
323	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
346V	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
745V	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.