

Report: Site

PINES LAKES ELEMENTARY

Walkthrough Date: 03/15/2007 Temp RH CO2

Outdoor Parameters: 70.2 58.8 887

Room	Priority	Responsible	Answer	Recommendation
115A	Inside Parameters:	Temp	RH	CO2
		71.9	49.5	843

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
119	Inside Parameters:	Temp	RH	CO2
		70.0	57.5	820

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Temperature was low at the time of the assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
121	Inside Parameters:	Temp	RH	CO2
		70.8	57.1	889

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust and dirt accumulation on floor. glue at tile joints Facilities serviceperson to thoroughly clean and sanitize.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom

communication among all stakeholders.

activities/conditions when necessary.

2

Site

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
125	Inside Parameters:	Temp	RH	CO2
		70.2	58.8	887

2

Site

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
126	Inside Parameters:	Temp	RH	CO2
		69.8	58.6	885

2

Site

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

2

Site

Dust observed on supply register at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
134	Inside Parameters:	Temp	RH	CO2
		71.4	51.2	899

2

Site

Slight dust accumulation was observed on environmental surfaces at the time of assessment. minor dust on elevated surfaces

Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
141	Inside Parameters:	Temp	RH	CO2
		72.5	50.1	1212

This is a general issue requiring approved

Site based administration is encouraged to communicate all known student

3 Site communication among all stakeholders. allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
142	Inside Parameters:	Temp	RH	CO2
		72.4	50.1	783

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
149	Inside Parameters:	Temp	RH	CO2
		76.8	57.4	514

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
164	Inside Parameters:	Temp	RH	CO2
		72.9	57.8	979

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
309	Inside Parameters:	Temp	RH	CO2
		70.9	54.2	943

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.