

Pinewood Elementary

IAQ Walkthrough 5/24/2005

2811

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
106	Temp <input type="text" value="74.8"/> RH% <input type="text" value="61.2"/> CO2 <input type="text" value="1284"/>	Occupants: <input type="text" value="2"/>			
LOCAL EXHAUST FANS					
Bathroom exhaust fan is functioning properly?	C. This room does not have a restroom.	No bathroom. Identified in error.	None		
THERMAL COMFORT					
Classroom is free of significant temperature shifts?	Temperature can shift from very cold to adequate from one day to the next.	Environmental parameters were within acceptable range at the time of assessment..	None		
Room is usually comfortable? (If no, please explain in the notes below.)	Temperature can shift from very cold to adequate from one day to the next.	Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?	Temperature can shift from very cold to adequate from one day to the next.	Temperature was acceptable at the time of assessment.	None		
Walkthrough					
		Carpet was stained.	Facilities serviceperson to thoroughly clean and sanitize carpet.	Site Based	2
		No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
108B	Temp <input type="text" value="73.1"/> RH% <input type="text" value="65.4"/> CO2 <input type="text" value="1391"/>	Occupants: <input type="text" value="10"/>			
LOCAL EXHAUST FANS					
Bathroom exhaust fan is functioning properly?	Do not have bathroom in room 108B.	No bathroom. Identified in error.	None		
Other exhaust fans that may exist in the classroom are functioning properly?	Do not have bathroom in room 108B.	No exhaust fans in room. Identified in error.	None		
Walkthrough					
		Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

109

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew? See previous comment. No odor detected at the time of assessment. None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room. None

THERMAL COMFORT

Classroom is free of significant temperature shifts? Moisture in room. Dehumidifier runs at night, and needs frequent emptying. A few staff members have complained about headaches and a few others have started to sneeze. One staff member complained that it smelled in our room. Environmental parameters were within acceptable range at the time of assessment.. None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Moisture in room. Dehumidifier runs at night, and needs frequent emptying. A few staff members have complained about headaches and a few others have started to sneeze. One staff member complained that it smelled in our room. Humidity was acceptable at the time of assessment. None

Room is usually comfortable? (If no, please explain in the notes below.) Moisture in room. Dehumidifier runs at night, and needs frequent emptying. A few staff members have complained about headaches and a few others have started to sneeze. One staff member complained that it smelled in our room. Environmental parameters were within acceptable range at the time of assessment.. None

Temperature in my classroom is generally comfortable (72F-76F)? Moisture in room. Dehumidifier runs at night, and needs frequent emptying. A few staff members have complained about headaches and a few others have started to sneeze. One staff member complained that it smelled in our room. Temperature was acceptable at the time of assessment. None

Walkthrough

Signs of water intrusion. Stained ceiling tiles. Physical Plant Operations to evaluate for leaks and repair as appropriate. Physical Plant Operations 1
 Stuffed animals in room. Occupant to remove stuffed animals. Site Based 2

112

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of kitchen/food? No odor detected at the time of assessment. None

Room is free of smell of mold or mildew? No odor detected at the time of assessment.

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
112	Temp	74.6	RH% 57.5	CO2 1157	Occupants:	3	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		Sometimes it can be very cold-68 degrees, other times it is fine.		Environmental parameters were within acceptable range at the time of assessment..	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Sometimes it can be very cold-68 degrees, other times it is fine.		Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		Sometimes it can be very cold-68 degrees, other times it is fine.		Environmental parameters were within acceptable range at the time of assessment..	None		
112A	Temp	74.6	RH% 57.5	CO2 1157	Occupants:		
AIR CONDITIONING							
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT							
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to open supply vents.	Site Based	1
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>112C</i>	Temp	<input type="text" value="72.1"/>	RH% <input type="text" value="68"/>	CO2 <input type="text" value="1273"/>	Occupants: <input type="text" value="3"/>		
AIR CONDITIONING							
Room is free of smell of kitchen/food?					No odor detected at the time of assessment.	None	
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					No leaks or signs of water intrusion identified.	None	
Classroom lavatories/water fountains free of leaks?					No leaks or signs of water intrusion identified.	None	
Cold water pipes free of continuous condensation?					No visible condensation at the time of assessment.	None	
Indoor surfaces of exterior walls free of continuous condensation?					No visible condensation at the time of assessment.	None	
Windows, windowsills and window frames free of continuous condensation?					No visible condensation at the time of assessment.	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None	
Walkthrough							
Live plants in room.					Facilities serviceperson should remove live plants	Site Based	1
Carpet was stained.					Facilities serviceperson to thoroughly clean and sanitize carpet.	Site Based	2
Humidity was slightly elevated at the time of assessment.					Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2

113A Temp RH% CO2 Occupants:

AIR CONDITIONING							
Room is free of smell of kitchen/food?					No odor detected at the time of assessment.	None	
Room is free of smell of mold or mildew?					No odor detected at the time of assessment.	None	

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

113A

Temp

75.2

RH%

57.9

CO2

1147

Occupants:

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

DRAIN TRAPS IN THE CLASSROOM

Water run in sinks at least once per week (about 2 cups of water).

There are sinks on the west wall that are no longer in use and need to be removed or capped or water ran to prevent sewer odor.

Physical Plant Operations to evaluate as appropriate.

Physical Plant Operations

2

EXCESS MOISTURE IN CLASSROOMS

Cold water pipes free of continuous condensation?

Classroom area ceiling is free and clear of discolorations, but over oven hood there is discoloration.

No visible condensation at the time of assessment.

None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

Room is free of pests?

No pests observed at the time of assessment.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Temperature was acceptable at the time of assessment.

None

Walkthrough

Dust and dirt accumulation on floor.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Ceiling tiles broken, damaged or missing.

Facilities serviceperson to replace damaged ceiling tiles.

Site Based

2

113B

Temp

73.8

RH%

64.9

CO2

1189

Occupants:

25

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

113B

Temp RH% CO2 Occupants:

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No issues identified at the time of assessment. None

Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)

No issues identified at the time of assessment. None

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

No issues identified at the time of assessment. None

Other exhaust fans that may exist in the classroom are functioning properly?

No issues identified at the time of assessment. None

Walkthrough

Dust observed on supply/return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site Based 2

Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site Based 2

Humidity was slightly elevated at the time of assessment. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level. Physical Plant Operations 2

113E

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site Based 3

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment. None

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room. None

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable. None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment. None

Room is free of pests?

No pests observed at the time of assessment. None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
113E	Temp	73.8	RH% 64.9	CO2 1189	Occupants:		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Humidity was slightly elevated at the time of assessment	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
116	Temp	73.6	RH% 60.5	CO2 1006	Occupants:	18	
AIR CONDITIONING							
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Room is free of pests?				No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
116	Temp	<input type="text" value="73.6"/>	RH%	<input type="text" value="60.5"/>	CO2	<input type="text" value="1006"/>	Occupants:	<input type="text" value="18"/>
THERMAL COMFORT								
Classroom is free of significant temperature shifts?			cold	Temperature was acceptable at the time of assessment.	None			
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			cold	No issues identified at the time of assessment.	None			
Room is usually comfortable? (If no, please explain in the notes below.)			cold	Environmental parameters were within acceptable range at the time of assessment..	None			
Temperature in my classroom is generally comfortable (72F-76F)?			cold	Temperature was acceptable at the time of assessment.	None			
Walkthrough								
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based		1
				Stuffed animals in room.	Occupant to remove stuffed animals.	Site Based		2
117	Temp	<input type="text" value="73.4"/>	RH%	<input type="text" value="62.9"/>	CO2	<input type="text" value="972"/>	Occupants:	<input type="text" value="27"/>
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
EXCESS MOISTURE IN CLASSROOMS								
Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None			
Classroom lavatories/water fountains free of leaks?				No leaks or signs of water intrusion identified.	None			
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None			
Room is free of pests?				No pests observed at the time of assessment.	None			
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None			
THERMAL COMFORT								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
117	Temp	73.4	RH% 62.9	CO2 972	Occupants: 27		
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		
	Walkthrough						
				Chalkboard being using causing excessive dust.	Site based administration is encouraged to replace chalkboards with whiteboard.	Site Based	3
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Signs of water intrusion at South wall tackable wall surface.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
118	Temp	71.6	RH% 63.9	CO2 1074	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?		c+d no exhaust fans exist	Dust observed on bathroom exhaust fan at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Other exhaust fans that may exist in the classroom are functioning properly?		c+d no exhaust fans exist	No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
118	Temp	71.6	RH% 63.9	CO2 1074	Occupants:			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?					No issues identified at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Walkthrough								
					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
119	Temp	71.8	RH% 63.7	CO2 1003	Occupants:	25		
AIR CONDITIONING								
Room is free of smell of chemicals?					No odor detected at the time of assessment.	None		
Room is free of smell of kitchen/food?					No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS								
Area around and under classroom sinks free of leaks?					No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT								
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)					Environmental parameters were within acceptable range at the time of assessment..	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
119	Temp	71.8	RH%	63.7	CO2	1003	Occupants:	25			
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None						
	Walkthrough										
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based					1
				Dust and debris in bathroom.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
				Evaluate baseboard at entrance of doorway.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations					2
120	Temp	71.8	RH%	62.4	CO2	912	Occupants:	0			
	AIR CONDITIONING										
	Room is free of smell of chemicals?			No odor detected at the time of assessment.	None						
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None						
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None						
	Indoor surfaces of exterior walls free of continuous condensation?			No visible condensation at the time of assessment.	None						
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed in corners of room at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
	Room is free of pests?			No pests observed at the time of assessment.	None						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>120</i>	Temp	71.8	RH% 62.4	CO2 912	Occupants: 0		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No issues identified at the time of assessment.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		It is either too cold or too warm.	Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		It is either too cold or too warm.	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		It is either too cold or too warm.	No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		It is either too cold or too warm.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		It is either too cold or too warm.	Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<i>121</i>	Temp	72	RH% 62.5	CO2 908	Occupants: 1		
AIR CONDITIONING							
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
121	Temp	<input type="text" value="72"/>	RH%	<input type="text" value="62.5"/>	CO2	<input type="text" value="908"/>	Occupants:	<input type="text" value="1"/>			
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	Room is free of pests?				No pests observed at the time of assessment.	None					
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None					
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None					
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		Drastic temperature changes;		Temperature was acceptable at the time of assessment.	None					
	Room is usually comfortable? (If no, please explain in the notes below.)		Drastic temperature changes;		Temperature was acceptable at the time of assessment.	None					
	Temperature in my classroom is generally comfortable (72F-76F)?		Drastic temperature changes;		Temperature was acceptable at the time of assessment.	None					
	Walkthrough										
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
					Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations				1
122	Temp	<input type="text" value="71.7"/>	RH%	<input type="text" value="63.8"/>	CO2	<input type="text" value="106"/>	Occupants:	<input type="text" value="0"/>			
	AIR CONDITIONING										
	Room is free of smell of kitchen/food?		mold/mildew smell under sink		No odor detected at the time of assessment.	None					
	Room is free of smell of mold or mildew?		mold/mildew smell under sink		No odor detected at the time of assessment.	None					
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
122	Temp	71.7	RH% 63.8	CO2 106	Occupants: 0		
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		varies from cold to hot; not a median for comfortability		Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		varies from cold to hot; not a median for comfortability		Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		varies from cold to hot; not a median for comfortability		Temperature was acceptable at the time of assessment.	None	
Walkthrough							
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
123	Temp	72.4	RH% 61.9	CO2 1120	Occupants: 17		
AIR CONDITIONING							
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None	
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
Walkthrough							
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
124	Temp	72.8	RH% 61.7	CO2 1065	Occupants: 1		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	2
	Room is free of pests?				No pests observed at the time of assessment.	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	NO restroom in classroom			No issues identified at the time of assessment.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?	NO restroom in classroom			No issues identified at the time of assessment.	None	
Walkthrough							
					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	2
					Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	2
125	Temp	72.6	RH% 62.5	CO2 1133	Occupants: 22		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	It can be real cold or warm at times			Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	It can be real cold or warm at times			Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	It can be real cold or warm at times			Temperature was acceptable at the time of assessment.	None	
Walkthrough							
					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
125	Temp	72.6	RH% 62.5	CO2 1133	Occupants: 22		
				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
126	Temp	74.8	RH% 59.5	CO2 1200	Occupants:		
AIR CONDITIONING							
				No odor detected at the time of assessment.	None		
				No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
GENERAL CLEANLINESS							
				No dust observed on supply/return registers at the time of assessment.	None		
				There does not appear to be a dusting issue within this room.	None		
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
LOCKER ROOM							
				No issues identified at the time of assessment.	None		
Walkthrough							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
126	Temp	74.8	RH% 59.5	CO2 1200	Occupants: <input type="text"/>		
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
127	Temp	74.4	RH% 58.8	CO2 1131	Occupants: <input type="text" value="1"/>		
EXCESS MOISTURE IN CLASSROOMS							
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
GENERAL CLEANLINESS							
				No dust observed on supply/return registers at the time of assessment.	None		
				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				No pests observed at the time of assessment.	None		
THERMAL COMFORT							
				The classroom is often very cold. Students pull their arms into their shirts to keep warm.	Temperature was acceptable at the time of assessment.	None	
				The classroom is often very cold. Students pull their arms into their shirts to keep warm.	Temperature was acceptable at the time of assessment.	None	
				The classroom is often very cold. Students pull their arms into their shirts to keep warm.	Temperature was acceptable at the time of assessment.	None	
Walkthrough							
				Sink is clogged.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
129	Temp	73.2	RH% 59.1	CO2 1181	Occupants: 17		
AIR CONDITIONING							
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Return register cover is missing.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		room is usually too cold		Temperature was acceptable at the time of assessment.	None		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		room is usually too cold		No issues identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		room is usually too cold		Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?		room is usually too cold		Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Stuffed animals and bean bag chair in room.	Occupant to remove stuffed animals and bean bag chair.	Site Based	2
129A	Temp		RH%	CO2	Occupants:		
Walkthrough							
				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
130	Temp	72.9	RH% 60.5	CO2 1181	Occupants:		
GENERAL CLEANLINESS							
Room is free of pests?				No pests observed at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		very cold on a daily basis		Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		very cold on a daily basis		Environmental parameters were within acceptable range at the time of assessment..	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
130	Temp	<input type="text" value="72.9"/>	RH% <input type="text" value="60.5"/>	CO2 <input type="text" value="1181"/>	Occupants: <input type="text"/>		
	Temperature in my classroom is generally comfortable (72F-76F)?		very cold on a daily basis	Temperature was acceptable at the time of assessment.	None		
	Walkthrough			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Throw rug in room.	Occupant to remove throw rug.	Site Based	2
131	Temp	<input type="text" value="72.5"/>	RH% <input type="text" value="63.1"/>	CO2 <input type="text" value="1312"/>	Occupants: <input type="text" value="19"/>		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		room is usually cold	Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		room is usually cold	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		room is usually cold	Temperature was acceptable at the time of assessment.	None		
	Walkthrough			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment - potting soil.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
131A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	Walkthrough			Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
133	Temp	<input type="text" value="74"/>	RH% <input type="text" value="56.1"/>	CO2 <input type="text" value="1183"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None		
	ANIMALS IN THE CLASSROOM						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
133	Temp	74	RH% 56.1	CO2 1183	Occupants:		
	Activities and/or room conditions are modified to address student allergies?	This room is a computer lab and houses all of our student population, not just a small portion. Addressing individual needs is not specifically addressed due to short duration of time by students in the lab (1/2 hour every 6 days).			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?	This room is a computer lab and houses all of our student population, not just a small portion. Addressing individual needs is not specifically addressed due to short duration of time by students in the lab (1/2 hour every 6 days).			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply/return registers at the time of assessment.			Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.			None		
	Floor is cleaned on a regular basis?	Carpet was stained and worn.			Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	No issues identified at the time of assessment.			None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No issues identified at the time of assessment.			None		
	Other exhaust fans that may exist in the classroom are functioning properly?	No issues identified at the time of assessment.			None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	This room typically is very hot with high humidity.			Environmental parameters were within acceptable range at the time of assessment..	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	This room typically is very hot with high humidity.			Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	This room typically is very hot with high humidity.			Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	This room typically is very hot with high humidity.			Temperature was acceptable at the time of assessment.	None	
Walkthrough							
		Live plants and stuffed animals in room.			Occupant to remove stuffed animals and live plants from room.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
133	Temp	74	RH% 56.1	CO2 1183	Occupants:		
134	Temp	74	RH% 59.4	CO2 1312	Occupants:	19	
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
Classroom lavatories/water fountains free of leaks?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				No issues identified at the time of assessment.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None		
Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
135	Temp	73	RH% 63.5	CO2 1235	Occupants:	29	
AIR CONDITIONING							
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
135	Temp	73	RH% 63.5	CO2 1235	Occupants: 29			
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Signs of water intrusion. Stained ceiling tiles above stove and by clock.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Room is free of pests?					No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?			No bathroom exhaust fans....		No issues identified at the time of assessment.	None		
Other exhaust fans that may exist in the classroom are functioning properly?			No bathroom exhaust fans....		No issues identified at the time of assessment.	None		
THERMAL COMFORT								
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)					No issues identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)					Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was acceptable at the time of assessment.	None		

137

Temp 74.3 RH% 59.3 CO2 1074 Occupants: 16

AIR CONDITIONING

Room is free of smell of mold or mildew?

No odor detected at the time of assessment. None

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
137	Temp	74.3	RH% 59.3	CO2 1074	Occupants: 16		
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	DRAIN TRAPS IN THE CLASSROOM						
	Water poured down floor drains once per week (approx. 1 quart of water).				No issues identified at the time of assessment.	None	
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Tackable wall behind stove needs to be replaced.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	Classroom lavatories/water fountains free of leaks?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	None	
	Cold water pipes free of continuous condensation?				No visible condensation at the time of assessment.	None	
	Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Temperature fluctuates a great deal. It is usually too hot.		Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
137	Temp	74.3	RH% 59.3	CO2 1074	Occupants: 16			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Temperature fluctuates a great deal. It is usually too hot.			Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature fluctuates a great deal. It is usually too hot.			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature fluctuates a great deal. It is usually too hot.			Temperature was acceptable at the time of assessment.	None		
Walkthrough								
				Dust observed on exhaust fan in 137A at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
138	Temp	74.2	RH% 59.4	CO2 1117	Occupants: 0			
EXCESS MOISTURE IN CLASSROOMS								
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Tackable wall (North) needs to be replaced.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None		
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Floor is SWEPT on a regular basis, not mopped. I have never seen my room dusted. As discovered by my allergist, I am severely allergic to mold, mildew and dust. I need to wear a surgical mask over my nose and mouth when I dust.			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?	Floor is SWEPT on a regular basis, not mopped. I have never seen my room dusted. As discovered by my allergist, I am severely allergic to mold, mildew and dust. I need to wear a surgical mask over my nose and mouth when I dust.			There does not appear to be a dusting issue within this room.	None		
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	My room is often "stuffy." Some students and I are often very warm in the classroom.			Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
138	Temp	74.2	RH%	59.4	CO2	1117	Occupants:	0			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		My room is often "stuffy." Some students and I are often very warm in the classroom.	Humidity was acceptable at the time of assessment.	None						
	Room is usually comfortable? (If no, please explain in the notes below.)		My room is often "stuffy." Some students and I are often very warm in the classroom.	Environmental parameters were within acceptable range at the time of assessment..	None						
	Temperature in my classroom is generally comfortable (72F-76F)?		My room is often "stuffy." Some students and I are often very warm in the classroom.	Temperature was acceptable at the time of assessment.	None						
139	Temp	74.9	RH%	60.3	CO2	961	Occupants:	2			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?						Odor detected. Appears to be from stuffed animals in room.	Occupant to remove stuffed animals.	Site Based		1
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?							Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
	EXCESS MOISTURE IN CLASSROOMS										
	Area around and under classroom sinks free of leaks?						No leaks or signs of water intrusion identified.	None			
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?						No leaks or signs of water intrusion identified.	None			
	Classroom lavatories/water fountains free of leaks?						No leaks or signs of water intrusion identified.	None			
	Indoor surfaces of exterior walls free of continuous condensation?						No visible condensation at the time of assessment.	None			
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based		2
	Classroom is dusted/vacuumed thoroughly and regularly?						There does not appear to be a dusting issue within this room.	None			
	Classrooms general appearance is clean and acceptable?						General cleanliness of the room at the time of assessment was acceptable.	None			
	Floor is cleaned on a regular basis?						Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based		2
	LOCAL EXHAUST FANS										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
139	Temp	74.9	RH% 60.3	CO2 961	Occupants: 2		
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations 1
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No issues identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	
	Walkthrough						
					Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations 1
141	Temp	76.5	RH% 58.2	CO2 878	Occupants: 11		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	LOCAL EXHAUST FANS						
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Walkthrough						
					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
141	Temp	<input type="text" value="76.5"/>	RH% <input type="text" value="58.2"/>	CO2 <input type="text" value="878"/>	Occupants: <input type="text" value="11"/>		
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
141A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
142	Temp	<input type="text" value="75.3"/>	RH% <input type="text" value="60.7"/>	CO2 <input type="text" value="916"/>	Occupants: <input type="text" value="10"/>		
AIR CONDITIONING							
	Air flowing from air supply?			Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No issues identified at the time of assessment.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		The temperature goes from one extreme to the other. The room is either too hot or too cold.	Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The temperature goes from one extreme to the other. The room is either too hot or too cold.	Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		The temperature goes from one extreme to the other. The room is either too hot or too cold.	No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		The temperature goes from one extreme to the other. The room is either too hot or too cold.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		The temperature goes from one extreme to the other. The room is either too hot or too cold.	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
144	Temp	76.7	RH% 56.7	CO2 982	Occupants: 11		
AIR CONDITIONING							
Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None		
Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None		
Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None		
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None		
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
Classroom lavatories/water fountains free of leaks?				No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Room is free of pests?				No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
My classroom has sufficient exhaust systems based on the activities/functionality of the room?				Dust observed on exhaust fan at the time of assessment and fan grill was closed.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner and open grill.	Site Based	2
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
144	Temp	76.7	RH% 56.7	CO2 982	Occupants: 11		
	Classroom is free of significant temperature shifts?			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was elevated at the time of assessment.	See other recommendation.		
145	Temp	75.3	RH% 63.7	CO2 933	Occupants: 0		
	AIR CONDITIONING						
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No visible condensation at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No visible condensation at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
145	Temp	75.3	RH% 63.7	CO2 933	Occupants: 0		
	Room is free of pests?				No pests observed at the time of assessment.	None	
	THERMAL COMFORT						
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No issues identified at the time of assessment.	None	
148	Temp	76.6	RH% 61.3	CO2 845	Occupants:		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	THERMAL COMFORT						
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No issues identified at the time of assessment.	None	
155	Temp	73.6	RH% 57.6	CO2 1161	Occupants: 26		
	AIR CONDITIONING						
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None	
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				Carpeting is harboring old dust and mold. No matter how many times it is vacuumed, it really needs to be replaced.	Carpet was stained and worn.	Physical Plant Operations to evaluate and repair/replace as appropriate. Physical Plant Operations 2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				Carpeting is harboring old dust and mold. No matter how many times it is vacuumed, it really needs to be replaced.	No issues identified at the time of assessment.	None
	Walkthrough						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
155	Temp	73.6	RH% 57.6	CO2 1161	Occupants: 26		
				Ceiling tiles and ceiling grid broken, damaged or missing.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
304	Temp	76.6	RH% 43.6	CO2 702	Occupants:		
AIR CONDITIONING							
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None		
	Water run in sinks at least once per week (about 2 cups of water).			No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles above clock.	Site Based	2
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Room is dusty. Needs to be vacuumed everyday. Also, needs to be sprayed for ants, that come and go.	Return vents closed and dust accumulation observed at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner and open vents.	Site Based	1
	Classroom is dusted/vacuumed thoroughly and regularly?		Room is dusty. Needs to be vacuumed everyday. Also, needs to be sprayed for ants, that come and go.	There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?		Room is dusty. Needs to be vacuumed everyday. Also, needs to be sprayed for ants, that come and go.	General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?		Room is dusty. Needs to be vacuumed everyday. Also, needs to be sprayed for ants, that come and go.	Floor was clean at the time of assessment.	None		
	Food, if any, is stored in tightly sealed containers?		Room is dusty. Needs to be vacuumed everyday. Also, needs to be sprayed for ants, that come and go.	No issues identified at the time of assessment.	None		
	Room is free of pests?		Room is dusty. Needs to be vacuumed everyday. Also, needs to be sprayed for ants, that come and go.	No pests observed at the time of assessment.	None		

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
304	Temp	76.6	RH% 43.6	CO2 702	Occupants: <input type="text"/>		
				Stuffed animals in room.	Occupant should remove stuffed animals.	Site Based	2
305	Temp	74.7	RH% 46.5	CO2 589	Occupants: <input type="text" value="18"/>		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	Room is free of smell of vehicle exhaust?			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
	Windows, windowsills and window frames free of continuous condensation?			No visible condensation at the time of assessment.	None		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		The temperature fluctuates too much in the classroom.	Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The temperature fluctuates too much in the classroom.	Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		The temperature fluctuates too much in the classroom.	No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		The temperature fluctuates too much in the classroom.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		The temperature fluctuates too much in the classroom.	Temperature was acceptable at the time of assessment.	None		

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
305	Temp	<input type="text" value="74.7"/>	RH% <input type="text" value="46.5"/>	CO2 <input type="text" value="589"/>	Occupants: <input type="text" value="18"/>		
				Stuffed animals in room.	Occupant should remove stuffed animals.	Site Based	2
				Return vents closed at the time of assessment.	Facilities serviceperson to open return vents.	Site Based	1
				Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
305A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
306	Temp	<input type="text" value="75.6"/>	RH% <input type="text" value="45.2"/>	CO2 <input type="text" value="702"/>	Occupants: <input type="text" value="18"/>		
AIR CONDITIONING							
Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None		
Room is free of smell of vehicle exhaust?				No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No issues identified at the time of assessment.	None		
Walkthrough				Dust and debris on window screens.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Carpet was stained and buckled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
307	Temp	76.1	RH% 44.1	CO2 663	Occupants:	12	
AIR CONDITIONING							
	Air flowing from air supply?			Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	Windows/doors are operable and are kept closed?			No issues identified at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	Classroom is free of animals and pets?			No animals identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No visible condensation at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No visible condensation at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
307	Temp	<input type="text" value="76.1"/>	RH% <input type="text" value="44.1"/>	CO2 <input type="text" value="663"/>	Occupants: <input type="text" value="12"/>		
	Classroom is free of significant temperature shifts?			Temperature was slightly elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Environmental parameters were not within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was slightly elevated at the time of assessment.	See other recommendation.		
	Walkthrough			Dust and debris on window screens.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
308	Temp	<input type="text" value="75.7"/>	RH% <input type="text" value="42.9"/>	CO2 <input type="text" value="658"/>	Occupants: <input type="text" value="18"/>		
	GENERAL CLEANLINESS						
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Wakthrough			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Walkthrough			Dust and debris on window screens.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
308A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	Walkthrough			Dust observed on bathroom exhaust fan at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
308A	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
309	Temp <input type="text" value="75.6"/> RH% <input type="text" value="43.2"/> CO2 <input type="text" value="682"/>	Occupants: <input type="text" value="16"/>			
GENERAL CLEANLINESS					
Room is free of pests?		Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
Walkthrough		Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
		Return vents closed at the time of assessment.	Facilities serviceperson to open return vents.	Site Based	1
		Dust and debris on window screens.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
		Dust and debris on window screens.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
309A	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
Walkthrough		No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
358V	Temp <input type="text" value="82.6"/> RH% <input type="text" value="40"/> CO2 <input type="text" value="1303"/>	Occupants: <input type="text" value="16"/>			
GENERAL CLEANLINESS					
Room is free of pests?		No pests observed at the time of assessment.	None		
Walkthrough		Temperature was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	1

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
359V	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
	EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.	None		
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly?	classroom is rarely dusted There does not appear to be a dusting issue within this room.	None		
401	Temp <input type="text" value="79.5"/> RH% <input type="text" value="43.3"/> CO2 <input type="text" value="1107"/>	Occupants: <input type="text" value="5"/>			
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly?	This room has 401A attached, a bathroom. There is no fan. Floors and bathroom are cleaned but nothing is dusted. There does not appear to be a dusting issue within this room.	None		
	LOCAL EXHAUST FANS Bathroom exhaust fan is functioning properly? My classroom has sufficient exhaust systems based on the activities/functionality of the room?	Bathroom exhaust fan is not functioning properly. No issues identified at the time of assessment.	Physical Plant Operations to evaluate and repair/replace as appropriate. None	Physical Plant Operations	1
	THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Temperature in my classroom is generally comfortable (72F-76F)?	Students complain that it is cold. Students complain that it is cold. Temperature was elevated at the time of assessment. Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. See other recommendation.	Site Based	2
	Walkthrough	Dust observed on supply/return registers at the time of assessment. Carpet was stained.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Facilities serviceperson to thoroughly clean and sanitize carpet.	Site Based Site Based	2 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
402	Temp	74	RH% 47.8	CO2 1160	Occupants: 20		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		Room is sometimes too cold.		Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?		Room is sometimes too cold.		Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Stuffed animals in room.	Occupant should remove stuffed animals.	Site Based	2
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust and debris on window screens.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

403	Temp	74.1	RH% 50.7	CO2 1054	Occupants: 1		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		Room is generally very cold. Students often need sweaters/jackets.		Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		Room is generally very cold. Students often need sweaters/jackets.		Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?		Room is generally very cold. Students often need sweaters/jackets.		Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Carpet was stained.	Facilities serviceperson to thoroughly clean and sanitize carpet.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
405	Temp	72.6	RH% 52.2	CO2 982	Occupants:	0	
AIR CONDITIONING							
	Air is flowing without obstruction?	Restroom reeks of urine		Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of mold or mildew?	Restroom reeks of urine		No odor detected at the time of assessment.	None		
	Windows/doors are operable and are kept closed?	Restroom reeks of urine		Window screens need to be replaced.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion by windows. Exterior window corner bead is split and separating.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	Classroom lavatories/water fountains free of leaks?			No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	wall falling apart due to water damage, windows do not shut completely, ANTS		Broken return air register.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Classroom is dusted/vacuumed thoroughly and regularly?	wall falling apart due to water damage, windows do not shut completely, ANTS		There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?	wall falling apart due to water damage, windows do not shut completely, ANTS		General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?	wall falling apart due to water damage, windows do not shut completely, ANTS		Carpet was stained and worn.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Room is free of pests?	wall falling apart due to water damage, windows do not shut completely, ANTS		No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	too hot all the time, children often complain of heat; teacher feels it is too hot		Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	too hot all the time, children often complain of heat; teacher feels it is too hot		Humidity was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
405	Temp	72.6	RH% 52.2	CO2 982	Occupants: 0		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	too hot all the time, children often complain of heat; teacher feels it is too hot			No issues identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	too hot all the time, children often complain of heat; teacher feels it is too hot			Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	too hot all the time, children often complain of heat; teacher feels it is too hot			Temperature was acceptable at the time of assessment.	None	
	Walkthrough				Stuffed animals in room.	Occupant should remove stuffed animals.	Site Based 2
406	Temp	72.1	RH% 51.4	CO2 1275	Occupants: 21		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	
	Walkthrough				Window does not close properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
					Dust and debris on window screens.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
					Stuffed animals in room.	Occupant should remove stuffed animals.	Site Based 2
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
407	Temp	73.2	RH% 53.1	CO2 1067	Occupants: 18		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Tackable wall on north wall and above stove.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
407	Temp	73.2	RH% 53.1	CO2 1067	Occupants:	18	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	
Room is free of pests?					No pests observed at the time of assessment.	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None	
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was acceptable at the time of assessment.	None	
Walkthrough							
Window is stuck in open position.						Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
Stuffed animals in room.						Occupant should remove stuffed animals.	Site Based 2
Dust and debris on window screens.						Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
440P	Temp	82.6	RH% 40.7	CO2 1594	Occupants:	12	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					No leaks or signs of water intrusion identified.	None	
Classroom lavatories/water fountains free of leaks?					No leaks or signs of water intrusion identified.	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
440P	Temp	82.6	RH% 40.7	CO2 1594	Occupants: 12		
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?		Bathroom fan is excessively noisy. Children are almost afraid to go into the bathroom, it is so noisy. The noise is disruptive.		Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations 2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Room gets excessively hot in the afternoon. Once the room gets too hot, it will not cool down.		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Room gets excessively hot in the afternoon. Once the room gets too hot, it will not cool down.		Humidity was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Room gets excessively hot in the afternoon. Once the room gets too hot, it will not cool down.		No issues identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Room gets excessively hot in the afternoon. Once the room gets too hot, it will not cool down.		Temperature was elevated at the time of assessment.	See other recommendation.	
	Temperature in my classroom is generally comfortable (72F-76F)?		Room gets excessively hot in the afternoon. Once the room gets too hot, it will not cool down.		Temperature was elevated at the time of assessment.	See other recommendation.	
	Walkthrough						
					Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.	Physical Plant Operations 1
					Dust and debris on HVAC filters.	Facilities serviceperson to replace HVAC filters.	Site Based 1

751

Temp 81.5 RH% 43.5 CO2 808 Occupants: 17

AIR CONDITIONING

Room is free of smell of mold or mildew?

No odor detected at the time of assessment. None

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

751

Temp RH% CO2 Occupants:

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Mold and mildew has been cleaned, removed and has returned. There is discoloration.

No leaks or signs of water intrusion identified.

None

Indoor surfaces of exterior walls free of continuous condensation?

Mold and mildew has been cleaned, removed and has returned. There is discoloration.

No visible condensation at the time of assessment.

None

Windows, windowsills and window frames free of continuous condensation?

Mold and mildew has been cleaned, removed and has returned. There is discoloration.

No visible condensation at the time of assessment.

None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Floor is not washed regularly, only vacuumed or swept.

No dust observed on supply/return registers at the time of assessment.

None

Classroom is dusted/vacuumed thoroughly and regularly?

Floor is not washed regularly, only vacuumed or swept.

There does not appear to be a dusting issue within this room.

None

Floor is cleaned on a regular basis?

Floor is not washed regularly, only vacuumed or swept.

Floor was clean at the time of assessment.

None

Room is free of pests?

Floor is not washed regularly, only vacuumed or swept.

No pests observed at the time of assessment.

None

THERMAL COMFORT

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

I have my own control as it is a module.

No issues identified at the time of assessment.

None

Walkthrough

Shelving is blocking return air register.

Facilities serviceperson should move shelving.

Site Based

1

Ant trap is on ceiling by teacher's desk.

Facilities serviceperson should remove ant trap.

Site Based

1

752

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.

Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.

Site Based

1

EXCESS MOISTURE IN CLASSROOMS

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
752	Temp	78.3	RH% 58.9	CO2 1100	Occupants: 17		
	Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Room is free of pests?				No pests observed at the time of assessment.	None	
	Walkthrough						
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
					Temperature was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 1
					Stuffed animals in room.	Occupant should remove stuffed animals.	Site Based 2
753	Temp	84.2	RH% 56.1	CO2 481	Occupants: 9		
	AIR CONDITIONING						
	Air is flowing without obstruction?		It smells very musty in the room.		Air flowing without obstruction at the time of assessments.	None	
	Room is free of smell of mold or mildew?		It smells very musty in the room.		No odor detected at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		It either gets very cold or very hot., The classroom temperature goes from very cold to very warm, there seems no inbetween.		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		It either gets very cold or very hot., The classroom temperature goes from very cold to very warm, there seems no inbetween.		Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		It either gets very cold or very hot., The classroom temperature goes from very cold to very warm, there seems no inbetween.		Temperature was elevated at the time of assessment.	See other recommendation.	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
753	Temp	84.2	RH%	56.1	CO2	481	Occupants:	9			
	Temperature in my classroom is generally comfortable (72F-76F)?		It either gets very cold or very hot., The classroom temperature goes from very cold to very warm, there seems no inbetween.	Temperature was elevated at the time of assessment.	See other recommendation.						
	Walkthrough			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
754	Temp	80.4	RH%	52.2	CO2	752	Occupants:	19			
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None						
	GENERAL CLEANLINESS										
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None						
	Walkthrough			Stuffed animals in room.	Occupant should remove stuffed animals.	Site Based					2
				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations					1
852	Temp	76.5	RH%	50.5	CO2	916	Occupants:	0			
	GENERAL CLEANLINESS										
	Room is free of pests?			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations					1
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?		no bathroom in my class	No bathroom. Identified in error.	None						
	Other exhaust fans that may exist in the classroom are functioning properly?		no bathroom in my class	No issues identified at the time of assessment.	None						
	Walkthrough										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
852	Temp	<input type="text" value="76.5"/>	RH% <input type="text" value="50.5"/>	CO2 <input type="text" value="916"/>	Occupants: <input type="text" value="0"/>		
				Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.	Physical Plant Operations	2
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
853	Temp	<input type="text" value="75.7"/>	RH% <input type="text" value="65.7"/>	CO2 <input type="text" value="964"/>	Occupants: <input type="text" value="0"/>		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?		I do not have a bathroom, so the bathroom exhaust question is not applicable.		No bathroom. Identified in error.	None	
	Walkthrough						
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.	Physical Plant Operations	2
854	Temp	<input type="text" value="80.4"/>	RH% <input type="text" value="56.7"/>	CO2 <input type="text" value="816"/>	Occupants: <input type="text" value="17"/>		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Walkthrough						
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Temperature was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	1
F149	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	Walkthrough						
				Standing water in drain pan - AHU.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
				Light bulbs, fixtures, desks and other items are stored in this room.	Facilities serviceperson should remove stored items from room.	Site Based	2