

# Tools for Schools Phase II - Indoor Air Quality

## Follow-up Action Plan for Physical Plant Operations



Pompano Beach Elementary

0751

Principal: Dr. Garie Rose

Walkthrough Date: 5/9/2005

Temp RH Co2  
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
131	2	Physical Plant Operations	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.
132	2	Physical Plant Operations	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.
202	2	Physical Plant Operations	Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
409	3	Physical Plant Operations	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
420	1	Physical Plant Operations	Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.
501	2	Physical Plant Operations	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.
507	1	Physical Plant Operations	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.
507	2	Physical Plant Operations	Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
782C	2	Physical Plant Operations	Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.
782C	2	Physical Plant Operations	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.