

Tools for Schools Phase II - Indoor Air Quality

Follow-up Action Plan for Site Based



Pompano Beach Elementary

0751

Principal: Dr. Garie Rose

Walkthrough Date: 5/9/2005

Temp RH Co2
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
106	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
126	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
127	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
130	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
131	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
132	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
132	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
132	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
202	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
202	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
202	3	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
404	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
404	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Response	Recommendation
406	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
407	2	Site Based	Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.
407	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
407	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
409	2	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
410	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
410	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
502	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
503	2	Site Based	Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.
503	2	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
503	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
507	2	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Response	Recommendation
507	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
512	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
512	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
607	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
782C	2	Site Based	Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.
782C	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.