

# Pompano Beach Elementary

## IAQ Walkthrough 5/9/2005

0751

Outside Temp  RH%  CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
106	Temp <input type="text" value="74.8"/> RH% <input type="text" value="52.3"/> CO2 <input type="text" value="859"/>	Occupants: <input type="text" value="3"/>			
	<b>GENERAL CLEANLINESS</b>				
	Room is free of pests?	No pests observed at the time of assessment.	None		
	<b>LOCAL EXHAUST FANS</b>				
	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is functioning properly.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.	None		
	<b>THERMAL COMFORT</b>				
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.	None		
108	Temp <input type="text" value="74.9"/> RH% <input type="text" value="50.9"/> CO2 <input type="text" value="812"/>	Occupants: <input type="text" value="2"/>			
	<b>GENERAL CLEANLINESS</b>				
	Room is free of pests?	No pests observed at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
126	Temp	<input type="text" value="74.2"/>	RH% <input type="text" value="54.2"/>	CO2 <input type="text" value="866"/>	Occupants: <input type="text" value="5"/>		
<b>ANIMALS IN THE CLASSROOM</b>							
Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
127	Temp	<input type="text" value="73.1"/>	RH% <input type="text" value="54.4"/>	CO2 <input type="text" value="840"/>	Occupants: <input type="text" value="2"/>		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
130	Temp	<input type="text" value="73.0"/>	RH% <input type="text" value="49.0"/>	CO2 <input type="text" value="1710"/>	Occupants: <input type="text" value="17"/>		
<b>AIR CONDITIONING</b>							
Room is free of smell of mold or mildew?			No odor detected at the time of assessment.		None		
<b>GENERAL CLEANLINESS</b>							
Room is free of pests?			No pests observed at the time of assessment.		None		
Room is free of the use of scented cleaners and air fresheners?			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.		None		
<b>LOCAL EXHAUST FANS</b>							
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			It appears that the ventilation system is adequate based on room activities.		None		
<b>Walkthrough</b>							
			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.		Facilities serviceperson should monitor this room.	Site Based	2
130A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<b>GENERAL CLEANLINESS</b>							
Classrooms general appearance is clean and acceptable?			Art room floor needs to be mopped more often. Floor is stained and we often use the floor area for reading.		General cleanliness of the room at the time of assessment was acceptable.	None	

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
130A	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/> Floor is cleaned on a regular basis?	Occupants: <input type="text"/> Floor was clean at the time of assessment.	None		
131	Temp <input type="text"/> 74.2 RH% <input type="text"/> 51.6 CO2 <input type="text"/> 1116 ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students?	Occupants: <input type="text"/> 20 This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS Room is free of pests?	No pests observed at the time of assessment.	None		
	Walkthrough	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	2
132	Temp <input type="text"/> 72.9 RH% <input type="text"/> 53.4 CO2 <input type="text"/> 1152 EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Occupants: <input type="text"/> 17 Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	2
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
132	Temp	72.9	RH%	53.4	CO2	1152	Occupants:	17			
	Temperature in my classroom is generally comfortable (72F-76F)?		During winter months my room is uncomfortable. We just found out that the builders DID NOT install a heating unit into this room. Air flow has been turned down to low however, aircondition is always flowing.	Temperature was acceptable at the time of assessment.			None				
136	Temp	72.4	RH%	59.9	CO2	696	Occupants:	3			
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Mr. Levi is a wonderful custodian.	No dust observed on supply/return registers at the time of assessment.			None				
	Classroom is dusted/vacuumed thoroughly and regularly?		Mr. Levi is a wonderful custodian.	General cleanliness of the room at the time of assessment was acceptable.			None				
	Floor is cleaned on a regular basis?		Mr. Levi is a wonderful custodian.	Floor was clean at the time of assessment.			None				
	Food, if any, is stored in tightly sealed containers?		Mr. Levi is a wonderful custodian.	No unsealed food items were observed at the time of assessment.			None				
	Room is free of pests?		Mr. Levi is a wonderful custodian.	No pests observed at the time of assessment.			None				
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.			None				
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.			None				
138	Temp	73.0	RH%	65.9	CO2	614	Occupants:	11			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?		Our custodians are overworked and underpaid. I think they do the best they can.	General cleanliness of the room at the time of assessment was acceptable.			None				
139	Temp	72.1	RH%	62.4	CO2	837	Occupants:	10			
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		Air is turned off in the evenings and weekends. This causes a musty smell along with causing bulletins to fall off the walls.	Temperature was acceptable at the time of assessment.			None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
146	Temp	72.3	RH% 64.7	CO2 813	Occupants: 7		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?	Not a regular classroom. Room used as a timeout room. Some ants present. Cleaners used in routine operation of time out equipment. Custodial staff is very responsive to requests for clean ups etc.			General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?	Not a regular classroom. Room used as a timeout room. Some ants present. Cleaners used in routine operation of time out equipment. Custodial staff is very responsive to requests for clean ups etc.			Floor was clean at the time of assessment.	None	
	Room is free of the use of scented cleaners and air fresheners?	Not a regular classroom. Room used as a timeout room. Some ants present. Cleaners used in routine operation of time out equipment. Custodial staff is very responsive to requests for clean ups etc.			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	
202	Temp	75.6	RH% 56.9	CO2 903	Occupants: 21		
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Floor was clean at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?	The a/c is too cold and the only way to regulate it seems to be to turn it off, then back on, off, etc.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	The a/c is too cold and the only way to regulate it seems to be to turn it off, then back on, off, etc.			Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)	The a/c is too cold and the only way to regulate it seems to be to turn it off, then back on, off, etc.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
	Temperature in my classroom is generally comfortable (72F-76F)?	The a/c is too cold and the only way to regulate it seems to be to turn it off, then back on, off, etc.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
301E	Temp	72.9	RH% 51.5	CO2 888	Occupants: 2		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None		
Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.		None		
Room is free of pests?			No pests observed at the time of assessment.		None		
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.		None		
Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.		None		
404	Temp	72.4	RH% 52.1	CO2 1810	Occupants: 23		
<b>ANIMALS IN THE CLASSROOM</b>							
You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		3
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Our custodians do an excellent job especially considering they are understaffed and overworked.		Site based administration should address general cleanliness with facility serviceperson staff.		2
Room is free of the use of scented cleaners and air fresheners?			Our custodians do an excellent job especially considering they are understaffed and overworked.		None		
406	Temp	74.8	RH% 47.4	CO2 1835	Occupants: 25		
<b>ANIMALS IN THE CLASSROOM</b>							
You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		3
<b>GENERAL CLEANLINESS</b>							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
406	Temp	74.8	RH% 47.4	CO2 1835	Occupants: 25			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Our custodians are wonderful. They are overworked, understaffed, and underpaid. We do have a problem with brown recluse spiders that should be address more seriously by the county.			No dust observed on supply/return registers at the time of assessment.	None		
	Room is free of the use of scented cleaners and air fresheners?	Our custodians are wonderful. They are overworked, understaffed, and underpaid. We do have a problem with brown recluse spiders that should be address more seriously by the county.			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
407	Temp	73.8	RH% 49.8	CO2 1781	Occupants: 28			
<b>ANIMALS IN THE CLASSROOM</b>								
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>ART SUPPLIES</b>								
	Science supplies okay?				No science supplies in room. Room not being used as a science room.	None		
<b>GENERAL CLEANLINESS</b>								
	Room is free of pests?				No pests observed at the time of assessment.	None		
<b>Walkthrough</b>								
					Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
409	Temp	74.3	RH% 52.7	CO2 2085	Occupants: 2		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None		
	Classroom lavatories/water fountains free of leaks?			No leaks or signs of water intrusion identified.	None		
<b>GENERAL CLEANLINESS</b>							
	Room is free of pests?			No pests observed at the time of assessment.	None		
410	Temp	74.4	RH% 49.4	CO2 2112	Occupants: 29		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>GENERAL CLEANLINESS</b>							
	Floor is cleaned on a regular basis?		My classroom floors are not mopped throughout the school year. The custodial staff is underpaid, understaffed and overworked.	Floor was clean at the time of assessment.	None		



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
420	Temp	74.7	RH% 47.8	CO2 1682	Occupants: 22		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	There are occasional ceiling leaks as we have had a continual A/C problem as long as I have worked here.		Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
501	Temp	73.9	RH% 61.0	CO2 1085	Occupants: 19		
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	<b>Walkthrough</b>						
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	2
502	Temp	74.5	RH% 63.8	CO2 1130	Occupants: 19		
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	We do not have sufficient custodial staff to do the work that needs to be completed on a daily basis. I believe they do the best they can, but we simply do not have enough employees in that area. Air filters are a concern.		Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	We do not have sufficient custodial staff to do the work that needs to be completed on a daily basis. I believe they do the best they can, but we simply do not have enough employees in that area. Air filters are a concern.		There does not appear to be a dusting issue within this room.	None		
503	Temp	73.4	RH% 56.1	CO2 1683	Occupants: 24		
	<b>AIR CONDITIONING</b>						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
503	Temp	73.4	RH% 56.1	CO2 1683	Occupants: 24		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	Classroom lavatories/water fountains free of leaks?			No leaks or signs of water intrusion identified.	None		
	Cold water pipes free of continuous condensation?			No condensation on pipes at the time of assessment.	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None		
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?		too many rooms and not enough custodians!!!!	There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?		too many rooms and not enough custodians!!!!	No pests observed at the time of assessment.	None		
506	Temp	74.7	RH% 56.0	CO2 1028	Occupants:		
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
507	Temp	73.5	RH% 62.0	CO2 1308	Occupants: 8		
	<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
507	Temp	73.5	RH% 62.0	CO2 1308	Occupants: 8		
<b>DRAIN TRAPS IN THE CLASSROOM</b>							
Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.		None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.		Physical Plant Operations to evaluate for roof leaks and repair as appropriate.		Physical Plant Operations 1
Walkthrough							
			Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.		Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.		Physical Plant Operations 2
508	Temp	71.8	RH% 56.6	CO2 1188	Occupants: 5		
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.		None		
511	Temp	77.4	RH% 58.4	CO2 998	Occupants: 5		
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?			Our custodians are overworked and underpaid.		There does not appear to be a dusting issue within this room.		
Floor is cleaned on a regular basis?			Our custodians are overworked and underpaid.		Floor was clean at the time of assessment.		
512	Temp	75.8	RH% 59.9	CO2 812	Occupants: 5		
<b>ANIMALS IN THE CLASSROOM</b>							
Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		Site Based 3
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.		Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
512	Temp	75.8	RH% 59.9	CO2 812	Occupants: 5		
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	
513	Temp	75.1	RH% 63.3	CO2 980	Occupants: 2		
	<b>DRAIN TRAPS IN THE CLASSROOM</b>						
	Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None	
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	
607	Temp	76.0	RH% 53.3	CO2 1315	Occupants: 62		
	<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
609	Temp	77.8	RH% 47.3	CO2 930	Occupants:	5	
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.		None		
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?			I THINK THE FLOOR SHOULD BE STRIPPED AND REWAXED MORE OFTEN.ALSO, THE ROOM IS NOT DUSTED ON A REGULAR BASIS. I OFTEN HAVE TO WIPE DOWN MY SINK AREA WHERE THE CHILDREN DRINK AND WASH THEIR HANDS. IT IS NOT CLEANED NIGHTLY.		There does not appear to be a dusting issue within this room.		None
782C	Temp	77.5	RH% 35.4	CO2 1360	Occupants:	2	
<b>GENERAL CLEANLINESS</b>							
Room is free of pests?			f) We have tiny ants in the room.  i)The floor needs to be mopped more, instead of just running a damp mop over the it.		Pests observed at the time of assessment.		Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.  Physical Plant Operations
<b>THERMAL COMFORT</b>							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			Gaps in windows or doors identified at the time of assessment.		Physical Plant Operations to evaluate and repair as appropriate.		Physical Plant Operations
<b>Walkthrough</b>							
			Dust observed on supply/return registers at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.		Site Based
			Stained ceiling tiles.		Facilities serviceperson to replace stained ceiling tiles.		Site Based
801A	Temp	79.3	RH% 44.5	CO2 412	Occupants:		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			THIS IS THE P.E. OFFICE AND OUTDOOR RESTROOMS.		Floor was clean at the time of assessment.		None
Floor is cleaned on a regular basis?			THIS IS THE P.E. OFFICE AND OUTDOOR RESTROOMS.		Floor was clean at the time of assessment.		None