

Tools for Schools - Indoor Air Quality

Follow-up Action Plan for Site



Quiet Waters Elementary

88.4 45% 485

Principal: Ms. Lori McConaughy

Walkthrough Date: 6/3/2004

Temp RH Co2
Outside Measurements

Assignment Member: Aston Henry

Room	Priority	Responsible	Assessment Comments	Recommended Corrective Action
123A	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
131	3	Site	General cleanliness appeared adequate on date of assessment. Problem identified with wax on the tile floor.	Custodial staff to check tile floor.
201	2	Site	Teacher reported the room is generally too cold.	Location should monitor situation and consider slightly raising thermostat within this area.
512	3	Site		Site based administration will provide information to site based staff.
512	3	Site		Site based administration will provide information to site based staff.
512	3	Site		Site based administration will provide information to site based staff.
512	3	Site		Site based administration will provide information to site based staff.
512	3	Site		Site based administration will provide information to site based staff.
512	3	Site		Site based administration will provide information to site based staff.
512	3	Site		Site based administration will provide information to site based staff.