

Report: Site

RIVERGLADES ELEMENTARY

Walkthrough Date: 03/30/2007 Temp RH CO2

Outdoor Parameters: 74.5 66.3 451

Room	Priority	Responsible	Answer	Recommendation
101J	Inside Parameters:	Temp 69.3	RH 53.1	CO2 835
2		Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
3		Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3		Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2		Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
101T	Inside Parameters:	Temp 67.1	RH 58	CO2 859
2		Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2		Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
108	Inside Parameters:	Temp 67.8	RH 59	CO2 584

Slight dust accumulation was observed

2 Site on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
211	Inside Parameters:	Temp 64.6	RH 72	CO2 1174

1 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
213	Inside Parameters:	Temp 66	RH 63.7	CO2 124

2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
215	Inside Parameters:	Temp 67.7	RH 59.8	CO2 1293

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site based administration to encourage facility serviceperson staff to adjust the

2 Site Temperature was low at the time of assessment. thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
218	Inside Parameters:	Temp	RH	CO2
		70.5	61.4	1000

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
220	Inside Parameters:	Temp	RH	CO2
		69.6	65.2	1216

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
221	Inside Parameters:	Temp	RH	CO2
		73.7	60.6	1252

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
	Inside			

226	Parameters:	Temp 70	RH 45	CO2 478
-----	-------------	------------	----------	------------

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
229	Inside Parameters:	Temp 73.1	RH 61.6	CO2 1302

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
232	Inside Parameters:	Temp 71.5	RH 64.9	CO2 1402

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
270	Inside Parameters:	Temp 72.5	RH 47.8	CO2 2002

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
308	Inside	Temp	RH	CO2

	Parameters:	70.2	57.4	1003
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
316	Inside Parameters:	Temp	RH	CO2
		70.0	56.2	1324
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
321	Inside Parameters:	Temp	RH	CO2
		73.1	47.9	1893
2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.		Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2	Site	Dust observed on supply and return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
332	Inside	Temp	RH	CO2

	Parameters:	68.3	58.4	931
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
333	Inside Parameters:	Temp	RH	CO2
		68	58.6	1114

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--	--	---

Room	Priority	Responsible	Answer	Recommendation
337	Inside Parameters:	Temp	RH	CO2
		69.2	54.3	990

2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
---	------	--	--	--

2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
---	------	--	--	--

Room	Priority	Responsible	Answer	Recommendation
401	Inside Parameters:	Temp	RH	CO2
		68.9	60.9	95

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	Temperature was low at the time of the assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
401B	Inside Parameters:	Temp	RH	CO2
		68.6	61.5	969

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--	---

Room	Priority	Responsible	Answer	Recommendation
401E	Inside Parameters:	Temp	RH	CO2
		70	61.6	1042

2	Site	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
---	------	---	--