

Riverland Elementary

IAQ Walkthrough 5/20/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
<i>115</i>	Temp <input type="text" value="75.1"/> RH% <input type="text" value="58.8"/> CO2 <input type="text" value="814"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None		
	THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Classroom is free of significant temperature shifts?	Humidity was acceptable at the time of assessment. Environmental parameters were within acceptable range at the time of assessment..	None None		
	Walkthrough	Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<i>118</i>	Temp <input type="text" value="75.1"/> RH% <input type="text" value="59.8"/> CO2 <input type="text" value="802"/>	Occupants: <input type="text"/>			
	GENERAL CLEANLINESS Room is free of pests?	No pests observed at the time of assessment.	None		
	Walkthrough	Dust and dirt accumulation on floor.	Facilities serviceperson should clean and sanitize carpet.	Site Based	2
		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
		Live plant in room.	Live plant needs to be removed from room.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
122	Temp	73.9	RH% 55.6	CO2 1217	Occupants: 24		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Walkthrough							
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
123	Temp	75.1	RH% 59.6	CO2 1956	Occupants: 25		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?		Floors are swept on a daily basis. They should be mopped at least twice a week.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?		Bathrooms should be deodorized	Exhaust fan is functioning properly. Dust and debris on exhaust vent.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Walkthrough							
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
123	Temp	<input type="text" value="75.1"/>	RH% <input type="text" value="59.6"/>	CO2 <input type="text" value="1956"/>	Occupants: <input type="text" value="25"/>		
				Environmental parameters were not within acceptable range at the time of assessment.. CO2 level slightly elevated.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
123C	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough				Cold air leak in mechanical room.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
124	Temp	<input type="text" value="74"/>	RH% <input type="text" value="56.2"/>	CO2 <input type="text" value="885"/>	Occupants: <input type="text" value="27"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Dust and dirt accumulation on floor.	Facilities serviceperson should clean and sanitize carpet.	Site Based	2
Walkthrough				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
127	Temp	<input type="text" value="77.4"/>	RH% <input type="text" value="64.3"/>	CO2 <input type="text" value="786"/>	Occupants: <input type="text" value="6"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			allergic reactions to the moisture and mold in the room. there is an odor in the room, poor ventilation and many children getting sick.	No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?			bugs are present, fruit flies, palmetto bugs		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
127	Temp	77.4	RH% 64.3	CO2 786	Occupants: 6		
	Area around and under classroom sinks free of leaks?			Signs of water intrusion from leaking faucet.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified.	None		
	Classroom lavatories/water fountains free of leaks?			See other item to repair faucet.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		room is dusty, floor and rug are not cleaned often enough.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?		room is dusty, floor and rug are not cleaned often enough.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		room is dusty, floor and rug are not cleaned often enough.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?		room is dusty, floor and rug are not cleaned often enough.	No pests observed at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			No issues identified at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was acceptable at the time of assessment.	None		
130	Temp	73.8	RH% 50.9	CO2 1142	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	ART SUPPLIES						
	Art supplies okay?			No issues identified at the time of assessment.	None		
	EXCESS MOISTURE IN CLASSROOMS						
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment. However, occupant has advised that windows are a continuing problem and have been repaired twice.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
130	Temp	73.8	RH% 50.9	CO2 1142	Occupants:		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)		Sometimes it takes awhile for the fumes from different activities to disipate.	No issues identified at the time of assessment.	None		
THERMAL COMFORT							
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		At times my room is very warm and humid.	Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		At times my room is very warm and humid.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		At times my room is very warm and humid.	Temperature was acceptable at the time of assessment.	None		
134	Temp	72.7	RH% 64.7	CO2 616	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?		There is rust around the boards of this room, and mold. This room is often humid and warm	No issues identified at the time of assessment.	None		
	Room is free of pests?		There is rust around the boards of this room, and mold. This room is often humid and warm	No pests observed at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?		There is rust around the boards of this room, and mold. This room is often humid and warm	General cleanliness of the room at the time of assessment was acceptable.	None		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		There is rust around the boards of this room, and mold. This room is often humid and warm	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
134	Temp	72.7	RH% 64.7	CO2 616	Occupants:		
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)	It is usually warm ,but has improved		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	It is usually warm ,but has improved		Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	It is usually warm ,but has improved		Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
				Dust and debris on HVAC filters.	Facilities serviceperson to replace HVAC filters.	Site Based	2
				Condensation on walls at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
135	Temp	73.9	RH% 71.5	CO2 584	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?	There is mold and mildew. Many people have allergies to mold and mildew, including myself. I have gotten sick due to this problem.			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Room is free of the use of scented cleaners and air fresheners?	Needs to be mopped more frequently.		No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Needs to be mopped more frequently.		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
135	Temp	73.9	RH%	71.5	CO2	584	Occupants:	
	Classroom is dusted/vacuumed thoroughly and regularly?		Needs to be mopped more frequently.	General cleanliness of the room at the time of assessment was acceptable.		None		
	LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?		There is only one in the room. The bathroom only has air conditioning. It does not have any exhaust fans.	No issues identified at the time of assessment.		None		
	THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)		My room is always too cold: 64 degrees. I have to dress for very cold weather every day. Children say that this room is like an ice box.	Temperature was acceptable at the time of assessment.		None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		My room is always too cold: 64 degrees. I have to dress for very cold weather every day. Children say that this room is like an ice box.	Humidity was slightly elevated at the time of assessment.		Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?		My room is always too cold: 64 degrees. I have to dress for very cold weather every day. Children say that this room is like an ice box.	Temperature was acceptable at the time of assessment.		None		
137	Temp	72.3	RH%	64.8	CO2	976	Occupants:	
	AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.		None		
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		My room has rust on the ceiling and if staples are left in the wall they begin to rust as well. I have bad allergies and have been to the doctor 3 times this year with an upper respiratory infection.	Ceiling tiles have signs of rust.		Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	Classroom lavatories/water fountains free of leaks?		My room has rust on the ceiling and if staples are left in the wall they begin to rust as well. I have bad allergies and have been to the doctor 3 times this year with an upper respiratory infection.	No issues identified at the time of assessment.		None		
	Indoor surfaces of exterior walls free of continuous condensation?		My room has rust on the ceiling and if staples are left in the wall they begin to rust as well. I have bad allergies and have been to the doctor 3 times this year with an upper respiratory infection.	Visible condensation at time of assessment.		Physical Plant Operations to evaluate tackable walls surfaces and repair as appropriate.	Physical Plant Operations	2
	GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
137	Temp	72.3	RH%	64.8	CO2	976	Occupants:	
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None			
	Room is free of pests?			No pests observed at the time of assessment.	None			
	LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None			
	THERMAL COMFORT							
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations		2
138	Temp	73.8	RH%	58.1	CO2	925	Occupants:	
	AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None			
	ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
	GENERAL CLEANLINESS							
	Room is free of pests?			No pests observed at the time of assessment.	None			
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			No issues identified at the time of assessment.	None			
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None			
	Walkthrough							
				Ceiling tiles have signs of rust. Tackable wall surfaces show signs of moisture intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations		1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
139	Temp	69.9	RH% 60.5	CO2 57.	Occupants:		
AIR CONDITIONING							
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None	
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None	
ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?		small ants present on large counter in middle of the room		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?		small ants present on large counter in middle of the room		No pests observed at the time of assessment.	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?		do not know if there are any exhaust fans in the room		No issues identified at the time of assessment.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		The room is either freezing cold - temps below 70 degrees, or very humid and temps around 80 degrees		No issues identified at the time of assessment.		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The room is either freezing cold - temps below 70 degrees, or very humid and temps around 80 degrees		Humidity was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		The room is either freezing cold - temps below 70 degrees, or very humid and temps around 80 degrees		See other recommendation to adjust thermostat.	None	

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
139	Temp <input type="text" value="69.9"/> RH% <input type="text" value="60.5"/> CO2 <input type="text" value="57."/> Room is usually comfortable? (If no, please explain in the notes below.)	Occupants: <input type="text"/> Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Walkthrough		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
		Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
		Dust and debris on range hood filter.	Facilities serviceperson should replace filter in range hood.	Site Based	2
		Tackable wall surfaces show signs of moisture intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
		Dust and dirt accumulation on floor.	Clean and sanitize carpet.	Site Based	2
140	Temp <input type="text" value="74.6"/> RH% <input type="text" value="66.5"/> CO2 <input type="text" value="637"/> AIR CONDITIONING Room is free of smell of mold or mildew?	Occupants: <input type="text"/> No odor detected at the time of assessment.	None		
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly?	General cleanliness of the room at the time of assessment was acceptable.	None		
	Room is free of pests?	No pests observed at the time of assessment.	None		
Walkthrough		HVAC unit was not on at the time of assessment.	Facilities serviceperson should ensure that HVAC system is on.	Site Based	1
		Tackable wall surfaces show signs of moisture intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
201	Temp	75.7	RH% 56.3	CO2 543	Occupants:			
AIR CONDITIONING								
Room is free of smell of mold or mildew?					No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS								
Room is free of pests?					No pests observed at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?					General cleanliness of the room at the time of assessment was acceptable.	None		
Trash is removed daily and trash bags are changed as appropriate?					No issues identified regarding trash removal practices.	None		
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No issues identified at the time of assessment.	None		
Walkthrough								
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
202	Temp	72.3	RH% 66.3	CO2 1143	Occupants:	25		
AIR CONDITIONING								
Room is free of smell of mold or mildew?					No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM								
You are informed about the potential allergies of your students?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM								
Water run in sinks at least once per week (about 2 cups of water).					No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					No issues identified at the time of assessment.	None		
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
202	Temp	72.3	RH% 66.3	CO2 1143	Occupants: 25		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No issues identified at the time of assessment.	None		
	Walkthrough			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
204	Temp	74.7	RH% 66.6	CO2 1098	Occupants: 24		
	GENERAL CLEANLINESS						
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Walkthrough			Humidity level was slightly elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
205	Temp	74.7	RH% 63.5	CO2 1278	Occupants: 18		
	DRAIN TRAPS IN THE CLASSROOM						
	Water poured down floor drains once per week (approx. 1 quart of water).			Toilets are used, sinks are sed, not sure of floor drains and water.	No issues identified at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			There was a request for window blinds to be fixed, this was not fulfilled in a timely manner. Whoever fixed it did a poor job and the entire blinds rail with blinds fell onto my computer center. Also, my room reeks!	No issues identified at the time of assessment.	None	
	Floor is cleaned on a regular basis?			There was a request for window blinds to be fixed, this was not fulfilled in a timely manner. Whoever fixed it did a poor job and the entire blinds rail with blinds fell onto my computer center. Also, my room reeks!	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

205

Temp RH% CO2

Occupants:

Classroom is dusted/vacuumed thoroughly and regularly?

There was a request for window blinds to be fixed, this was not fulfilled in a timely manner. Whoever fixed it did a poor job and the entire blinds rail with blinds fell onto my computer center. Also, my room reeks!

No issues identified at the time of assessment.

None

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

There was a request for window blinds to be fixed, this was not fulfilled in a timely manner. Whoever fixed it did a poor job and the entire blinds rail with blinds fell onto my computer center. Also, my room reeks!

No issues identified at the time of assessment.

None

Room is free of pests?

There was a request for window blinds to be fixed, this was not fulfilled in a timely manner. Whoever fixed it did a poor job and the entire blinds rail with blinds fell onto my computer center. Also, my room reeks!

No pests observed at the time of assessment.

None

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

My room is generally smelly, wether from the children or other things, is there anything that can be done. It REEKS!

Environmental parameters were within acceptable range at the time of assessment..

None

Walkthrough

Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.

Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.

Site Based

1

Dust and dirt accumulation on area rugs.

Facilities serviceperson should clean and sanitize area rugs.

Site Based

2

Humidity level was slightly elevated.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

206

Temp RH% CO2

Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
206	Temp	75.7	RH% 64.3	CO2 1308	Occupants: <input type="text"/>		
				Humidity level was slightly elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
207	Temp	75.1	RH% 66.4	CO2 1165	Occupants: <input type="text" value="28"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
Walkthrough							
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Humidity level was slightly elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
208	Temp	73	RH% 68.3	CO2 953	Occupants: <input type="text" value="12"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
Area around and under classroom sinks free of leaks?				no leaks identified.	None		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			Too Cold or too hot	Temperature was acceptable at the time of assessment.	None		
Classroom is free of significant temperature shifts?			Too Cold or too hot	No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
208	Temp	73	RH%	68.3	CO2	953	Occupants:	12			
	Temperature in my classroom is generally comfortable (72F-76F)?		Too Cold or too hot		Temperature was acceptable at the time of assessment.	None					
	Walkthrough				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
					Tackable wall surfaces show signs of moisture intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations				2
209	Temp	74.7	RH%	67.2	CO2	975	Occupants:	20			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?		THE SMELL OF MOLD/MILDEW IS PRESENT MOST OF THE TIME DURING THE WARMER DAYS - WHICH IS MOST OF THE YEAR.		Odor detected at time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations				2
			WE ARE CURRENTLY HAVING VERY COOL WEATHER, SO THIS IS NOT EVIDENT AT THIS TIME.								
	GENERAL CLEANLINESS										
	Floor is cleaned on a regular basis?		F)ANTS & FRUIT FLIES		Floor was clean at the time of assessment.	None					
			I)THE FLOOR IS SWEEPED FAIRLY FREQUENTLY, HOWEVER IT IS NOT FREQUENTLY DAMP-MOPPED/WASHED. INCREASING THE NUMBER OF TIMES IT IS DAMP-MOPPED/WASHED EACH MONTH WOULD BE GREATLY APPRECIATED.								
	Classroom is dusted/vacuumed thoroughly and regularly?		F)ANTS & FRUIT FLIES		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based				2
			I)THE FLOOR IS SWEEPED FAIRLY FREQUENTLY, HOWEVER IT IS NOT FREQUENTLY DAMP-MOPPED/WASHED. INCREASING THE NUMBER OF TIMES IT IS DAMP-MOPPED/WASHED EACH MONTH WOULD BE GREATLY APPRECIATED.								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority					
209	Temp	74.7	RH%	67.2	CO2	975	Occupants:	20				
Room is free of pests?	F)ANTS & FRUIT FLIES			No pests observed at the time of assessment.	None							
	I)THE FLOOR IS SWEEPED FAIRLY FREQUENTLY, HOWEVER IT IS NOT FREQUENTLY DAMP-MOPPED/WASHED. INCREASING THE NUMBER OF TIMES IT IS DAMP-MOPPED/WASHED EACH MONTH WOULD BE GREATLY APPRECIATED.											
THERMAL COMFORT												
Room is usually comfortable? (If no, please explain in the notes below.)	THE ROOM IS CURRENTLY COMFORTABLE AS THERE HAS RECENTLY BEEN SOME ADJUSTMENT AND WE ARE CURRENTLY HAVING COOLER WEATHER.			Temperature was acceptable at the time of assessment.	None							
	WHEN IT IS HOT OUTSIDE, THE ROOM IS NOT ALWAYS COMFORTABLE - TEMPERATURE-WISE AND HUMIDITY-WISE.											
Classroom is free of significant temperature shifts?	THE ROOM IS CURRENTLY COMFORTABLE AS THERE HAS RECENTLY BEEN SOME ADJUSTMENT AND WE ARE CURRENTLY HAVING COOLER WEATHER.			No issues identified at the time of assessment.	None							
	WHEN IT IS HOT OUTSIDE, THE ROOM IS NOT ALWAYS COMFORTABLE - TEMPERATURE-WISE AND HUMIDITY-WISE.											
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	THE ROOM IS CURRENTLY COMFORTABLE AS THERE HAS RECENTLY BEEN SOME ADJUSTMENT AND WE ARE CURRENTLY HAVING COOLER WEATHER.			Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2					
	WHEN IT IS HOT OUTSIDE, THE ROOM IS NOT ALWAYS COMFORTABLE - TEMPERATURE-WISE AND HUMIDITY-WISE.											

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
209	Temp	74.7	RH%	67.2	CO2	975	Occupants:	20			
	Temperature in my classroom is generally comfortable (72F-76F)?	THE ROOM IS CURRENTLY COMFORTABLE AS THERE HAS RECENTLY BEEN SOME ADJUSTMENT AND WE ARE CURRENTLY HAVING COOLER WEATHER. WHEN IT IS HOT OUTSIDE, THE ROOM IS NOT ALWAYS COMFORTABLE - TEMPERATURE-WISE AND HUMIDITY-WISE.			Temperature was acceptable at the time of assessment.	None					
	Walkthrough				Tackable wall surfaces show signs of moisture intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations				1
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based				1
					Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based				2
212	Temp	73.4	RH%	67.3	CO2	1058	Occupants:				
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?	at times smells musty			No odor detected at the time of assessment.	None					
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff. Wipe down cabinet inside and out in kitchen area and dust environmental surfaces.	Site Based				2
	Room is free of pests?				No pests observed at the time of assessment.	None					
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	THERMAL COMFORT										
	Temperature in my classroom is generally comfortable (72F-76F)?	cool at times			Temperature was acceptable at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
212	Temp	73.4	RH% 67.3	CO2 1058	Occupants: <input type="text"/>		
	Room is usually comfortable? (If no, please explain in the notes below.)		cool at times	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
220	Temp	75.7	RH% 63.7	CO2 1388	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?		stuffy room, germs and children with constant colds.	No odor detected at the time of assessment.	None		
	DRAIN TRAPS IN THE CLASSROOM						
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?		bags need to be changed in trash cans.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		bags need to be changed in trash cans.	No issues identified at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?		bags need to be changed in trash cans.	There appears to be an issue regarding daily trash removal practices.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is stuffy, no windows, a/c temperature, varies daily,	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is stuffy, no windows, a/c temperature, varies daily,	Temperature was acceptable at the time of assessment.	None		
	Classroom is free of significant temperature shifts?		Room is stuffy, no windows, a/c temperature, varies daily,	No issues identified at the time of assessment.	None		
	Walkthrough						
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment. Deodorizer in room 220A (restroom).	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
220	Temp	<input type="text" value="75.7"/>	RH% <input type="text" value="63.7"/>	CO2 <input type="text" value="1388"/>	Occupants: <input type="text"/>			
				Live plants outside of doorway.	Facilities serviceperson should remove live plants from building.	Site Based	1	
222	Temp	<input type="text" value="74.5"/>	RH% <input type="text" value="64"/>	CO2 <input type="text" value="566"/>	Occupants: <input type="text"/>			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	EXCESS MOISTURE IN CLASSROOMS							
	Indoor surfaces of exterior walls free of continuous condensation?			Tackable wall surfaces show signs of moisture intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1	
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None			
	Walkthrough							
				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2	
223	Temp	<input type="text" value="77.3"/>	RH% <input type="text" value="67.4"/>	CO2 <input type="text" value="1407"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING							
	Room is free of smell of mold or mildew?			Room frequently smells like wires burning. Kids are constantly sick with cold like symptoms and coughing.	Odor detected. Tackable wall surfaces show signs of moisture intrusion.	Physical Plant Operations to evaluate cause of odor. Repair/replace tackable wall surfaces as appropriate.	Physical Plant Operations	1
	Room is free of smell of chemicals?			Room frequently smells like wires burning. Kids are constantly sick with cold like symptoms and coughing.	No odor of chemicals detected at the time of the assessment.	None		
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Ceiling tiles are stained.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1	
	Classroom lavatories/water fountains free of leaks?			No leaks identified.	None			
	Windows, windowsills and window frames free of continuous condensation?			No condensation identified at the time of assessment.	None			
	GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
223	Temp	77.3	RH% 67.4	CO2 1407	Occupants:		
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Walkthrough				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
224	Temp	77.7	RH% 65.6	CO2 1716	Occupants:	31	
	ANIMALS IN THE CLASSROOM						
	Classroom is free of animals and pets?				No animals identified at the time of assessment.	None	
	DRAIN TRAPS IN THE CLASSROOM						
	Water run in sinks at least once per week (about 2 cups of water).				No issues identified at the time of assessment.	None	
	Water poured down floor drains once per week (approx. 1 quart of water).				No issues identified at the time of assessment.	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No issues identified at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Classrooms general appearance is clean and acceptable?				Sink handle has been broken since August 2004. Students are unable to wash their hands after using restroom, or get water for class activities ie feeding plant, pet, for the most part. Bathroom sink water runs very slowly.	Humidity was acceptable at the time of assessment.	None
	Classroom is dusted/vacuumed thoroughly and regularly?				Sink handle has been broken since August 2004. Students are unable to wash their hands after using restroom, or get water for class activities ie feeding plant, pet, for the most part. Bathroom sink water runs very slowly.	General cleanliness of the room at the time of assessment was acceptable.	None
	THERMAL COMFORT						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
224	Temp	<input type="text" value="77.7"/>	RH% <input type="text" value="65.6"/>	CO2 <input type="text" value="1716"/>	Occupants: <input type="text" value="31"/>		
	Room is usually comfortable? (If no, please explain in the notes below.)				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Walkthrough				Tackable wall surfaces show signs of moisture intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
300	Temp	<input type="text" value="71.8"/>	RH% <input type="text" value="61.2"/>	CO2 <input type="text" value="615"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	DRAIN TRAPS IN THE CLASSROOM						
	Water poured down floor drains once per week (approx. 1 quart of water).				No issues identified at the time of assessment.	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Ceiling tiles are stained.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	Indoor surfaces of exterior walls free of continuous condensation?				No issues identified at the time of assessment.	None	
	Cold water pipes free of continuous condensation?				No condensation on pipes at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

300

Temp RH% CO2

Occupants:

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

None

Room is free of pests?

No pests observed at the time of assessment.

None

Floor is cleaned on a regular basis?

Carpet was stained and dirty.

Facilities serviceperson should clean with extraction machine.

Site Based

2

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-76F)?

Too much dust, moisture and variations in temperature, one day hot the other day too cold.

Temperature was acceptable at the time of assessment.

None

Classroom is free of significant temperature shifts?

Too much dust, moisture and variations in temperature, one day hot the other day too cold.

No issues identified at the time of assessment.

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Too much dust, moisture and variations in temperature, one day hot the other day too cold.

Humidity was acceptable at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

Too much dust, moisture and variations in temperature, one day hot the other day too cold.

No issues identified at the time of assessment.

None

Walkthrough

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

312

Temp RH% CO2

Occupants:

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
312	Temp	73.6	RH% 58.1	CO2 504	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Windows, windowsills and window frames free of continuous condensation?			No issues identified at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Food, if any, is stored in tightly sealed containers?			No issues identified at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
500	Temp	75.6	RH% 63.9	CO2 1337	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS						
	Indoor surfaces of exterior walls free of continuous condensation?			No issues identified at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
500	Temp	75.6	RH%	63.9	CO2	1337	Occupants:	<input type="text"/>			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
	LOCAL EXHAUST FANS										
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			No issues identified at the time of assessment.	None						
	Walkthrough										
				Carpet was stained and dirty.	Facilities serviceperson should clean carpet with extraction machine.	Site Based					2
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based					2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based					2
502	Temp	79.6	RH%	66.4	CO2	934	Occupants:	<input type="text"/>			
	AIR CONDITIONING										
	Room is free of smell of chemicals?			No odor detected at the time of assessment.	None						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None						
	Room is free of smell of vehicle exhaust?			No odor detected at the time of assessment.	None						
	ANIMALS IN THE CLASSROOM										
	Classroom is free of animals and pets?			No animals identified at the time of assessment.	None						
	EXCESS MOISTURE IN CLASSROOMS										
	Cold water pipes free of continuous condensation?			No condensation on pipes at the time of assessment.	None						
	GENERAL CLEANLINESS										
	Room is free of the use of scented cleaners and air fresheners?			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None						
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No issues identified at the time of assessment.	None						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
502	Temp	<input type="text" value="79.6"/>	RH% <input type="text" value="66.4"/>	CO2 <input type="text" value="934"/>	Occupants: <input type="text"/>		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Walkthrough			Humidity and temperature were slightly elevated at the time of assessment. Windows and/or doors were open at the time of assessment. Open doors and windows allow humid untreated air into occupied environment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat and advise occupant to keep door closed. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	1
510	Temp	<input type="text" value="76.4"/>	RH% <input type="text" value="63.6"/>	CO2 <input type="text" value="1108"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Walkthrough			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
510	Temp	76.4	RH% 63.6	CO2 1108	Occupants: <input type="text"/>			
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2	
511	Temp	74.3	RH% 65.7	CO2 1150	Occupants: <input type="text"/>			
GENERAL CLEANLINESS								
				Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
				Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	None		
				Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.	None		
934P	Temp	73.6	RH% 37.7	CO2 1234	Occupants: <input type="text" value="8"/>			
GENERAL CLEANLINESS								
				Classroom is dusted/vacuumed thoroughly and regularly?	Classroom is vacuumed daily but not dusted on a regular basis.	General cleanliness of the room at the time of assessment was acceptable.	None	
LOCAL EXHAUST FANS								
				Bathroom exhaust fan is functioning properly?	Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Walkthrough								
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2