

Jeffrey S. Moquin, Director  
Risk Management Department

Telephone: 754-321-3200  
Facsimile: 754-321-3290

October 25, 2006

*Signature on File*

TO: Ms. Robin David, Principal  
**Royal Palm Elementary School**

FROM: Aston A. Henry, Jr., Supervisor  
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment  
**FISH 602**

On September 29, 2006 Kenneth Partee conducted a follow up assessment of FISH 602 at **Royal Palm Elementary School**. The assessment consisted of a reevaluation walkthrough of the previously identified areas to assess the current condition of the location with regard to indoor air quality. This assessment included reviewing previously generated work orders as well as observations of the areas of concern as stated in the IAQ Assessment performed on August 10, 2006 by the IAQ Assessment Team. Attached are the findings of this assessment along with recommendations for further assessment, remediation, or corrective actions, if needed.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Harry LaCava, Area Superintendent  
Fran Bolden, Area Director  
Jeffrey S. Moquin, Director, Risk Management  
Israel Rodriguez-Soto, Project Manager, Facilities and Construction Management  
Robert Goode, Project Manager, Facilities and Construction Management  
Gary Itzkowitz, Broward Teachers Union  
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1  
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division  
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

AAH/tc  
Enc.

# IAQ Assessment

Location Number 1851  
 Evaluation Requested September 25, 2006  
 Evaluation Date September 29, 2006

Royal Palm Elementary School

Time of Day 12:10 pm

Outdoor Conditions      Temperature 90.3      Relative Humidity 54.1      Ambient CO2 503

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<span style="border: 1px solid black; padding: 2px;">602</span>	<span style="border: 1px solid black; padding: 2px;">69.6</span>	<span style="border: 1px solid black; padding: 2px;">72 - 78</span>	<span style="border: 1px solid black; padding: 2px;">66.2</span>	<span style="border: 1px solid black; padding: 2px;">30% - 60%</span>	<span style="border: 1px solid black; padding: 2px;">931</span>	<span style="border: 1px solid black; padding: 2px;">Max 700 &gt; Ambient</span>	<span style="border: 1px solid black; padding: 2px;">2</span>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">None</span>	
Ceiling Type	<span style="border: 1px solid black; padding: 2px;">2 x 4 Lay In</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Wall Type	<span style="border: 1px solid black; padding: 2px;">Plaster</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Flooring	<span style="border: 1px solid black; padding: 2px;">Carpet</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Walls	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Flooring	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Clean and sanitize</span>
HVAC Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
HVAC Return Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Ceiling at Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Surfaces in Room	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Clean as appropriate</span>

**Observations**

**Findings:**

- Dust build up on floor
- Dust build up on environmental surfaces
- Temperature was low and humidity level was slightly elevated
- Teacher's desk was impacted with mold and has been removed from the classroom

**Recommendations:**

**Site Based Maintenance:**

- Clean and sanitize floor
- Clean environmental surfaces throughout the room
- Adjust thermostat to increase temperature and lower humidity level. Continue to monitor condition and initiate a work order to Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate