

Aston A. Henry, Director

managing risk with responsibility

754 321-1900

Telephone:

Risk Managem	ent Department	Fax: 754 321-1917
March 19, 2015	Signature on File	For Custodial Supervisor Use Only
TO:	Amada Walker, Principal Silver Palms Elementary	Custodial Issues Addressed
FROM:	Richard Rosa, Project Manager Risk Management Department	Custodial Issues Not Addressed
SUBIECT:	Indoor Air Ouality (IAO) Assessment	

On March 17, 2015, I conducted an assessment at **Silver Palms Elementary School.** Attached are findings and recommendations for further assessment, remediation, or corrective actions needed.

The IAQ Assessment did not identify any existing conditions significantly impacting IAQ or presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to allergens and / or conditions noted during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of any item/s identified and noted in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-1900.

cc: Shelley Meloni, Executive Director, Facilities & Construction
Mark Dorsett, Manager, Zone 1, Physical Plant Operations Division
Roy Norton, Manager, Custodial/Grounds, Physical Plant Operations Division
Aston Henry, Director, Risk Management
Sonja Coley, Senior Project Manager, Facilities & Construction
Broward Teachers Union
Federation of Public Employees

RR/jj Enc.

▼

▼

Clean cobwebs from low corners

Tape and date HVAC filters