

Tools for Schools Phase II - Indoor Air Quality

Follow-up Action Plan for Physical Plant Operations



Sunset Lakes Elementary

3661

80.2 58.5 392

Principal: Dr. Linda McDaniel

Walkthrough Date: 5/13/2005

Temp RH Co2
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
131	1	Physical Plant Operations	Water damage to wallboard over window.	Physical Plant Operations to evaluate for leaks and repair as appropriate.
153	2	Physical Plant Operations	Air flowing only slightly at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.
155	2	Physical Plant Operations	Secondary exit door not sealed at bottom.	Physical Plant Operations to evaluate and repair as appropriate.
158	1	Physical Plant Operations	Water damaged wall over windows.	Physical Plant Operations to evaluate for leaks and repair as appropriate.
159	2	Physical Plant Operations	Exterior door not sealed properly.	Physical Plant Operations to evaluate and repair as appropriate.
209	2	Physical Plant Operations	Dust and debris identified on inside of HVAC duct.	Physical Plant operations to evaluate and clean HVAC ducts.
213	2	Physical Plant Operations	Dust and debris identified on inside of HVAC ducts.	Physical Plant operations to evaluate and clean HVAC ducts.
219	2	Physical Plant Operations	Dust and debris identified on inside of HVAC ducts.	Physical Plant operations to evaluate and clean HVAC ducts
228	2	Physical Plant Operations	Dust and debris identified on inside of HVAC ducts.	Physical Plant operations to evaluate and clean HVAC ducts.
231	1	Physical Plant Operations	Sink faucet is loose and water is leaking into the cabinet.	Physical Plant Operations to evaluate and repair/replace as appropriate.
231	2	Physical Plant Operations	Dust and debris identified on inside of HVAC ducts.	physical Plant operations to evaluate and clean HVAC ducts.
232	1	Physical Plant Operations	Signs of water intrusion at windows (oxidation of aluminum frames).	Physical Plant Operations to evaluate for leaks and repair as appropriate.
232	2	Physical Plant Operations	Dust and debris identified on inside of HVAC ducts.	Physical Plant operations to evaluate and clean HVAC ducts.
233	2	Physical Plant Operations	Dust and debris identified on inside of HVAC ducts.	Physical Plant operations to evaluate and clean HVAC ducts.
236	2	Physical Plant Operations	Dust and debris identified on inside of HVAC ducts.	Physical Plant operations to evaluate and clean HVAC ducts
237	2	Physical Plant Operations	Dust and debris identified on inside of HVAC ducts.	Physical Plant operations to evaluate and clean HVAC ducts.