

Tamarac Elementary

IAQ Walkthrough 5/13/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
101	Temp	<input type="text" value="75.6"/>	RH%	<input type="text" value="47.2"/>	CO2	<input type="text" value="1095"/>	Occupants:	<input type="text"/>
GENERAL CLEANLINESS								
Floor is cleaned on a regular basis?					None	None		
THERMAL COMFORT								
Temperature in my classroom is generally comfortable (72F-76F)?		too cold		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2
Room is usually comfortable? (If no, please explain in the notes below.)		too cold		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2
101C	Temp	<input type="text" value="73.3"/>	RH%	<input type="text" value="49.8"/>	CO2	<input type="text" value="1051"/>	Occupants:	<input type="text"/>
THERMAL COMFORT								
Temperature in my classroom is generally comfortable (72F-76F)?		Room is often extremely cold		Temperature was acceptable at the time of assessment.	None	None		
Room is usually comfortable? (If no, please explain in the notes below.)		Room is often extremely cold		Temperature was elevated at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2
Classroom is free of significant temperature shifts?		Room is often extremely cold		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2
101J	Temp	<input type="text" value="74.8"/>	RH%	<input type="text" value="47.8"/>	CO2	<input type="text" value="1058"/>	Occupants:	<input type="text" value="2"/>
GENERAL CLEANLINESS								
Floor is cleaned on a regular basis?					None	None		
Classroom is dusted/vacuumed thoroughly and regularly?					None	None		
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					None	None		
LOCAL EXHAUST FANS								
Other exhaust fans that may exist in the classroom are functioning properly?		N/A - Office			None	None		
Bathroom exhaust fan is functioning properly?		N/A - Office			None	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
101J	Temp	<input type="text" value="74.8"/>	RH%	<input type="text" value="47.8"/>	CO2	<input type="text" value="1058"/>	Occupants:	<input type="text" value="2"/>		
THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)	Always too cold			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based			2
	Temperature in my classroom is generally comfortable (72F-76F)?	Always too cold			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based			2
101K	Temp	<input type="text" value="74"/>	RH%	<input type="text" value="48.9"/>	CO2	<input type="text" value="1070"/>	Occupants:	<input type="text" value="2"/>		
GENERAL CLEANLINESS										
	Floor is cleaned on a regular basis?					None				None
	Classroom is dusted/vacuumed thoroughly and regularly?					None				None
LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?	N/A-Office				None				None
	Other exhaust fans that may exist in the classroom are functioning properly?	N/A-Office				None				None
112	Temp	<input type="text" value="76.4"/>	RH%	<input type="text" value="45.7"/>	CO2	<input type="text" value="1025"/>	Occupants:	<input type="text" value="2"/>		
GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?					None				None
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					None				None
113A	Temp	<input type="text" value="75.3"/>	RH%	<input type="text" value="48.3"/>	CO2	<input type="text" value="1005"/>	Occupants:	<input type="text" value="2"/>		
GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					None				None
	Classroom is dusted/vacuumed thoroughly and regularly?					None				None
	Floor is cleaned on a regular basis?					None				None
LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?					None				None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
113B	Temp	<input type="text" value="75.1"/>	RH% <input type="text" value="48.8"/>	CO2 <input type="text" value="991"/>	Occupants: <input type="text" value="3"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
THERMAL COMFORT							
Classroom is free of significant temperature shifts?					None	None	
113C	Temp	<input type="text" value="75.7"/>	RH% <input type="text" value="48.5"/>	CO2 <input type="text" value="990"/>	Occupants: <input type="text" value="3"/>		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
121	Temp	<input type="text" value="72.3"/>	RH% <input type="text" value="54.3"/>	CO2 <input type="text" value="1197"/>	Occupants: <input type="text" value="21"/>		
LOCAL EXHAUST FANS							
Other exhaust fans that may exist in the classroom are functioning properly?					None	None	
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)					None	None	
Bathroom exhaust fan is functioning properly?					None	None	
My classroom has sufficient exhaust systems based on the activities/functionality of the room?					None	None	
Walkthrough					Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
122A	Temp	<input type="text" value="70.4"/>	RH% <input type="text" value="55.8"/>	CO2 <input type="text" value="1117"/>	Occupants: <input type="text" value="2"/>		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
123	Temp	69.5	RH% 58.7	CO2 1180	Occupants: 22			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				None	None		
	LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?		Do not have an exhaust system. No bathroom in class.		None	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)		Do not have an exhaust system. No bathroom in class.		None	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		Do not have an exhaust system. No bathroom in class.		None	None		
	Other exhaust fans that may exist in the classroom are functioning properly?		Do not have an exhaust system. No bathroom in class.		None	None		
	THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Classroom is free of significant temperature shifts?				None	None		
124	Temp	68.8	RH% 59.8	CO2 1200	Occupants: 25			
	GENERAL CLEANLINESS							
	Food, if any, is stored in tightly sealed containers?				None	None		
	Walkthrough							
					Temperature was low at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
125	Temp	71	RH% 65.7	CO2 853	Occupants: 25			
	LOCAL EXHAUST FANS							
	Other exhaust fans that may exist in the classroom are functioning properly?		No bathroom or exhaust system		None	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		No bathroom or exhaust system		None	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)		No bathroom or exhaust system		None	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
125	Temp	71	RH% 65.7	CO2 853	Occupants: 25			
	Bathroom exhaust fan is functioning properly?	No bathroom or exhaust system				None	None	
	Walkthrough				Humidity level was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
126	Temp	72.1	RH% 64.0	CO2 848	Occupants: 22			
	AIR CONDITIONING							
	Room is free of smell of kitchen/food?					None	None	
	THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?	Tends to be very cold.		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2	
	Classroom is free of significant temperature shifts?	Tends to be very cold.		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2	
	Room is usually comfortable? (If no, please explain in the notes below.)	Tends to be very cold.		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2	
127	Temp	71.6	RH% 65.0	CO2 895	Occupants: 24			
	AIR CONDITIONING							
	Room is free of smell of kitchen/food?					None	None	
	LOCAL EXHAUST FANS							
	Other exhaust fans that may exist in the classroom are functioning properly?					None	None	
	Bathroom exhaust fan is functioning properly?					None	None	
	Walkthrough				Dust observed on supply register at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
					Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
128	Temp	72.5	RH% 63.8	CO2 891	Occupants: 25		
THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?	Sometimes the air conditioner is broken or turned off and it gets very stuffy and hot in here. There are times it is unusually cold also (68).			None	None	
	Classroom is free of significant temperature shifts?	Sometimes the air conditioner is broken or turned off and it gets very stuffy and hot in here. There are times it is unusually cold also (68).			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Sometimes the air conditioner is broken or turned off and it gets very stuffy and hot in here. There are times it is unusually cold also (68).			Humidity level was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	2
129	Temp	72.6	RH% 63.0	CO2 763	Occupants: 18		
ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	3
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	3
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				None	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	NO BATHROOM			None	None	
	Other exhaust fans that may exist in the classroom are functioning properly?	NO BATHROOM			None	None	
THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?	TOO COLD			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	TOO COLD			Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
129	Temp	72.6	RH% 63.0	CO2 763	Occupants: 18		
	Room is usually comfortable? (If no, please explain in the notes below.)	TOO COLD			Temperature was acceptable at the time of assessment.	None	None
130	Temp	73.3	RH% 63.1	CO2 890	Occupants: 25		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?					None	None
	Room is free of pests?					None	None
	THERMAL COMFORT						
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2
131	Temp	73.4	RH% 61.5	CO2 884	Occupants: 19		
	AIR CONDITIONING						
	Room is free of smell of kitchen/food?					None	None
	DRAIN TRAPS IN THE CLASSROOM						
	Water run in sinks at least once per week (about 2 cups of water).					None	None
	Water poured down floor drains once per week (approx. 1 quart of water).					None	None
	EXCESS MOISTURE IN CLASSROOMS						
	Indoor surfaces of exterior walls free of continuous condensation?					None	None
	GENERAL CLEANLINESS						
	Room is free of pests?					None	None
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?	no bathrm.				None	None
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)	chilly most of the time			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2
	Classroom is free of significant temperature shifts?	chilly most of the time			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
131	Temp	73.4	RH%	61.5	CO2	884	Occupants:	19			
	Temperature in my classroom is generally comfortable (72F-76F)?		chilly most of the time		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2		
Walkthrough				Teacher covered air supply vents with cardboard.	Facilities serviceperson to remove cardboard.	Site Based		1			
133	Temp	74.6	RH%	60.6	CO2	1044	Occupants:	20			
	EXCESS MOISTURE IN CLASSROOMS										
	Area around and under classroom sinks free of leaks?					None	None				
	Classroom lavatories/water fountains free of leaks?					None	None				
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					None	None				
134	THERMAL COMFORT										
	Temperature in my classroom is generally comfortable (72F-76F)?		too cold		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2		
	Room is usually comfortable? (If no, please explain in the notes below.)		too cold		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2		
134	Temp	69.5	RH%	60.7	CO2	1151	Occupants:	18			
	EXCESS MOISTURE IN CLASSROOMS										
	Classroom lavatories/water fountains free of leaks?					None	None				
	THERMAL COMFORT										
Room is usually comfortable? (If no, please explain in the notes below.)		My classroom gets very cold, especially in the afternoon. We must wear sweaters and jackets.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based		2			
Temperature in my classroom is generally comfortable (72F-76F)?		My classroom gets very cold, especially in the afternoon. We must wear sweaters and jackets.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based		2			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
134	Temp	69.5	RH% 60.7	CO2 1151	Occupants: 18		
	Classroom is free of significant temperature shifts?	My classroom gets very cold, especially in the afternoon. We must wear sweaters and jackets.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
135	Temp	69.5	RH% 60.9	CO2 1170	Occupants: 20		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?	My classroom is extremely cold.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	My classroom is extremely cold.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	My classroom is extremely cold.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
136	Temp	69.2	RH% 61.6	CO2 1149	Occupants: 21		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?	My room is very cold.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority		
136	Temp	69.2	RH% 61.6	CO2 1149	Occupants: 21				
	Room is usually comfortable? (If no, please explain in the notes below.)	My room is very cold.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2	
	Temperature in my classroom is generally comfortable (72F-76F)?	My room is very cold.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2	
138	Temp		RH%	CO2	Occupants: 21				
	GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						None	None	
	LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?						None	None	
	Other exhaust fans that may exist in the classroom are functioning properly?						None	None	
	THERMAL COMFORT								
	Classroom is free of significant temperature shifts?						None	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)						None	None	
139	Temp	70.8	RH% 57.0	CO2 1026	Occupants:				
	ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
139	Temp	70.8	RH% 57.0	CO2 1026	Occupants:		
	Room is free of pests?					None	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		too hot or cold	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Room is usually comfortable? (If no, please explain in the notes below.)		too hot or cold	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Temperature in my classroom is generally comfortable (72F-76F)?		too hot or cold	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
140	Temp	70.4	RH% 57.7	CO2 978	Occupants:		
	ART SUPPLIES						
	Following good handling and storage practices for art supplies?					None	None
	Industrial supplies okay?					None	None
	GENERAL CLEANLINESS						
	Room is free of pests?					None	None
141	Temp	70.7	RH% 57.5	CO2 1092	Occupants:	24	
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?					None	None
	EXCESS MOISTURE IN CLASSROOMS						
	Cold water pipes free of continuous condensation?					None	None
	Area around and under classroom sinks free of leaks?					None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
141	Temp	<input type="text" value="70.7"/>	RH%	<input type="text" value="57.5"/>	CO2	<input type="text" value="1092"/>	Occupants:	<input type="text" value="24"/>		
	Classroom lavatories/water fountains free of leaks?				None	None				
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				None	None				
	GENERAL CLEANLINESS									
	Room is free of pests?				None	None				
	THERMAL COMFORT									
	Classroom is free of significant temperature shifts?				Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based			2
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based			2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Temperature was low at the time of assessment.	Facilities serviceperson to open return vents.	Site Based			2
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based			2
144	Temp	<input type="text" value="70.6"/>	RH%	<input type="text" value="58.3"/>	CO2	<input type="text" value="1028"/>	Occupants:	<input type="text" value="22"/>		
	EXCESS MOISTURE IN CLASSROOMS									
	Classroom lavatories/water fountains free of leaks?				None	None				
145	Temp	<input type="text" value="70.9"/>	RH%	<input type="text" value="53.9"/>	CO2	<input type="text" value="1202"/>	Occupants:	<input type="text" value="21"/>		
	GENERAL CLEANLINESS									
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				None	None				
	Food, if any, is stored in tightly sealed containers?				None	None				
145C	Temp	<input type="text" value="70.9"/>	RH%	<input type="text" value="51.6"/>	CO2	<input type="text" value="1060"/>	Occupants:	<input type="text" value="2"/>		
	GENERAL CLEANLINESS									
	Trash is removed daily and trash bags are changed as appropriate?				None	None				
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				None	None				
	Classroom is dusted/vacuumed thoroughly and regularly?				None	None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
145C	Temp	<input type="text" value="70.9"/>	RH%	<input type="text" value="51.6"/>	CO2	<input type="text" value="1060"/>	Occupants:	<input type="text" value="2"/>		
	Classrooms general appearance is clean and acceptable?				None	None				
	Floor is cleaned on a regular basis?				None	None				
	THERMAL COMFORT									
	Classroom is free of significant temperature shifts?		Gets to be too cold.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based			2
	Room is usually comfortable? (If no, please explain in the notes below.)		Gets to be too cold.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based			2
	Temperature in my classroom is generally comfortable (72F-76F)?		Gets to be too cold.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based			2
146	Temp	<input type="text" value="71.0"/>	RH%	<input type="text" value="53.7"/>	CO2	<input type="text" value="1181"/>	Occupants:	<input type="text" value="23"/>		
	ANIMALS IN THE CLASSROOM									
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based			3
	LOCAL EXHAUST FANS									
	Bathroom exhaust fan is functioning properly?		no exhaust fans			None	None			
	Other exhaust fans that may exist in the classroom are functioning properly?		no exhaust fans			None	None			
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		no exhaust fans			None	None			
	THERMAL COMFORT									

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
146	Temp	71.0	RH%	53.7	CO2	1181	Occupants:	23			
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Sometimes way too cold!!!		Temperature was low at the time of assessment.		Facilities serviceperson should monitor this room.		Site Based		2
	Room is usually comfortable? (If no, please explain in the notes below.)		Sometimes way too cold!!!		Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.		Site Based		2
	Temperature in my classroom is generally comfortable (72F-76F)?		Sometimes way too cold!!!		Temperature was low at the time of assessment.		Facilities serviceperson should monitor this room.		Site Based		2
147	Temp	72.8	RH%	52.9	CO2	1226	Occupants:	2			
	DRAIN TRAPS IN THE CLASSROOM										
	Water poured down floor drains once per week (approx. 1 quart of water).						None		None		
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.		Facilities serviceperson to replace stained ceiling tiles.		Site Based		2
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						None		None		
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?						None		None		
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		c)I have a back door that I use on occasion-when opened outdoor air is introduced into the classroom. e) the temperature shifts often-some days it is very warm and others it is quite chilly. This fluctuation is causing frequent classroom sickness.		Temperature was acceptable at the time of assessment.		Facilities serviceperson should monitor this room.		Site Based		2
	Temperature in my classroom is generally comfortable (72F-76F)?		c)I have a back door that I use on occasion-when opened outdoor air is introduced into the classroom. e) the temperature shifts often-some days it is very warm and others it is quite chilly. This fluctuation is causing frequent classroom sickness.		Temperature was acceptable at the time of assessment.		Facilities serviceperson should monitor this room.		Physical Plant Operations		2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
147	Temp	72.8	RH% 52.9	CO2 1226	Occupants: 2			
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	c)I have a back door that I use on occasion-when opened outdoor air is introduced into the classroom. e) the temperature shifts often-some days it is very warm and others it is quite chilly. This fluctuation is causing frequent classroom sickness.				None	None	2
	Room is usually comfortable? (If no, please explain in the notes below.)	c)I have a back door that I use on occasion-when opened outdoor air is introduced into the classroom. e) the temperature shifts often-some days it is very warm and others it is quite chilly. This fluctuation is causing frequent classroom sickness.			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
149	Temp	73.6	RH% 56.0	CO2 983	Occupants: 3			
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?					None	None	
	Walkthrough							
					Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
159	Temp	72.4	RH% 60.4	CO2 776	Occupants: 2			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?	carpet needs to be cleaned				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	one area of ceiling tiles has some discoloration			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	GENERAL CLEANLINESS							
	Room is free of pests?					None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
163G	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough				Roof is very soft.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
				Damaged ceiling tiles.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
201	Temp	<input type="text" value="74.3"/>	RH% <input type="text" value="51.6"/>	CO2 <input type="text" value="835"/>	Occupants: <input type="text" value="12"/>		
GENERAL CLEANLINESS							
Room is free of pests?					None	None	
THERMAL COMFORT							
Temperature in my classroom is generally comfortable (72F-76F)?			Room is usually much too cold. I sometimes wear two sweaters.	Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)			Room is usually much too cold. I sometimes wear two sweaters.	Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
Walkthrough				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	2
202	Temp	<input type="text" value="73.1"/>	RH% <input type="text" value="54.3"/>	CO2 <input type="text" value="856"/>	Occupants: <input type="text" value="11"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			The entire building smells of mold and mildew. My first month in this building I had a headache everyday!		None	None	
GENERAL CLEANLINESS							
Room is free of the use of scented cleaners and air fresheners?			The use of air fresheners must be used because the smell of mildew is absolutely intolerable. I also have from home an ionic breeze air purifier because most of my students have horrible allergies to mold and mildew.		None	None	
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?			We do not have a exhaust fan in our bathroom.		None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
205	Temp	72.1	RH% 56.1	CO2 781	Occupants:	3	
AIR CONDITIONING							
Room is free of smell of mold or mildew?		g) see comments on previous page			None	None	
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					None	None	
Indoor surfaces of exterior walls free of continuous condensation?					None	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					None	None	
Room is free of pests?					None	None	
THERMAL COMFORT							
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		too cold a constant humid, musty smell all around, causing breathing difficulties if in room for long periods of time			None	None	
Room is usually comfortable? (If no, please explain in the notes below.)		too cold a constant humid, musty smell all around, causing breathing difficulties if in room for long periods of time			None	None	
Temperature in my classroom is generally comfortable (72F-76F)?		too cold a constant humid, musty smell all around, causing breathing difficulties if in room for long periods of time			None	None	
Classroom is free of significant temperature shifts?		too cold a constant humid, musty smell all around, causing breathing difficulties if in room for long periods of time			None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority		
206	Temp	72.0	RH% 56.0	CO2 752	Occupants: 3				
AIR CONDITIONING									
Room is free of smell of mold or mildew?						None	None		
EXCESS MOISTURE IN CLASSROOMS									
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?						No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
GENERAL CLEANLINESS									
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						None	None		
207	Temp	73.5	RH% 53.5	CO2 794	Occupants: 5				
AIR CONDITIONING									
Room is free of smell of mold or mildew?						None	None		
GENERAL CLEANLINESS									
Classroom is dusted/vacuumed thoroughly and regularly?						None	None		
LOCAL EXHAUST FANS									
Other exhaust fans that may exist in the classroom are functioning properly?						None	None		
Bathroom exhaust fan is functioning properly?						None	None		
THERMAL COMFORT									
Classroom is free of significant temperature shifts?			Some days toohot other days too cold. No air frequently			None	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Some days toohot other days too cold. No air frequently			None	None		
Room is usually comfortable? (If no, please explain in the notes below.)			Some days toohot other days too cold. No air frequently			Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			Some days toohot other days too cold. No air frequently			Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
208	Temp	<input type="text" value="74.0"/>	RH% <input type="text" value="53.5"/>	CO2 <input type="text" value="825"/>	Occupants: <input type="text" value="14"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			When you walk into our building, you can smell an awful musty, mildew odor.		None	None	
EXCESS MOISTURE IN CLASSROOMS							
Indoor surfaces of exterior walls free of continuous condensation?					None	None	
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					None	None	
Room is free of pests?					None	None	
THERMAL COMFORT							
Temperature in my classroom is generally comfortable (72F-76F)?			room appears to be humid and hot		None	None	
Room is usually comfortable? (If no, please explain in the notes below.)			room appears to be humid and hot		None	None	
Classroom is free of significant temperature shifts?			room appears to be humid and hot		None	None	
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			room appears to be humid and hot		None	None	
209	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough							
Bathroom exhaust fan is not functioning properly.					Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Signs of microbial growth.					Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Physical Plant Operations	2
210	Temp	<input type="text" value="76.1"/>	RH% <input type="text" value="52.9"/>	CO2 <input type="text" value="1016"/>	Occupants: <input type="text" value="22"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			Temperature was elevated at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

210

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

None

None

GENERAL CLEANLINESS

Trash is removed daily and trash bags are changed as appropriate?

No issues identified regarding trash removal practices.

None

None

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

None

None

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

None

Classrooms general appearance is clean and acceptable?

None

None

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-76F)?

Temperature was elevated at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Room is usually comfortable? (If no, please explain in the notes below.)

None

None

211

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

211

Temp RH% CO2 Occupants:

EXCESS MOISTURE IN CLASSROOMS

Area around and under classroom sinks free of leaks?	Occasionally, I see evidence of water leakage from the drain pipes under the sink. It was brought to the attention of the custodial staff but I have not been informed that anything was ever done to resolve the problem.	No leaks identified. Signs of previous water intrusion as evidenced by stains in cabinet.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
--	--	---	--	---------------------------	---

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			None	None	
Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None	None	
Room is free of pests?		No pests observed at the time of assessment.	None	None	

LOCAL EXHAUST FANS

Other exhaust fans that may exist in the classroom are functioning properly?	There is no bathroom in my classroom. There is, however, an adult bathroom five feet away from my door and there is no exhaust fan in that room.	Exhaust fan is functioning properly.	None	None	
Bathroom exhaust fan is functioning properly?	There is no bathroom in my classroom. There is, however, an adult bathroom five feet away from my door and there is no exhaust fan in that room.		None	None	

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-76F)?	Cold!	Temperature was acceptable at the time of assessment.	None	None	
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Cold!	Temperature was acceptable at the time of assessment.	None	None	
Classroom is free of significant temperature shifts?	Cold!	Temperature was acceptable at the time of assessment.	None	None	
Room is usually comfortable? (If no, please explain in the notes below.)	Cold!	Temperature was acceptable at the time of assessment.	None	None	

301

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None	None	
Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
301	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text" value="29"/>		
	Room is free of pests?				No pests observed at the time of assessment.	None	None
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?		I do not have a bathroom in my classroom			None	None
	Other exhaust fans that may exist in the classroom are functioning properly?		I do not have a bathroom in my classroom		Exhaust fan is functioning properly.	None	None
301D	Temp	<input type="text" value="69.1"/>	RH% <input type="text" value="56.7"/>	CO2 <input type="text" value="1198"/>	Occupants: <input type="text"/>		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					None	None
	GENERAL CLEANLINESS						
	Room is free of pests?					None	None
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	LOCAL EXHAUST FANS						
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?					None	None
	THERMAL COMFORT						
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is usually warm and a fan is needed daily.		Temperature was low at the time of assessment.	None	None
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is usually warm and a fan is needed daily.		Temperature was low at the time of assessment.	None	None
	Classroom is free of significant temperature shifts?		Room is usually warm and a fan is needed daily.			None	None
302	Temp	<input type="text" value="71.9"/>	RH% <input type="text" value="54.3"/>	CO2 <input type="text" value="1959"/>	Occupants: <input type="text" value="27"/>		
	DRAIN TRAPS IN THE CLASSROOM						
	Water run in sinks at least once per week (about 2 cups of water).					None	None
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?		The only time my room is dusted and vacuumed is when I am present. That is very seldom.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
302	Temp	71.9	RH% 54.3	CO2 1959	Occupants: 27			
	Floor is cleaned on a regular basis?	The only time my room is dusted and vacuumed is when I am present. That is very seldom.			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	There is no bathroom in the room.				None	None	
401	Temp	75.8	RH% 49.2	CO2 969	Occupants: 2			
	GENERAL CLEANLINESS							
	Room is free of pests?					None	None	
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?					None	None	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
402	Temp	70.5	RH% 53.9	CO2 1074	Occupants: 27			
	AIR CONDITIONING							
	Room is free of smell of chemicals?	my room has had a putrid smell in it for months... which is currently being addressed by the custodial staff and the plumbers and air conditioning specialists . It has not been corrected as of this survey				None	None	
	Room is free of smell of mold or mildew?	my room has had a putrid smell in it for months... which is currently being addressed by the custodial staff and the plumbers and air conditioning specialists . It has not been corrected as of this survey				None	None	
	Room is free of smell of vehicle exhaust?	my room has had a putrid smell in it for months... which is currently being addressed by the custodial staff and the plumbers and air conditioning specialists . It has not been corrected as of this survey				None	None	
	GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
402	Temp	70.5	RH% 53.9	CO2 1074	Occupants: 27			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Food, if any, is stored in tightly sealed containers?					None	None	
	Room is free of the use of scented cleaners and air fresheners?					None	None	
403	Temp	70.3	RH% 53.8	CO2 1176	Occupants: 19			
	AIR CONDITIONING							
	Room is free of smell of chemicals?				My room has an odor. It is currently being addressed by the maintenance people at our school.	None	None	
411	Temp	74.5	RH% 43.7	CO2 2348	Occupants: 23			
	AIR CONDITIONING							
	Room is free of smell of mold or mildew?					None	None	
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	DRAIN TRAPS IN THE CLASSROOM							
	Water run in sinks at least once per week (about 2 cups of water).					None	None	
	EXCESS MOISTURE IN CLASSROOMS							
	Windows, windowsills and window frames free of continuous condensation?					None	None	
	Area around and under classroom sinks free of leaks?					None	None	
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?					None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
411	Temp	74.5	RH% 43.7	CO2 2348	Occupants: 23		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			C does not apply to my classroom. I am basing my answer on outside bathrooms. I asked my students if the bathrooms have a fan and they said no.	None	None	
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			C does not apply to my classroom. I am basing my answer on outside bathrooms. I asked my students if the bathrooms have a fan and they said no.	None	None	
412	Temp	74.4	RH% 45.5	CO2 1496	Occupants: 31		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?				None	None	
	THERMAL COMFORT						
	Temperature in my classroom is generally comfortable (72F-76F)?			The room is to hot in the morning hours, then to cold around lunch time.	Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2
	Classroom is free of significant temperature shifts?			The room is to hot in the morning hours, then to cold around lunch time.	Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2
	Room is usually comfortable? (If no, please explain in the notes below.)			The room is to hot in the morning hours, then to cold around lunch time.	Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2
415	Temp	71.2	RH% 49.4	CO2 615	Occupants: 2		
	EXCESS MOISTURE IN CLASSROOMS						
	Classroom lavatories/water fountains free of leaks?				None	None	
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				None	None	
	Walkthrough						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
415	Temp	71.2	RH% 49.4	CO2 615	Occupants: 2			
				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
418	Temp	71.1	RH% 50.3	CO2 595	Occupants: 2			
AIR CONDITIONING								
	Windows/doors are operable and are kept closed?				None	None		
GENERAL CLEANLINESS								
	Classrooms general appearance is clean and acceptable?				None	None		
	Floor is cleaned on a regular basis?				None	None		
	Classroom is dusted/vacuumed thoroughly and regularly?				None	None		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS								
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				None	None		
	Other exhaust fans that may exist in the classroom are functioning properly?				None	None		
	Bathroom exhaust fan is functioning properly?				None	None		
THERMAL COMFORT								
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Room is usually either very warm or very cold. No in between.		Temperature was low at the time of assessment.	None	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Room is usually either very warm or very cold. No in between.			None	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is usually either very warm or very cold. No in between.		Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is usually either very warm or very cold. No in between.		Temperature was low at the time of assessment.	None	None	
	Classroom is free of significant temperature shifts?		Room is usually either very warm or very cold. No in between.		Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

419

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

None None

DRAIN TRAPS IN THE CLASSROOM

Water run in sinks at least once per week (about 2 cups of water).

None None

GENERAL CLEANLINESS

Spills and other such issues requiring custodial assistance are addressed in a timely manner?

None None

Floor is cleaned on a regular basis?

None None

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site Based 2

Classroom is dusted/vacuumed thoroughly and regularly?

None None

Classrooms general appearance is clean and acceptable?

None None

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-76F)?

Either too hot with air being off, or too cold, cannot be easily adjusted without causing problems in the rest of the classrooms. If we adjust the system it shuts down all together

Temperature was acceptable at the time of assessment. Facilities serviceperson should monitor this room. Site Based 2

Room is usually comfortable? (If no, please explain in the notes below.)

Either too hot with air being off, or too cold, cannot be easily adjusted without causing problems in the rest of the classrooms. If we adjust the system it shuts down all together

Temperature was acceptable at the time of assessment. Facilities serviceperson should monitor this room. Site Based 2

Classroom is free of significant temperature shifts?

Either too hot with air being off, or too cold, cannot be easily adjusted without causing problems in the rest of the classrooms. If we adjust the system it shuts down all together

Temperature was acceptable at the time of assessment. Facilities serviceperson should monitor this room. Site Based 2

601

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site Based 2

Classroom is dusted/vacuumed thoroughly and regularly?

None None

Classrooms general appearance is clean and acceptable?

None None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
601	Temp	76.4	RH%	57.9	CO2	827	Occupants:	18			
	Floor is cleaned on a regular basis?				None				None		
	THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)			My room is too cold for me and my students.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Temperature in my classroom is generally comfortable (72F-76F)?			My room is too cold for me and my students.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Classroom is free of significant temperature shifts?			My room is too cold for me and my students.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
605	Temp	73.7	RH%	55.1	CO2	838	Occupants:	24			
	EXCESS MOISTURE IN CLASSROOMS										
	Windows, windowsills and window frames free of continuous condensation?					None				None	
610	Temp	76.3	RH%	59.6	CO2	941	Occupants:	24			
	AIR CONDITIONING										
	Air is flowing without obstruction?					None				None	
	Air flowing from air supply?					None				None	
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?					None				None	
	THERMAL COMFORT										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
610	Temp	76.3	RH%	59.6	CO2	941	Occupants:	24			
	Room is usually comfortable? (If no, please explain in the notes below.)		MY ROOM IS USUALLY WARM...	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
	Temperature in my classroom is generally comfortable (72F-76F)?		MY ROOM IS USUALLY WARM...	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
620	Temp	75.5	RH%	58.7	CO2	1121	Occupants:	26			
	DRAIN TRAPS IN THE CLASSROOM If not regularly used, toilets flushed once each week.								None	None	
	EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Policy of completing turning off AC at night/weekends causing mold /mildew to grow in schools. Instead of turning it off why not just raise the thermostate. Electric bill more than likely higher than it needs to be since on Monday so long to cool down t						None	None	
	GENERAL CLEANLINESS Floor is cleaned on a regular basis?		There is not enough custodial staff (at any school) to do what needs to be done on a daily basis. Our custodians are wonderful but they are stretched too far!						None	None	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		There is not enough custodial staff (at any school) to do what needs to be done on a daily basis. Our custodians are wonderful but they are stretched too far!	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
	Classroom is dusted/vacuumed thoroughly and regularly?		There is not enough custodial staff (at any school) to do what needs to be done on a daily basis. Our custodians are wonderful but they are stretched too far!						None	None	
	THERMAL COMFORT Classroom is free of significant temperature shifts?		Too cold most of time. However temperature shifts are due to poor AC system that is always going down.	Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based					2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
620	Temp	75.5	RH%	58.7	CO2	1121	Occupants:	26			
	Room is usually comfortable? (If no, please explain in the notes below.)	Too cold most of time. However temperature shifts are due to poor AC system that is always going down.			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based				2
	Temperature in my classroom is generally comfortable (72F-76F)?	Too cold most of time. However temperature shifts are due to poor AC system that is always going down.			Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based				2
621	Temp	74.3	RH%	58.7	CO2	1108	Occupants:	27			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?	Room is acceptable except it is not consistently dusted, other than by classroom teacher.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Room is free of pests?	Room is acceptable except it is not consistently dusted, other than by classroom teacher.				None	None				
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?	We do not have exhaust fans.				None	None				
	Other exhaust fans that may exist in the classroom are functioning properly?	We do not have exhaust fans.				None	None				
	Walkthrough										
					Dust observed on supply register at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
624	Temp	73.7	RH%	59.1	CO2	1134	Occupants:	25			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?					None	None				
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					None	None				
	GENERAL CLEANLINESS										
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?					None	None				
	Classroom is dusted/vacuumed thoroughly and regularly?					None	None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority					
624	Temp	73.7	RH%	59.1	CO2	1134	Occupants:	25				
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based			2			
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based			2			
LOCAL EXHAUST FANS												
Bathroom exhaust fan is functioning properly?					None	None						
625	Temp	75.2	RH%	58.2	CO2	1187	Occupants:	25				
	GENERAL CLEANLINESS											
	Classroom is dusted/vacuumed thoroughly and regularly?					None	None					
Walkthrough												
			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2			
			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2			
628	Temp	75.2	RH%	57.7	CO2	1191	Occupants:	25				
	LOCAL EXHAUST FANS											
	Bathroom exhaust fan is functioning properly?			NO exhaust systems that I know of.		None	None					
Other exhaust fans that may exist in the classroom are functioning properly?			NO exhaust systems that I know of.		None	None						
629	Temp	74.3	RH%	57.6	CO2	1023	Occupants:	2				
	GENERAL CLEANLINESS											
	Classroom is dusted/vacuumed thoroughly and regularly?					None	None					
Room is free of pests?					None	None						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
630	Temp	76.4	RH% 59.8	CO2 1004	Occupants:	9		
AIR CONDITIONING								
Windows/doors are operable and are kept closed?					None	None		
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
EXCESS MOISTURE IN CLASSROOMS								
Cold water pipes free of continuous condensation?					None	None		
Indoor surfaces of exterior walls free of continuous condensation?					None	None		
Windows, windowsills and window frames free of continuous condensation?					None	None		
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					None	None		
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classrooms general appearance is clean and acceptable?					None	None		
Floor is cleaned on a regular basis?					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT								
Classroom is free of significant temperature shifts?			It is extremely cold in the room!, too cold		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)			It is extremely cold in the room!, too cold		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
630 Temperature in my classroom is generally comfortable (72F-76F)?	Temp <input type="text" value="76.4"/>	RH% <input type="text" value="59.8"/>	CO2 <input type="text" value="1004"/>	Occupants: <input type="text" value="9"/>	None	None	