79.7 52% Virginia Young Elementary Principal: Dr. Mark Strauss Co₂ Temp RH Walkthrough Date: 4/21/2004 Assignment Member: Jeff Moquin **Outside Measurements** Responsible **Recommended Corrective Action** Room Priority Assessment Comments 2 Site 120 Unauthorized chemicals identified. Site to remove all unauthorized chemicals. 2 Site Vent in storage closet and surrounding ceiling tiles are dirty. Custodial staff to clean and sanitize vent and tiles. 120 123 2 Site Vent in storage closet and surrounding ceiling tiles are dirty. Custodial staff to clean and sanitize vent and tiles. 153 2 Site Dust and debris was observed on the air supply and return Custodial staff should clean and sanitize the air supply and registers at the time of the assessment. Temperature was return registers in this classroom. within recommended range at time of assessment. 3 Site Vent in storage closet is dirty. Custodial staff to clean vent. 153 Site Site to contact District Maintenance. 217 3 Site Live plant and air freshener in room. Remove plant and air freshener. 501 3 504 2 Site Teacher is storing unsealed food items within classroom. This Staff should be encouraged to store all food items in could lead to a pest problem. sealable plastic containers. 504 3 Site On the date of assessment, unauthorized cleaning supplies Location should remove unauthorized cleaning supplies were observed in this classroom. from this classroom and discourage the use of unauthorized chemicals throughout the school. 3 Site Custodial staff should thorougly clean all environmental 508 Dust accumulation was observed on environmental surfaces. surfaces within classroom.

Tools for Schools - Indoor Air Quality Follow-up Action Plan for <u>Site</u>

