

Report: PPO

WALKER ELEMENTARY

Walkthrough Date: 05/12/2006 Temp RH CO2

Outdoor Parameters: 78.3 61.3 549

Room	Priority	Responsible	Answer	Recommendation
130B	Inside Parameters:	Temp	RH	CO2
		78.3	61.3	549

2 PPO Environmental parameters were not within acceptable range at the time of assessment.. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
139	Inside Parameters:	Temp	RH	CO2
		76.6	63.2	831

2 PPO Humidity was slightly elevated at the time of assessment. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

2 PPO Environmental parameters were not within acceptable range at the time of assessment.. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
141	Inside Parameters:	Temp	RH	CO2
		80.2	52.7	65.4

2 PPO Environmental parameters were not within acceptable range at the time of assessment.. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
147	Inside Parameters:	Temp	RH	CO2
		81.5	49.4	1012

2 PPO Environmental parameters were not within acceptable range at the time of assessment.. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
152	Inside Parameters:	Temp	RH	CO2
		76.1	64.1	833

1	PPO	Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.
2	PPO	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
2	PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
153	Inside Parameters:	Temp	RH	CO2
		75.5	65.5	832

2	PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.
---	-----	---	--

Room	Priority	Responsible	Answer	Recommendation
505	Inside Parameters:	Temp	RH	CO2
		75.8	58.5	857

1	PPO	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.
---	-----	--	---

Room	Priority	Responsible	Answer	Recommendation
506	Inside Parameters:	Temp	RH	CO2
		71.2	65.6	843

2	PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.
---	-----	---	--

Room	Priority	Responsible	Answer	Recommendation
517	Inside Parameters:	Temp	RH	CO2
		76	61.8	888

2	PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.
---	-----	---	--

Room	Priority	Responsible	Answer	Recommendation
519	Inside Parameters:	Temp	RH	CO2
		75.1	62.8	876

2	PPO	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
2	PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
524	Inside Parameters:	Temp	RH	CO2
		73.5	62.3	848

2	PPO	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.
---	-----	---	--

Room	Priority	Responsible	Answer	Recommendation
525A	Inside Parameters:	Temp	RH	CO2
		74.5	65.5	842

2	PPO	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
---	-----	---	---

2	PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.
---	-----	---	--

Room	Priority	Responsible	Answer	Recommendation
526	Inside Parameters:	Temp	RH	CO2
		74.8	65.4	887

2	PPO	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
---	-----	---	---

2	PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.
---	-----	---	--

2	PPO	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.
---	-----	---	--

Room	Priority	Responsible	Answer	Recommendation
527	Inside Parameters:	Temp	RH	CO2
		75.7	64.4	954

2	PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.
---	-----	---	--

--	--	--	--	--

Room	Priority	Responsible	Answer	Recommendation
528	Inside Parameters:	Temp	RH	CO2
		75.8	62.9	866
2		PPO	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
2		PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.
Room	Priority	Responsible	Answer	Recommendation
529	Inside Parameters:	Temp	RH	CO2
		75.9	62.8	857
2		PPO	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
2		PPO	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.