

WALKER ELEMENTARY

Walkthrough Date: 05/12/2006 Temp RH CO2

Outdoor Parameters: 78.6 74.6 476

Room	Section	Question	Answer	Recommendation	Responsible
102	Inside Parameters:	Temp	RH	CO2	
		78.8	60.7	673	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is functioning properly.		
Room	Section	Question	Answer	Recommendation	Responsible
1039P	Inside Parameters:	Temp	RH	CO2	
		79.7	51.6	673	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Portable 1039PK Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	Portable 1039PK - No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
104	Inside Parameters:	Temp 78.8	RH 60.3	CO2 705	
GENERAL CLEANLINESS		Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
THERMAL COMFORT		Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT		Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the	Site

thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
130B	Inside Parameters:	Temp	RH	CO2	
		78.3	61.3	549	
GENERAL CLEANLINESS		Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS		Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS		Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS		Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
THERMAL COMFORT		Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT		Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT		Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Site based facilities serviceperson should monitor this room.	Site
THERMAL COMFORT		Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of	Physical Plant Operations to evaluate and repair as appropriate.	PPO

AIR CONDITIONING	Air flowing from air supply?	assessment.. Air supply/return ventilation is functioning.
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.

Room	Section	Question	Answer	Recommendation	Responsible
139	Inside Parameters:	Temp 76.6	RH 63.2	CO2 831	
	EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace ceiling tiles.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
	LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.		

Room	Section	Question	Answer	Recommendation	Responsible
140	Inside Parameters:	Temp 74.6	RH 56	CO2 752	

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
--------------------------	--	--	--	------

Room	Section	Question	Answer	Recommendation	Responsible
141	Inside Parameters:	Temp 80.2	RH 52.7	CO2 65.4	

GENERAL CLEANLINESS	Food, if any, is stored in tightly sealed containers?	No unsealed food items were observed at the time of assessment.			
DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	It appears as though water is poured down the floor drain at least once a week.			
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site	
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site	
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO	

Room	Section	Question	Answer	Recommendation	Responsible
144	Inside Parameters:	Temp 80.1	RH 50.4	CO2 850	

ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
--------------------------	--	--	--	------

THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
AIR CONDITIONING	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
147	Inside Parameters:	Temp 81.5	RH 49.4	CO2 1012	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	THERMAL	Room is usually comfortable? (If	Environmental parameters	Physical Plant Operations to evaluate and	PPO

COMFORT no, please explain in the notes below.) were not within acceptable range at the time of assessment.. repair as appropriate.

ART SUPPLIES Art supplies okay? No art supplies in room. Room not being used as an art room.

Room	Section	Question	Answer	Recommendation	Responsible
150	Inside Parameters:	Temp 76.3	RH 63.1	CO2 808	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	AIR CONDITIONING	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.		

Room	Section	Question	Answer	Recommendation	Responsible
151	Inside Parameters:	Temp 76	RH 64.5	CO2 845	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		

GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site	
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.			
Room	Section	Question	Answer	Recommendation	Responsible
152	Inside Parameters:	Temp 76.1	RH 64.1	CO2 833	
GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.			
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site	
GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.			
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site	
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.			
GENERAL CLEANLINESS	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..			
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site	
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site	

EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	PPO
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
AIR CONDITIONING	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.		

Room	Section	Question	Answer	Recommendation	Responsible
153	Inside Parameters:	Temp 75.5	RH 65.5	CO2 832	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site

ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.		

Room	Section	Question	Answer	Recommendation	Responsible
154	Inside Parameters:	Temp 74.5	RH 65.6	CO2 738	

EXCESS MOISTURE IN CLASSROOMS
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?
No leaks or signs of water intrusion identified.

Room	Section	Question	Answer	Recommendation	Responsible
155	Inside Parameters:	Temp 74.6	RH 65.5	CO2 717	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student	This is a general issue requiring approved	Site based administration is encouraged to communicate all known student allergies to	Site

allergies?

communication among all stakeholders.

the appropriate personnel in order to modify classroom activities/conditions when necessary.

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water).

It appears as though water is poured down the floor drain at least once a week.

Room	Section	Question	Answer	Recommendation	Responsible
160	Inside Parameters:	Temp 73.4	RH 61.7	CO2 543	

GENERAL CLEANLINESS

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply and return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

EXCESS MOISTURE IN CLASSROOMS

Windows, windowsills and window frames free of continuous condensation?

No condensation on windows at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
168B	Inside Parameters:	Temp 73.1	RH 58.2	CO2 547	

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply and return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site

GENERAL CLEANLINESS

Room is free of pests?

No pests observed at the time of assessment.

GENERAL CLEANLINESS

Floor is cleaned on a regular basis?

Dust and dirt accumulation on floor.

Facilities serviceperson to thoroughly clean and sanitize.

Site

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	It appears as though water is poured down the floor drain at least once a week.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
503	Inside Parameters:	Temp 76.1	RH 58.8	CO2 1018	

THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
505	Inside Parameters:	Temp 75.8	RH 58.5	CO2 857	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site

GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.		

Room	Section	Question	Answer	Recommendation	Responsible
505B	Inside Parameters:	Temp 76.5	RH 58.4	CO2 852	

GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		

THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
506	Inside Parameters:	Temp 71.2	RH 65.6	CO2 843	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning	Exhaust fan is functioning properly.		

properly?

Room	Section	Question	Answer	Recommendation	Responsible
516	Inside Parameters:	Temp 76.1	RH 59.2	CO2 836	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.	Site
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	It appears as though water is poured down the floor drain at least once a week.		
	DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.		
	EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.		
	EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		

EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.
ART SUPPLIES	Exposure minimized for art supplies?	No art supplies in room. Room not being used as an art room.
ART SUPPLIES	Exposure minimized for science supplies?	No science supplies in room. Room not being used as a science room.
ART SUPPLIES	Exposure minimized for industrial supplies?	No industrial supplies in room. Room not being used as an industrial room.

Room	Section	Question	Answer	Recommendation	Responsible
517	Inside Parameters:	Temp	RH	CO2	

	76	61.8	888	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
518	Inside Parameters:	Temp	RH	CO2	
		76.3	58.7	902	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved		

			chemicals found at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site	
ANIMALS IN THE CLASSROOM	Classroom is free of animals and pets?	No animals identified at the time of assessment.			
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.			
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.			
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..			
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.			

Room	Section	Question	Answer	Recommendation	Responsible
519	Inside Parameters:	Temp	RH	CO2	
		75.1	62.8	876	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site	
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.			

THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	Live plants in room. Plant soil is a source of microbial growth.	Site based administration to advise staff to remove live plants.	Site
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
521	Inside Parameters:	Temp 73.8	RH 66.1	CO2 869	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site	
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site	
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.			
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site	
ANIMALS IN THE CLASSROOM	Classroom is free of animals and pets?	No animals identified at the time of assessment.			

LOCAL EXHAUST FANS Bathroom exhaust fan is functioning properly? No bathroom. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
524	Inside Parameters:	Temp 73.5	RH 62.3	CO2 848	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
Room	Section	Question	Answer	Recommendation	Responsible
525A	Inside Parameters:	Temp 74.5	RH 65.5	CO2 842	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.		
AIR CONDITIONING	Air is flowing without obstruction?	Air flowing without obstruction at the time of assessments.		

Room	Section	Question	Answer	Recommendation	Responsible
526	Inside Parameters:	Temp	RH	CO2	
		74.8	65.4	887	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student	This is a general issue requiring approved	Site based administration is encouraged to communicate all known student allergies to	Site

	allergies?	communication among all stakeholders.	the appropriate personnel in order to modify classroom activities/conditions when necessary.	
DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.		
DRAIN TRAPS IN THE CLASSROOM	If not regularly used, toilets flushed once each week.	It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning	No exhaust fans in room. Identified in error.		

properly?
 ART SUPPLIES Science supplies okay? No science supplies in room.
 Room not being used as a science room.

Room	Section	Question	Answer	Recommendation	Responsible
527	Inside Parameters:	Temp	RH	CO2	
		75.7	64.4	954	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.			
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.		Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.		Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.			
GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.			
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.		Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		Site
EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.			
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.			
EXCESS	Area around and under classroom	No leaks or signs of water			

MOISTURE IN CLASSROOMS	sinks free of leaks?	intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
528	Inside Parameters:	Temp 75.8	RH 62.9	CO2 866	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant	Temperature was acceptable at		

COMFORT THERMAL COMFORT	temperature shifts? Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	the time of assessment. No gaps in windows or doors identified at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
529	Inside Parameters:	Temp 75.9	RH 62.8	CO2 857	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
540	Inside Parameters:	Temp	RH	CO2	

		74.3	66.2	652	
GENERAL CLEANLINESS		Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS		Room is free of pests?	No pests observed at the time of assessment.		
ANIMALS IN THE CLASSROOM		Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site

Room	Section	Question	Answer	Recommendation	Responsible
751	Inside Parameters:	Temp	RH	CO2	
		74.2	53.2	788	
	DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	No floor drain in room.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		

Room	Section	Question	Answer	Recommendation	Responsible
755	Inside Parameters:	Temp	RH	CO2	
		74.1	56.9	602	
	DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	No floor drain in room.		
	EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		