

--	--	--

	Category	Detail	Assessment Comments	Recommended Corrective Action
113A	76.7	51%	1306	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		27 occupants in classroom at time of assessment. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
113B	76.5	52%	1347	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		31 occupants in classroom at time of assessment. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
116	74.2	51%	994	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
117	General Classroom Information		21 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		One stained ceiling tile identified from an old roof leak.	Install new ceiling tiles.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	Thermal Comfort	Humidity level.	the humidity was 51% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	73.8	53%	1019	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
11N	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		26 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
		Rooms needs to be dusted more often.		
	77.4	51%	3205	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Room has a musty smell.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
120					
		73.8	54%	1076	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		26 occupants in classroom at time of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.	
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.		
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.		
122					
		73.8	53%	948	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		3 occupants in classroom at time of assessment.	No corrective action recommended at this time.	
General Classroom Information		One stained ceiling tile identified from an old roof leak.	Install new ceiling tiles.		
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.		
123					
		73.6	53%	1207	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>		
General Classroom Information		1 occupant in classroom at time of assessment. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.		

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Four air supply vents.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

127

74.3	53%	1379
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		2 occupants in classroom at time of assessment. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

129

74.3	55%	1299
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		23 occupants in classroom at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
131	73.8 <i>Temp</i>	55% <i>RH</i>	1304 <i>Co2</i>	
	General Classroom Information		23 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
183C	76 <i>Temp</i>	43% <i>RH</i>	1720 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment. Coils on both A/C units are very dirty. Only one of the two units was working properly.	Maintenance needs to inspect HVAC and repair.
	General Classroom Information		1 occupant in classroom at time of assessment Co2 level slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
184C	74.6 <i>Temp</i>	42% <i>RH</i>	1271 <i>Co2</i>	
	General Classroom Information		1 occupant in classroom at time of assessment. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
401	General Classroom Information		Coils on both A/C units are dirty.	Maintenance needs to inspect HVAC for proper operation.	
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.	
		79.4	57%	1825	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	General Classroom Information		HVAC was not working at time of assessment.	Maintenance needs to inspect HVAC for proper operation.	
	General Classroom Information		32 occupants in classroom at time of assessment. Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.	
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.			
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.		
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	HVAC was not working at time of assessment.	See other items.		
Thermal Comfort	Humidity level.	The humidity was 57% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.		
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	HVAC was not working at time of assessment.	See other items.		
Ventilation	Determine how your classroom is ventilated.	Four air supply vents and one return air grill.	No corrective action recommended at this time.		
	My room is not dusted!				

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
402	80.1 <i>Temp</i>	60% <i>RH</i>	1892 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		HVAC was not working at time of assessment.	Maintenance needs to inspect HVAC for proper operation.
	General Classroom Information		32 occupants in classroom at time of assessment. Co2 was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
406	76.9 <i>Temp</i>	47% <i>RH</i>	2464 <i>Co2</i>	
	General Classroom Information		3 occupants in classroom at time of assessment. Co2 level elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
408	8036 <i>Temp</i>	51% <i>RH</i>	2891 <i>Co2</i>	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Classroom Information		128 occupants in classroom at time of assessment. The Co2 reading along with the temperature was elevated due to the amount of people in the room at one time.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies	Minimize exposure to hazardous materials.		Site based administration will provide information to site based staff.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Four air supply vents and one return air grill.	No corrective action recommended at this time.
703	79.2	45%	2489
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
General Classroom Information		61 occupants in classroom at time of assessment. Co2 level was elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
76C	77.4	48%	1066
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		2 occupants in classroom at time of assessment.	

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
851	General Classroom Information		A/C coils on both stand alone units dirty.	Maintenance to inspect and repair as appropriate.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment with the exception of the tile floor.	clean and sanitize flooring.
	76.2	44%	1467	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
852	General Classroom Information		34 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	75.7	55%	2846	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		31 occupants in classroom at time of assessment. Co2 level elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Classroom Information		Teacher complained of dirt on the walls. Would like room repainted with semi gloss paint.	Maintenance to inspect and repair as appropriate.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
		Room is very dusty and tile floor is dirty.		

	<i>Category</i>		<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
856	76.1 <i>Temp</i>	55% <i>RH</i>	909 <i>Co2</i>		
	Drain Traps in the Classroom		Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms		Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information			9 occupants in classroom at time of assessment.	No corrective action recommended at this time.
857	75.2 <i>Temp</i>	58% <i>RH</i>	1180 <i>Co2</i>		
	General Classroom Information			21 occupants in classroom at time of assessment.	
	General Cleanliness		Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
Media Center	76.6 <i>Temp</i>	50% <i>RH</i>	1307 <i>Co2</i>		
	General Classroom Information			25 occupants in classroom at time of assessment. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
	General Cleanliness		Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment with the exception of minor dust on bookshelves and the media specialist desk.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	The books on the shelves get very dusty, especially those on the lower shelves. Dust on the books can attract moisture and lead to mold. Book collections in libraries should be kept in an air conditioned environment. Students often mention kitchen/food odors from cafeteria.				