

Cooper City High

IAQ Walkthrough 5/17/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
017	Temp <input type="text" value="79.9"/> RH% <input type="text" value="34.5"/> CO2 <input type="text" value="1586"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING				
	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.	None	None	
	Room is free of smell of mold or mildew?	Odor detected and no microbial growth identified.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
	ANIMALS IN THE CLASSROOM				
	Activities and/or room conditions are modified to address student allergies?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	ART SUPPLIES				
	Art supplies okay?	No art supplies in room. Room not being used as an art room.	None	None	
	EXCESS MOISTURE IN CLASSROOMS				
	Indoor surfaces of exterior walls free of continuous condensation?	No condensation on walls at the time of assessment.	None	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.	None	None	
	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.	None	None	
	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.	None	None	
	GENERAL CLEANLINESS				
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
017	Temp	<input type="text" value="79.9"/>	RH% <input type="text" value="34.5"/>	CO2 <input type="text" value="1586"/>	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None	None	
LOCKER ROOM							
Locker room and showers cleaned regularly and properly?				Issues not applicable. Room is not a locker room.	None	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was elevated at the time of assessment.	None	None	
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	None	
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None	None	
Walkthrough				Portable floor soft/walls and ceiling water damaged.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
102M	Temp	<input type="text" value="76.0"/>	RH% <input type="text" value="49.4"/>	CO2 <input type="text" value="899"/>	Occupants: <input type="text"/>		
Walkthrough				Carpet was stained and dirty.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
102N	Temp	<input type="text" value="76.7"/>	RH% <input type="text" value="50.5"/>	CO2 <input type="text" value="913"/>	Occupants: <input type="text"/>		
Walkthrough				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	3
				Carpet was stained and dirty.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
114	Temp	<input type="text" value="74.6"/>	RH% <input type="text" value="60.6"/>	CO2 <input type="text" value="936"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
114	Temp	74.6	RH% 60.6	CO2 936	Occupants:		
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor. Floor needs to be waxed.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	None
	LOCAL EXHAUST FANS						
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				Letter C and D does not exist in my room.	None	None
	Other exhaust fans that may exist in the classroom are functioning properly?				Letter C and D does not exist in my room.	Exhaust fan is functioning properly.	None
	Bathroom exhaust fan is functioning properly?				Letter C and D does not exist in my room.	Bathroom exhaust fan is functioning properly.	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	None
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	None
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Facilities serviceperson should monitor this room.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
117	Temp	74.8	RH% 60.1	CO2 769	Occupants:		
AIR CONDITIONING							
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None	None	
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None	None	
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Visible signs of microbial growth. Stained ceiling tiles.	Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.	Physical Plant Operations	1
	Cold water pipes free of continuous condensation?			No condensation on pipes at the time of assessment.	None	None	
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation on walls at the time of assessment.	None	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			I have not detected heat in this classroom all year. The normal temperature in the mornings is 59 degrees F (15 C) and about 65 by mid afternoon - if the outside air temp. has risen to 80 or above. The air conditioning is always too severe.	Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)			I have not detected heat in this classroom all year. The normal temperature in the mornings is 59 degrees F (15 C) and about 65 by mid afternoon - if the outside air temp. has risen to 80 or above. The air conditioning is always too severe.	Environmental parameters were within acceptable range at the time of assessment..	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
117	Temp	74.8	RH%	60.1	CO2	769	Occupants:	<input type="text"/>			
	Classroom is free of significant temperature shifts?	I have not detected heat in this classroom all year. The normal temperature in the mornings is 59 degrees F (15 C) and about 65 by mid afternoon - if the outside air temp. has risen to 80 or above. The air conditioning is always too severe.			Temperature was acceptable at the time of assessment.	None	None				
	Temperature in my classroom is generally comfortable (72F-76F)?	I have not detected heat in this classroom all year. The normal temperature in the mornings is 59 degrees F (15 C) and about 65 by mid afternoon - if the outside air temp. has risen to 80 or above. The air conditioning is always too severe.			Temperature was acceptable at the time of assessment.	None	None				
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	I have not detected heat in this classroom all year. The normal temperature in the mornings is 59 degrees F (15 C) and about 65 by mid afternoon - if the outside air temp. has risen to 80 or above. The air conditioning is always too severe.			Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Facilities serviceperson should monitor this room.	Site Based			2		
119	Temp	72.4	RH%	57.5	CO2	743	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2	
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2		
LOCAL EXHAUST FANS											
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)						None			None		
124	Temp	72.4	RH%	59.0	CO2	915	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>126N</i>	Temp	<input type="text" value="77.7"/>	RH% <input type="text" value="35.6"/>	CO2 <input type="text" value="3300"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None		
GENERAL CLEANLINESS							
Room is free of pests?			No pests observed at the time of assessment.	None	None		
Classroom is dusted/vacuumed thoroughly and regularly?			Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based		2
<i>131</i>	Temp	<input type="text" value="75.3"/>	RH% <input type="text" value="58.8"/>	CO2 <input type="text" value="1616"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			Mold and mildew smell is evident whenever the ac is not working properly	Odor detected and no microbial growth identified.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Mold/Mildew problem when ac is not working	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	None	
Other exhaust fans that may exist in the classroom are functioning properly?				No exhaust fans in room. Identified in error.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
134	Temp	72.6	RH% 57.1	CO2 1149	Occupants:		
AIR CONDITIONING							
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None	None
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None	None
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None
EXCESS MOISTURE IN CLASSROOMS							
	Windows, windowsills and window frames free of continuous condensation?	N/A			No condensation on windows at the time of assessment.	None	None
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	I really have no idea.			No exhaust fans in room. Identified in error.	None	None
	Other exhaust fans that may exist in the classroom are functioning properly?	I really have no idea.			No exhaust fans in room. Identified in error.	None	None
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	I really have no idea.				None	None
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	I really have no idea.			No exhaust fans in room. Identified in error.	None	None
THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?	It is o.k. for me usually but too cold for the students. Hard to please everyone?????!!!			Temperature was acceptable at the time of assessment.	None	None
	Classroom is free of significant temperature shifts?	It is o.k. for me usually but too cold for the students. Hard to please everyone?????!!!			Temperature was acceptable at the time of assessment.	None	None
Walkthrough							
					Signs of water intrusion visible microbial growth. Stained ceiling tiles.	Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.	Physical Plant Operations 2

141 Temp 72.8 RH% 60.4 CO2 1630 Occupants:

AIR CONDITIONING

Windows/doors are operable and are kept closed?	not enough fresh air, no air circulation	Windows and doors are operable and are kept closed.	None	None
Air flowing from air supply?	not enough fresh air, no air circulation	Air flowing without obstruction at the time of assessments.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
141	Temp	72.8	RH% 60.4	CO2 1630	Occupants:		
Air is flowing without obstruction?	not enough fresh air, no air circulation			Air flowing without obstruction at the time of assessments.	None	None	
Room is free of smell of mold or mildew?	not enough fresh air, no air circulation			No odor detected at the time of assessment.	None	None	
Room is free of smell of chemicals?	not enough fresh air, no air circulation			No odor detected at the time of assessment.	None	None	
Room is free of smell of vehicle exhaust?	not enough fresh air, no air circulation			No odor detected at the time of assessment.	None	None	
GENERAL CLEANLINESS							
Classrooms general appearance is clean and acceptable?	too hot, smelly...moldy, musty, no air circulation			General cleanliness of the room at the time of assessment was acceptable.	None	None	
Room is free of pests?	too hot, smelly...moldy, musty, no air circulation			No pests observed at the time of assessment.	None	None	
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	too hot, smelly...moldy, musty, no air circulation			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	too hot, smelly...moldy, musty, no air circulation			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	too hot, smelly...moldy, musty, no air circulation			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)					None	None	
My classroom has sufficient exhaust systems based on the activities/functionality of the room?				Exhaust fan is functioning properly.	None	None	
Other exhaust fans that may exist in the classroom are functioning properly?				No exhaust fans in room. Identified in error.	None	None	
Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	None	
THERMAL COMFORT							
Temperature in my classroom is generally comfortable (72F-76F)?	too hot and sometimes too cold. smelly			Temperature was acceptable at the time of assessment.	None	None	
Room is usually comfortable? (If no, please explain in the notes below.)	too hot and sometimes too cold. smelly			Temperature was acceptable at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
141	Temp	<input type="text" value="72.8"/>	RH%	<input type="text" value="60.4"/>	CO2	<input type="text" value="1630"/>	Occupants:	<input type="text"/>
Classroom is free of significant temperature shifts?	too hot and sometimes too cold. smelly			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2	
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	too hot and sometimes too cold. smelly			No gaps in windows or doors identified at the time of assessment.	None	None		
143	Temp	<input type="text" value="71.1"/>	RH%	<input type="text" value="59.5"/>	CO2	<input type="text" value="1283"/>	Occupants:	<input type="text" value="0"/>
AIR CONDITIONING								
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None		
Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None	None		
ANIMALS IN THE CLASSROOM								
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
ART SUPPLIES								
Art supplies okay?				No art supplies in room. Room not being used as an art room.	None	None		
Industrial supplies okay?				No industrial supplies in room. Room not being used as an industrial room.	None	None		
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None		
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	None		
THERMAL COMFORT								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
143	Temp	71.1	RH%	59.5	CO2	1283	Occupants:	0			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	ROOM TEMPERATURE IS AT THE MERCY OF CUSTODIAN AND THE WEATHER. OFTEN THE AC IS OFF OR BROKEN IN MY AREA OF THE BUILDING WHILE OTHER AREAS NEVER HAVE PROBLEMS AT ALL! I SHOULD NOT HAVE TO SWEAT WHEN I AM TEACHING UNLESS I AM A GYM TEACHER.			Humidity was acceptable at the time of assessment.	None	None				
	Room is usually comfortable? (If no, please explain in the notes below.)	ROOM TEMPERATURE IS AT THE MERCY OF CUSTODIAN AND THE WEATHER. OFTEN THE AC IS OFF OR BROKEN IN MY AREA OF THE BUILDING WHILE OTHER AREAS NEVER HAVE PROBLEMS AT ALL! I SHOULD NOT HAVE TO SWEAT WHEN I AM TEACHING UNLESS I AM A GYM TEACHER.			Environmental parameters were within acceptable range at the time of assessment..	None	None				
	Temperature in my classroom is generally comfortable (72F-76F)?	ROOM TEMPERATURE IS AT THE MERCY OF CUSTODIAN AND THE WEATHER. OFTEN THE AC IS OFF OR BROKEN IN MY AREA OF THE BUILDING WHILE OTHER AREAS NEVER HAVE PROBLEMS AT ALL! I SHOULD NOT HAVE TO SWEAT WHEN I AM TEACHING UNLESS I AM A GYM TEACHER.			Temperature was acceptable at the time of assessment.	None	None				
	Classroom is free of significant temperature shifts?	ROOM TEMPERATURE IS AT THE MERCY OF CUSTODIAN AND THE WEATHER. OFTEN THE AC IS OFF OR BROKEN IN MY AREA OF THE BUILDING WHILE OTHER AREAS NEVER HAVE PROBLEMS AT ALL! I SHOULD NOT HAVE TO SWEAT WHEN I AM TEACHING UNLESS I AM A GYM TEACHER.			Temperature was acceptable at the time of assessment.	None	None				
	Walkthrough					Remove live plant from room	Site Based				3

144

Temp 73.1 RH% 59.7 CO2 16312 Occupants: 32

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?	The classroom, ledges, equipment, etc. are rarely dusted. When it gets to an uncomfortable level, I do it myself!	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
--	---	--	---	------------	---

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
144	Temp	73.1	RH%	59.7	CO2	16312	Occupants:	32			
Walkthrough							Dust and debris on ceiling tiles.		Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
147	Temp	72.6	RH%	62.7	CO2	1679	Occupants:	30			
ANIMALS IN THE CLASSROOM											
You are informed about the potential allergies of your students?									Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS											
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?							Dust and debris on ceiling tiles.		Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
GENERAL CLEANLINESS											
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?							Dust observed on supply/return registers at the time of assessment. Supply grill missing.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT											
Classroom is free of significant temperature shifts?			Temperature varies greatly throughout the day as the ambient temperature changes				Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.		Facilities serviceperson should monitor this room.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)			Temperature varies greatly throughout the day as the ambient temperature changes				Environmental parameters were not within acceptable range at the time of assessment.. Elevated CO2 and RH.		Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
Temperature in my classroom is generally comfortable (72F-76F)?			Temperature varies greatly throughout the day as the ambient temperature changes				Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.		Facilities serviceperson should monitor this room.	Site Based	2
148	Temp	70.1	RH%	66.5	CO2	1500	Occupants:				
AIR CONDITIONING											
Room is free of smell of mold or mildew?							No odor detected at the time of assessment.		None	None	
ANIMALS IN THE CLASSROOM											
Activities and/or room conditions are modified to address student allergies?									Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
148	Temp	70.1	RH% 66.5	CO2 1500	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	2
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?		Many days too hot!	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2
	Classroom is free of significant temperature shifts?		Many days too hot!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Many days too hot!	Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)		Many days too hot!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

150 Temp 69.4 RH% 68.1 CO2 1486 Occupants:

GENERAL CLEANLINESS

	Floor is cleaned on a regular basis?	The tile floors are generally dusty. Often the floors are not cleaned daily. Little to no infusion of fresh air from the ventilation system. Often too hot or too cold. Custodial staff needs proper supplies and equipment which should be funded by the Cou	Floor was clean at the time of assessment.	None	None
--	--------------------------------------	---	--	------	------

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
150	Temp	69.4	RH% 68.1	CO2 1486	Occupants:		
	Classrooms general appearance is clean and acceptable?	The tile floors are generally dusty. Often the floors are not cleaned daily. Little to no infusion of fresh air from the ventilation system. Often too hot or too cold. Custodial staff needs proper supplies and equipment which should be funded by the Cou			General cleanliness of the room at the time of assessment was acceptable.	None	None
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	The tile floors are generally dusty. Often the floors are not cleaned daily. Little to no infusion of fresh air from the ventilation system. Often too hot or too cold. Custodial staff needs proper supplies and equipment which should be funded by the Cou			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?	The tile floors are generally dusty. Often the floors are not cleaned daily. Little to no infusion of fresh air from the ventilation system. Often too hot or too cold. Custodial staff needs proper supplies and equipment which should be funded by the Cou			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
152	Temp	74.1	RH% 61.8	CO2 1670	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?	room is holds odors due to lack of infusion of fresh air and lack of air circulaiton			No odor detected at the time of assessment.	None	None
	Air flowing from air supply?	room is holds odors due to lack of infusion of fresh air and lack of air circulaiton			Air flowing without obstruction at the time of assessments.	None	None
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?	sometimes ants....an occasional roach				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations 1
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	Tile floors usually dusty & need to be cleaned daily. Often room temperature is too cold/too hot. No infusion of fresh air from ventilation system. Custodians work hard.County should properly fund schools so that can adequate staff is hired and proper			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

152

Temp RH% CO2

Occupants:

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Tile floors usually dusty & need to be cleaned daily. Often room temperature is too cold/too hot. No infusion of fresh air from ventilation system. Custodians work hard. County should properly fund schools so that can adequate staff is hired and proper

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Floor is cleaned on a regular basis?

Tile floors usually dusty & need to be cleaned daily. Often room temperature is too cold/too hot. No infusion of fresh air from ventilation system. Custodians work hard. County should properly fund schools so that can adequate staff is hired and proper

Floor was clean at the time of assessment.

None

None

LOCAL EXHAUST FANS

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

No exhaust system/ventilation in room. Identified in error.

None

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

students say that the room is often too cold or too hot

Temperature was elevated at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Room is usually comfortable? (If no, please explain in the notes below.)

students say that the room is often too cold or too hot

Environmental parameters were not within acceptable range at the time of assessment..

Physical Plant Operations to evaluate need for test and balance.

Physical Plant Operations

2

Temperature in my classroom is generally comfortable (72F-76F)?

students say that the room is often too cold or too hot

Temperature was elevated at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

153

Temp RH% CO2

Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
153	Temp	71.5	RH% 62.9	CO2 1388	Occupants:			
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	None	
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?				No pests observed at the time of assessment.	None	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	None	
	THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?		either too cold or too hot		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)		either too cold or too hot		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Classroom is free of significant temperature shifts?		either too cold or too hot		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
154G	Temp	<input type="text" value="72.6"/>	RH% <input type="text" value="59.9"/>	CO2 <input type="text" value="1100"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.			
GENERAL CLEANLINESS							
	Floor is cleaned on a regular basis?			Carpet was stained.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None	None	
154R	Temp	<input type="text" value="72.4"/>	RH% <input type="text" value="59.6"/>	CO2 <input type="text" value="914"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			Odor detected at the time of assessment. Remove tackable wall surface.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	Air is flowing without obstruction?			No supply in room	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Air flowing from air supply?			No air supply.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Room is free of smell of chemicals?			No odor detected at the time of assessment.	None	None	
GENERAL CLEANLINESS							
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None	None	
	Floor is cleaned on a regular basis?			Carpet was stained and dirty.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
LOCAL EXHAUST FANS							
	Other exhaust fans that may exist in the classroom are functioning properly?			Install exhaust.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No air supply in room.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
154R	Temp	<input type="text" value="72.4"/>	RH%	<input type="text" value="59.6"/>	CO2	<input type="text" value="914"/>	Occupants:	<input type="text"/>
Room is usually comfortable? (If no, please explain in the notes below.)			d)Humidity is variable and I am not able to state with definite terms. e)extreme alternating between hot and cold.	Temperature was acceptable at the time of assessment.	None	None		
Temperature in my classroom is generally comfortable (72F-76F)?			d)Humidity is variable and I am not able to state with definite terms. e)extreme alternating between hot and cold.	Temperature was acceptable at the time of assessment.	None	None		
Classroom is free of significant temperature shifts?			d)Humidity is variable and I am not able to state with definite terms. e)extreme alternating between hot and cold.	Temperature was acceptable at the time of assessment.	None	None		
154S	Temp	<input type="text" value="72"/>	RH%	<input type="text" value="60.2"/>	CO2	<input type="text" value="924"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Room is free of smell of mold or mildew?				Odor detected at the time of assessment. Carpet and tackable wall surface dirty and stained.	Facilities serviceperson to thoroughly clean and sanitize carpet with District approved germicidal cleaner. Physical plant to remove tackable wall surfaces.	Physical Plant Operations	2	
GENERAL CLEANLINESS								
Spills and other such issues requiring custodial assistance are addressed in a timely manner?				There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
Floor is cleaned on a regular basis?				Carpet was stained.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Remove stuffed animals.	Site Based	2	
THERMAL COMFORT								
Temperature in my classroom is generally comfortable (72F-76F)?			Room is usually extremely cold.	Temperature was acceptable at the time of assessment.	None	None		
Room is usually comfortable? (If no, please explain in the notes below.)			Room is usually extremely cold.	Temperature was acceptable at the time of assessment.	None	None		
Classroom is free of significant temperature shifts?			Room is usually extremely cold.	Temperature was acceptable at the time of assessment.	None	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
154T	Temp	72.7	RH% 57.9	CO2 930	Occupants:		
AIR CONDITIONING							
	Air is flowing without obstruction?			No supply grill in room.	Physical Plant Operations to evaluate and repair as appropriate. Install supply grill.	Physical Plant Operations	2
	Air flowing from air supply?			No supply grill in room.	Physical Plant Operations to evaluate and repair as appropriate. Install supply grill.	Physical Plant Operations	2
	Room is free of smell of mold or mildew?			Odor detected at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	1
GENERAL CLEANLINESS							
	Room is free of pests?			No pests observed at the time of assessment.	None	None	
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None	None	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No supply grill in room.	Physical Plant Operations to evaluate and repair as appropriate. Install supply grill.	Physical Plant Operations	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Carpet was stained and dirty.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			Exhaust fan is functioning properly.	None	None	
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None	None	
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>154T</i>	Temp	<input type="text" value="72.7"/>	RH% <input type="text" value="57.9"/>	CO2 <input type="text" value="930"/>	Occupants: <input type="text"/>		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	There is no circulation of air so when door is closed the room gets very warm and the air stagnant.			Humidity was acceptable at the time of assessment.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?	There is no circulation of air so when door is closed the room gets very warm and the air stagnant.			Temperature was acceptable at the time of assessment.	None	None
	Room is usually comfortable? (If no, please explain in the notes below.)	There is no circulation of air so when door is closed the room gets very warm and the air stagnant.			Temperature was acceptable at the time of assessment.	None	None
	Classroom is free of significant temperature shifts?	There is no circulation of air so when door is closed the room gets very warm and the air stagnant.			Temperature was acceptable at the time of assessment.	Remove heater from beneath desk.	Site Based 1
<i>155A</i>	Temp	<input type="text" value="71.2"/>	RH% <input type="text" value="58.9"/>	CO2 <input type="text" value="1111"/>	Occupants: <input type="text"/>		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	The floor is cleaned once a year which is not enough. The air conditioning is freezing in this room and causes me to be sick regularly.			No dust observed on supply/return registers at the time of assessment.	None	None
	Classroom is dusted/vacuumed thoroughly and regularly?	The floor is cleaned once a year which is not enough. The air conditioning is freezing in this room and causes me to be sick regularly.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?	The floor is cleaned once a year which is not enough. The air conditioning is freezing in this room and causes me to be sick regularly.			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?	My room is never comfortable. It is freezing almost all of the time and very uncomfortable. I have several jackets in the office and am often sick because of the temperature.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
155A	Temp	71.2	RH%	58.9	CO2	1111	Occupants:				
	Room is usually comfortable? (If no, please explain in the notes below.)		My room is never comfortable. It is freezing almost all of the time and very uncomfortable. I have several jackets in the office and am often sick because of the temperature.	Temperature was low at the time of assessment.	Check HVAC	Physical Plant Operations					2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		My room is never comfortable. It is freezing almost all of the time and very uncomfortable. I have several jackets in the office and am often sick because of the temperature.	Temperature was low at the time of assessment.	Check HVAC	Physical Plant Operations					2
	Temperature in my classroom is generally comfortable (72F-76F)?		My room is never comfortable. It is freezing almost all of the time and very uncomfortable. I have several jackets in the office and am often sick because of the temperature.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
156	Temp	71.9	RH%	58.6	CO2	1152	Occupants:				
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Every time it rains new stains appear. The custodial staff always addresses the roof leaks, but a new roof is needed.	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations					1
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None	None					
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?		There are no exhaust fans. There are two restrooms with no ventilation	No exhaust fans in room. Identified in error.	None	None					
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		There are no exhaust fans. There are two restrooms with no ventilation	No exhaust fans in room. Identified in error.	None	None					
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		Room is very cold most of the time	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
156	Temp	71.9	RH%	58.6	CO2	1152	Occupants:	<input type="text"/>			
	Temperature in my classroom is generally comfortable (72F-76F)?	Room is very cold most of the time			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based		2		
	Room is usually comfortable? (If no, please explain in the notes below.)	Room is very cold most of the time			Temperature was low at the time of assessment.	Check HVAC	Physical Plant Operations		1		
158	Temp	73.2	RH%	58.6	CO2	1345	Occupants:	<input type="text"/>			
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3		
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3		
EXCESS MOISTURE IN CLASSROOMS											
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations		1		
GENERAL CLEANLINESS											
	Room is free of pests?				No pests observed at the time of assessment.	None	None				
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Wax floor	Site Based		2		
THERMAL COMFORT											
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	None				
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	None				
161	Temp	71	RH%	59	CO2	1258	Occupants:	<input type="text"/>			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?				Exterior wall water damaged	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations		1		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

161

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Dust and debris on ceiling tiles.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

GENERAL CLEANLINESS

Floor is cleaned on a regular basis?

Dust and dirt accumulation on floor.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

None

None

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-76F)?

Room is sometimes too cold or too hot--never comfortable temperature.

Temperature was acceptable at the time of assessment.

None

None

Classroom is free of significant temperature shifts?

Room is sometimes too cold or too hot--never comfortable temperature.

Temperature was acceptable at the time of assessment.

None

None

Room is usually comfortable? (If no, please explain in the notes below.)

Room is sometimes too cold or too hot--never comfortable temperature.

Temperature was acceptable at the time of assessment.

None

None

163

Temp RH% CO2 Occupants:

Walkthrough

Stained ceiling tiles.

Facilities serviceperson to replace stained ceiling tiles.

Site Based

2

Walthrough

Dust and dirt accumulation on floor. Needs wax.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
164	Temp	70.9	RH% 59.1	CO2 1250	Occupants:		
AIR CONDITIONING							
	Room is free of smell of vehicle exhaust?			No odor detected at the time of assessment.	None	None	
	Room is free of smell of mold or mildew?			Visible water damage at exterior door.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	1
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
GENERAL CLEANLINESS							
	Room is free of pests?			No pests observed at the time of assessment.	None	None	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Carpet was stained	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No exhaust fans in room. Identified in error.	None	None	
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
164	Temp	<input type="text" value="70.9"/>	RH%	<input type="text" value="59.1"/>	CO2	<input type="text" value="1250"/>	Occupants:	<input type="text"/>
Temperature in my classroom is generally comfortable (72F-76F)?	Generally, the room is freezing cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Adjust HVAC	Physical Plant Operations	2	
Room is usually comfortable? (If no, please explain in the notes below.)	Generally, the room is freezing cold.			Temperature was acceptable at the time of assessment. Elevated CO2	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2	
Classroom is free of significant temperature shifts?	Generally, the room is freezing cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2	
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Generally, the room is freezing cold.			Humidity was acceptable at the time of assessment.	Adjust HVAC	Physical Plant Operations	2	
165	Temp	<input type="text" value="70.2"/>	RH%	<input type="text" value="60.6"/>	CO2	<input type="text" value="1142"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Room is free of smell of mold or mildew?	the room has an unidentifiable odor.			No odor detected at the time of assessment.	None	None		
Room is free of smell of chemicals?	the room has an unidentifiable odor.			No odor detected at the time of assessment.	None	None		
ANIMALS IN THE CLASSROOM								
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Door jambs are rotting from either moisture or mold			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1	
Windows, windowsills and window frames free of continuous condensation?	Door jambs are rotting from either moisture or mold			Condensation on walls at the time of assessment. Door jambs rotting	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1	
GENERAL CLEANLINESS								
Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	None		
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority		
165	Temp	70.2	RH%	60.6	CO2	1142	Occupants:		
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	None		
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	None	None		
THERMAL COMFORT									
	Classroom is free of significant temperature shifts?				The room is generally too cold. If there is a request to fix that, the response is negligible or to the other extreme - no ac	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)				The room is generally too cold. If there is a request to fix that, the response is negligible or to the other extreme - no ac	Temperature was low at the time of assessment.	Adjust HVAC	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?				The room is generally too cold. If there is a request to fix that, the response is negligible or to the other extreme - no ac	Temperature was low at the time of assessment.	Adjust HVAC	Site Based	2
167	Temp	69.1	RH%	61.4	CO2	1079	Occupants:		
GENERAL CLEANLINESS									
	Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?					Dust and dirt accumulation on floor. Floor need waxing.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS									
	Other exhaust fans that may exist in the classroom are functioning properly?				No bathroom or exhaust fan in classroom	No exhaust fans in room. Identified in error.	None	None	
	Bathroom exhaust fan is functioning properly?				No bathroom or exhaust fan in classroom	No exhaust fans in room. Identified in error.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
167	Temp	69.1	RH% 61.4	CO2 1079	Occupants:		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Physical Plant Operations	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
168	Temp	72.2	RH% 59.2	CO2 1188	Occupants:		
ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Dust observed on ceiling tiles.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
GENERAL CLEANLINESS							
	Floor is cleaned on a regular basis?		loose paper is swept up but not dirt	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		loose paper is swept up but not dirt	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
168	Temp	72.2	RH%	59.2	CO2	1188	Occupants:				
	Classroom is dusted/vacuumed thoroughly and regularly?		loose paper is swept up but not dirt	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
	Classrooms general appearance is clean and acceptable?		loose paper is swept up but not dirt	General cleanliness of the room at the time of assessment was acceptable.	None	None					
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?		loose paper is swept up but not dirt	There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
THERMAL COMFORT											
	Classroom is free of significant temperature shifts?		The room is always cold. I often have to wear thermal underwear and socks to be comfortable.	Temperature was acceptable at the time of assessment.	None	None					
	Temperature in my classroom is generally comfortable (72F-76F)?		The room is always cold. I often have to wear thermal underwear and socks to be comfortable.	Temperature was acceptable at the time of assessment.	None	None					
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The room is always cold. I often have to wear thermal underwear and socks to be comfortable.	Humidity was acceptable at the time of assessment.	None	None					
	Room is usually comfortable? (If no, please explain in the notes below.)		The room is always cold. I often have to wear thermal underwear and socks to be comfortable.	Elevated CO2. Adjust HVAC	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Physical Plant Operations					2
170	Temp	72.3	RH%	57.6	CO2	1186	Occupants:				
THERMAL COMFORT											
	Room is usually comfortable? (If no, please explain in the notes below.)		It is freezing!!!!	Temperature was acceptable at the time of assessment.	None	None					
	Temperature in my classroom is generally comfortable (72F-76F)?		It is freezing!!!!	Temperature was acceptable at the time of assessment.	None	None					
Walkthrough											
				Signs of water intrusion. Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based					2
				Dust and debris on ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based					2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
199	Temp	72.1	RH% 66.3	CO2 1466	Occupants:			
AIR CONDITIONING								
	Room is free of smell of mold or mildew?			Signs of water intrusion. Stained ceiling tiles. Odor detected.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1	
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
EXCESS MOISTURE IN CLASSROOMS								
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation at the time of assessment.	None	None		
GENERAL CLEANLINESS								
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor. Floor needs waxing.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?			right now the room has finally found a comfortable temperature. There have been times that the room is so cold or so hot that it has been impossible to teach. It varies from month to month.	Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)			right now the room has finally found a comfortable temperature. There have been times that the room is so cold or so hot that it has been impossible to teach. It varies from month to month.	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
199	Temp	72.1	RH%	66.3	CO2	1466	Occupants:				
	Temperature in my classroom is generally comfortable (72F-76F)?		right now the room has finally found a comfortable temperature. There have been times that the room is so cold or so hot that it has been impossible to teach. It varies from month to month.	Temperature was acceptable at the time of assessment.	None		None				
230	Temp	74.8	RH%	56.9	CO2	1711	Occupants:				
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None				
	ANIMALS IN THE CLASSROOM										
	You are informed about the potential allergies of your students?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based			3
	Activities and/or room conditions are modified to address student allergies?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based			3
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		There is a fowl musty/moldy smell.		Dust observed on supply/return registers at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2
	Floor is cleaned on a regular basis?		There is a fowl musty/moldy smell.		Floor was clean at the time of assessment.		None	None			
	Classroom is dusted/vacuumed thoroughly and regularly?		There is a fowl musty/moldy smell.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2
	Room is free of the use of scented cleaners and air fresheners?		There is a fowl musty/moldy smell.		No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.		None	None			
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?		There is a fowl musty/moldy smell.				None	None			
243	Temp	69.9	RH%	62.2	CO2	1435	Occupants:				
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?		Mold is a HUGE problem.		No odor detected at the time of assessment. No visible signs of mold identified.	None	None	None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
243	Temp	69.9	RH% 62.2	CO2 1435	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?	No pets in room---MOLD is a big problem.				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?	No pets in room---MOLD is a big problem.				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
Classroom is free of animals and pets?	No pets in room---MOLD is a big problem.			No pests observed at the time of assessment.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Many ceiling leaks, as well as down the walls, particularly in corner areas.			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
Windows, windowsills and window frames free of continuous condensation?	Many ceiling leaks, as well as down the walls, particularly in corner areas.			No condensation on windows at the time of assessment.	None	None	
Cold water pipes free of continuous condensation?	Many ceiling leaks, as well as down the walls, particularly in corner areas.			No condensation on pipes at the time of assessment.	None	None	
Indoor surfaces of exterior walls free of continuous condensation?	Many ceiling leaks, as well as down the walls, particularly in corner areas.			No condensation at the time of assessment.	None	None	
GENERAL CLEANLINESS							
Room is free of pests?	Ceilings and walls leak water (bldg is just OLD). Mold is a HUGE problem. Sometimews water actually leaks into and accumulates in the light fixtures in the ceiling. This seems quite dangerous! Everything is JUST old and worn out-storage cabionet doors			No pests observed at the time of assessment.	None	None	
Floor is cleaned on a regular basis?	Ceilings and walls leak water (bldg is just OLD). Mold is a HUGE problem. Sometimews water actually leaks into and accumulates in the light fixtures in the ceiling. This seems quite dangerous! Everything is JUST old and worn out-storage cabionet doors			Floor was clean at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
243	Temp	69.9	RH% 62.2	CO2 1435	Occupants:			
	Classroom is dusted/vacuumed thoroughly and regularly?	Ceilings and walls leak water (bldg is just OLD). Mold is a HUGE problem. Sometimes water actually leaks into and accumulates in the light fixtures in the ceiling. This seems quite dangerous! Everything is JUST old and worn out-storage cabinet doors			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Ceilings and walls leak water (bldg is just OLD). Mold is a HUGE problem. Sometimes water actually leaks into and accumulates in the light fixtures in the ceiling. This seems quite dangerous! Everything is JUST old and worn out-storage cabinet doors			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?	Ceilings and walls leak water (bldg is just OLD). Mold is a HUGE problem. Sometimes water actually leaks into and accumulates in the light fixtures in the ceiling. This seems quite dangerous! Everything is JUST old and worn out-storage cabinet doors			General cleanliness of the room at the time of assessment was not acceptable. Water damaged wall at exterior door. Door does not seal.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
THERMAL COMFORT								
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Humidity is quite high, and we operate 2 dehumidifiers in our uniform room---can not do the same in instrument storage areas, and this is a problem.			Exterior door not sealed	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity is quite high, and we operate 2 dehumidifiers in our uniform room---can not do the same in instrument storage areas, and this is a problem.			Humidity was slightly elevated at the time of assessment - Roof Leak	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
	Classroom is free of significant temperature shifts?	Humidity is quite high, and we operate 2 dehumidifiers in our uniform room---can not do the same in instrument storage areas, and this is a problem.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	Humidity is quite high, and we operate 2 dehumidifiers in our uniform room---can not do the same in instrument storage areas, and this is a problem.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
265	Temp	73.0	RH% 56.3	CO2 1274	Occupants:		
AIR CONDITIONING							
Room is free of smell of kitchen/food?				Across the hall from kitchen.	None	None	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?				No sink in room.	None	None	
292	Temp	76.7	RH% 47.2	CO2 640	Occupants:		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Two minor discolorations of ceiling tiles.	Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
292	Temp	76.7	RH% 47.2	CO2 640	Occupants:		
Walkthrough							
				Signs of water intrusion. Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
603D	Temp	72.5	RH% 65.7	CO2 888	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			The room is freezing cold!!!!!!!!!! The sliding folding panel in the middle of the room is filled with mold/mildew and it has an odor.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?			The room is freezing cold!!!!!!!!!! The sliding folding panel in the middle of the room is filled with mold/mildew and it has an odor.	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?			The room is freezing cold!!!!!!!!!! The sliding folding panel in the middle of the room is filled with mold/mildew and it has an odor.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			Room temperature cannot be controlled... usually too cold.	Adjust HVAC. Elevated humidity.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Temperature in my classroom is generally comfortable (72F-76F)?			Room temperature cannot be controlled... usually too cold.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
603D	Temp	72.5	RH% 65.7	CO2 888	Occupants:		
Classroom is free of significant temperature shifts?	Room temperature cannot be controlled... usually too cold.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	1		
604	Temp	75.4	RH% 57.7	CO2 760	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?		No odor detected at the time of assessment.	None	None			
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1		
Windows, windowsills and window frames free of continuous condensation?		No condensation on windows at the time of assessment.	None	None			
GENERAL CLEANLINESS							
Room is free of pests?		No pests observed at the time of assessment.	None	None			
Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None	None			
Classrooms general appearance is clean and acceptable?		General cleanliness of the room at the time of assessment was acceptable.	None	None			
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2		
Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2		
THERMAL COMFORT							
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Humidity was acceptable at the time of assessment.	None	None			
Classroom is free of significant temperature shifts?		Temperature was slightly elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

965C

Temp

80

RH%

43.1

CO2

1977

Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

floor is never swept or mopped. only large debris is picked up on a daily basis. Shelves, blinds, and equipment are all coated with dirt and dust.

Dust observed on supply/return registers at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

floor is never swept or mopped. only large debris is picked up on a daily basis. Shelves, blinds, and equipment are all coated with dirt and dust.

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classrooms general appearance is clean and acceptable?

floor is never swept or mopped. only large debris is picked up on a daily basis. Shelves, blinds, and equipment are all coated with dirt and dust.

General cleanliness of the room at the time of assessment was acceptable.

None

None

Floor is cleaned on a regular basis?

floor is never swept or mopped. only large debris is picked up on a daily basis. Shelves, blinds, and equipment are all coated with dirt and dust.

Dust and dirt accumulation on floor.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Walkthrough

Dust and debris on ceiling tiles.

Facilities serviceperson to replace soiled ceiling tiles.

Site Based

2