

# Tools for Schools Phase II - Indoor Air Quality

## Follow-up Action Plan for Physical Plant Operations



Coral Glades High

79.5 46.2 437

Principal: Mr. David Jones

Walkthrough Date: 4/29/2005

Temp RH Co2  
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
126A	2	Physical Plant Operations	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.
153A	2	Physical Plant Operations	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.
190	2	Physical Plant Operations	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.