

Tools for Schools - Indoor Air Quality

Follow-up Action Plan for Site



Coral Springs High

77.5 62% 341

Principal: Ms. Anne Lynch

Walkthrough Date: 4/26/2004

Temp RH Co2
Outside Measurements

Assignment Member: Aston Henry

Room	Priority	Responsible	Assessment Comments	Recommended Corrective Action
304	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
520	1	Site	Drain traps and sinks need to be cleaned.	Custodial staff to clean sinks and traps.
520	2	Site	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
520	2	Site	Return air grill is functioning properly. Dust and debris on return air grill.	Custodial staff should clean and sanitize the return registers in this classroom.
525/527	2	Site	Missing ceiling tile and broken light diffuser.	Custodial staff to repair as appropriate.
525/527	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
534	3	Site	Dust accumulation was observed on environmental surfaces. Stones, shells and other items are all over the countertops.	Custodial staff should thoroughly clean all environmental surfaces within classroom. Remove stones, shells, etc. from countertops.
538	1	Site	Hamster in room.	Remove hamster.
538	2	Site	No leaks but one stained ceiling tile.	Install new ceiling tiles.
610	2	Site	Dust and debris was observed on the air supply at the time of the assessment.	Custodial staff should clean and sanitize the air supply in this classroom.
708	3	Site		Site based administration will provide information to site based staff.
708	3	Site		Contact EPA website www.epa.gov/iaq
708	3	Site		Site based administration will provide information to site based staff.
805	3	Site		Site based administration will provide information to site based staff.
805	3	Site		Site based administration will provide information to site based staff.
805	3	Site		Site based administration will provide information to site based staff.
805	3	Site		Site based administration will provide information to site based staff.

Room	Priority	Responsible	Assessment Comments	Recommended Corrective Action
805	3	Site		Site based administration will provide information to site based staff.
805	3	Site		Contact EPA website www.epa.gov/iaq
805	3	Site		Site based administration will provide information to site based staff.
933	2	Site	Minor dust and debris was observed on the air supply at the time of the assessment.	Custodial staff should clean and sanitize the air supply in this classroom.
933	3	Site		Site based administration will provide information to site based staff.
933	3	Site		Site based administration will provide information to site based staff.