

DEERFIELD BEACH HIGH

Walkthrough Date: 04/18/2007 Temp RH CO2

Outdoor Parameters: 77.7 44.4 567

Room	Section	Question	Answer	Recommendation	Responsible
123	Inside Parameters:	Temp	RH	CO2	
		70.8	49.2	1525	
	GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	Dust build up on ceiling tiles at air supply grills. Air supply grills blocked with paper.	Facilities serviceperson to thoroughly clean ceiling tiles at air supply grills and remove paper.	Site
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of the assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was low at the time of the assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
Room	Section	Question	Answer	Recommendation	Responsible
133	Inside Parameters:	Temp	RH	CO2	
		71.2	60.4	1863	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris	Dust build up on ceiling tiles at air supply grills.	Facilities serviceperson to thoroughly clean ceiling tiles at air supply grills.	Site

accumulation?

THERMAL COMFORT
THERMAL COMFORT
THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F- 76F)?
Classroom is free of significant temperature shifts?
Room is usually comfortable? (If no, please explain in the notes below.)

Temperature was acceptable at the time of assessment.
Temperature was acceptable at the time of assessment.
Temperature was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
135	Inside Parameters:	Temp 71.9	RH 48.5	CO2 1322	

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust build up on ceiling tiles at air supply grills.

Facilities serviceperson to thoroughly clean ceiling tiles at air supply grills.

Site

GENERAL CLEANLINESS

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F- 76F)?

Temperature was acceptable at the time of assessment.

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Portable space heater is being used.

Site based administration is encouraged to advise staff regarding the use of space heaters. Facilities serviceperson to adjust thermostat to increase temperature as appropriate.

Site

Room	Section	Question	Answer	Recommendation	Responsible
136	Inside Parameters:	Temp 68.3	RH 53.1	CO2 1325	

GENERAL CLEANLINESS

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time

Site based administration should address general cleanliness with facility serviceperson staff.

Site

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust build up on ceiling tiles at air supply grills.	Facilities serviceperson to thoroughly clean ceiling tiles at air supply grills.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
THERMAL COMFORT	Miscellaneous	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site

Room	Section	Question	Answer	Recommendation	Responsible
148	Inside Parameters:	Temp	RH	CO2	
		72.5	53.6	1528	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Minor staining on carpet.	Facilities serviceperson to thoroughly clean and sanitize.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	A/C turned off during assessment.	Encourage staff to keep A/C units on.	Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site

Room	Section	Question	Answer	Recommendation	Responsible
180	Inside Parameters:	Temp	RH	CO2	

		72.6	49.4	2032	
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust build up on ceiling tiles at air supply grills.	Facilities serviceperson to thoroughly clean ceiling tiles at air supply grills.	Site	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Occupants advised room is either too hot or too cold. Temperature was acceptable at the time of the assessment.			
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	CO2 level was slightly elevated at the time of the assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO	
AIR CONDITIONING	Air is flowing without obstruction?	Return vents closed at the time of assessment.	Facilities serviceperson to open return vents.	Site	
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.			

Room	Section	Question	Answer	Recommendation	Responsible
182	Inside Parameters:	Temp 71.4	RH 51.9	CO2 2109	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.			
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.			
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site	
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.			
GENERAL CLEANLINESS	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..			
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.			
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.			
EXCESS MOISTURE	Ceiling tiles or walls free of leaks	Dust and debris on ceiling tiles.	Facilities serviceperson to replace ceiling tiles.	Site	

IN CLASSROOMS	and/or discoloration (discoloration may indicate periodic leaks)?			
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	CO2 level was slightly elevated at the time of the assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
AIR CONDITIONING	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
184	Inside Parameters:	Temp 73.8	RH 49.2	CO2 1642	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
	AIR	Air is flowing without obstruction?	Air flowing without obstruction at the		

CONDITIONING		time of assessments.			
Room	Section	Question	Answer	Recommendation	Responsible
195	Inside Parameters:	Temp 67.3	RH 60.7	CO2 1075	
	GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean as appropriate.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Site based facilities serviceperson should monitor this room.	Site
Room	Section	Question	Answer	Recommendation	Responsible

212	Inside Parameters:	Temp 65.7	RH 56.5	CO2 1697	
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
221	Inside Parameters:	Temp 68.6	RH 51.3	CO2 1613	

	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	GENERAL	Floor is cleaned on a regular basis?	Floor was clean at the time of		

CLEANLINESS

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	assessment. This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	No sink in room.		
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No sink in room.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site

Room	Section	Question	Answer	Recommendation	Responsible
223A	Inside Parameters:	Temp	RH	CO2	
		70.4	52.6	1111	

GENERAL Classrooms general appearance is General cleanliness of the room at the

CLEANLINESS clean and acceptable?
 GENERAL Classroom is dusted/vacuumed
 CLEANLINESS thoroughly and regularly?
 GENERAL Room is free of pests?
 CLEANLINESS
 GENERAL Floor is cleaned on a regular basis?
 CLEANLINESS

time of assessment was acceptable.
 There does not appear to be a dusting
 issue within this room.
 No pests observed at the time of
 assessment.
 Floor was clean at the time of
 assessment.

Room	Section	Question	Answer	Recommendation	Responsible
225	Inside Parameters:	Temp	RH	CO2	
		71.8	53	1358	

GENERAL Room is free of the use of scented
 CLEANLINESS cleaners and air fresheners?
 No scented cleaners air fresheners or
 non-approved chemicals found at the
 time of assessment.

ANIMALS IN THE You are informed about the potential
 CLASSROOM allergies of your students?
 This is a general issue requiring
 approved communication among all
 stakeholders.
 Site based administration is encouraged to communicate all Site
 known student allergies to the appropriate personnel in
 order to modify classroom activities/conditions when
 necessary.

ANIMALS IN THE Activities and/or room conditions are
 CLASSROOM modified to address student allergies?
 This is a general issue requiring
 approved communication among all
 stakeholders.
 Site based administration is encouraged to communicate all Site
 known student allergies to the appropriate personnel in
 order to modify classroom activities/conditions when
 necessary.

THERMAL Temperature in my classroom is
 COMFORT generally comfortable (72F- 76F)?
 Temperature was acceptable at the time
 of assessment.
 THERMAL Classroom is free of significant
 COMFORT temperature shifts?
 Temperature was acceptable at the time
 of assessment.
 THERMAL Room is usually comfortable? (If no,
 COMFORT please explain in the notes below.)
 Environmental parameters were within
 acceptable range at the time of
 assessment..

Room	Section	Question	Answer	Recommendation	Responsible
225A	Inside Parameters:	Temp	RH	CO2	
		72.6	50	1295	

ANIMALS IN THE You are informed about the potential
 CLASSROOM allergies of your students?
 This is a general issue requiring
 approved communication among all
 stakeholders.
 Site based administration is encouraged to communicate all Site
 known student allergies to the appropriate personnel in
 order to modify classroom activities/conditions when
 necessary.

THERMAL Classroom is free of significant
 COMFORT temperature shifts?
 Temperature was acceptable at the time
 of assessment.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? Exhaust fan is functioning properly.

Room	Section	Question	Answer	Recommendation	Responsible
233	Inside Parameters:	Temp 63.4	RH 62.1	CO2 1355	

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all Site known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all Site known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? No leaks or signs of water intrusion identified.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F- 76F)? Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site

Room	Section	Question	Answer	Recommendation	Responsible
234	Inside Parameters:	Temp 67.1	RH 60	CO2 1500	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Floor was clean at the time of assessment.

AIR Air flowing from air supply? Air supply/return ventilation is

CONDITIONING
 AIR CONDITIONING
 LOCAL EXHAUST FANS

Air is flowing without obstruction?
 Other exhaust fans that may exist in the classroom are functioning properly?

functioning.
 Air flowing without obstruction at the time of assessments.
 Exhaust fan is functioning properly.

Room	Section	Question	Answer	Recommendation	Responsible
235	Inside Parameters:	Temp 69.3	RH 61.5	CO2 1433	

GENERAL CLEANLINESS
 Classroom is dusted/vacuumed thoroughly and regularly?
 There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS
 Air supply/return registers are cleaned regularly and free of dust and debris accumulation?
 No dust observed on supply/return registers at the time of assessment.

GENERAL CLEANLINESS
 Floor is cleaned on a regular basis?
 Floor was clean at the time of assessment.

THERMAL COMFORT
 Temperature in my classroom is generally comfortable (72F- 76F)?
 Temperature was low at the time of the assessment.
 Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
 Site

THERMAL COMFORT
 Classroom is free of significant temperature shifts?
 Temperature was low at the time of assessment.
 Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
 Site

THERMAL COMFORT
 Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)
 Humidity was slightly elevated at the time of assessment.
 Site based facilities serviceperson should monitor this room. Site

THERMAL COMFORT
 Room is usually comfortable? (If no, please explain in the notes below.)
 Environmental parameters were not within acceptable range at the time of assessment.
 Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
 Site

AIR CONDITIONING
 LOCAL EXHAUST FANS

Air flowing from air supply?
 Other exhaust fans that may exist in

Air supply/return ventilation is functioning.
 Exhaust fan is functioning properly.

FANS the classroom are functioning properly?

Room	Section	Question	Answer	Recommendation	Responsible
236	Inside Parameters:	Temp 66.5	RH 63	CO2 1267	
	GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of the assessment.		Site
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment.		PPO

Room	Section	Question	Answer	Recommendation	Responsible
242	Inside Parameters:	Temp 67.4	RH 62.5	CO2 1185	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	GENERAL	Floor is cleaned on a regular basis?	Floor was clean at the time of		

CLEANLINESS		assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	It appears as though water is poured down the floor drain at least once a week.		
DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.		
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of the assessment.		Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		PPO
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.		
AIR CONDITIONING	Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.		

AIR
CONDITIONINGRoom is free of smell of mold or
mildew?No microbial growth identified. No
odor identified at the time of
assessment.

Room	Section	Question	Answer	Recommendation	Responsible
242B	Inside Parameters:	Temp	RH	CO2	

ANIMALS IN THE
CLASSROOMActivities and/or room conditions are
modified to address student allergies?This is a general issue requiring
approved communication among all
stakeholders.Site based administration is encouraged to communicate all
known student allergies to the appropriate personnel in
order to modify classroom activities/conditions when
necessary.

Site

Room	Section	Question	Answer	Recommendation	Responsible
252	Inside Parameters:	Temp	RH	CO2	
		67.3	64.5	1048	

GENERAL
CLEANLINESSClassroom is dusted/vacuumed
thoroughly and regularly?There does not appear to be a dusting
issue within this room.GENERAL
CLEANLINESSAir supply/return registers are cleaned
regularly and free of dust and debris
accumulation?No dust observed on supply/return
registers at the time of assessment.ANIMALS IN THE
CLASSROOMYou are informed about the potential
allergies of your students?This is a general issue requiring
approved communication among all
stakeholders.Site based administration is encouraged to communicate all
known student allergies to the appropriate personnel in
order to modify classroom activities/conditions when
necessary.

Site

EXCESS MOISTURE
IN CLASSROOMSCeiling tiles or walls free of leaks
and/or discoloration (discoloration
may indicate periodic leaks)?Ceiling tiles damaged or stained and
require cut.Physical Plant Operations to replace ceiling tiles as
appropriate.

PPO

THERMAL
COMFORTTemperature in my classroom is
generally comfortable (72F- 76F)?Temperature was low at the time of the
assessment.Site based administration to encourage facility
serviceperson staff to adjust the thermostat. Continue to
monitor condition and initiate a work order for Physical
Plant Operations to evaluate the HVAC system if
temperature does not improve.

Site

THERMAL
COMFORTClassroom is free of significant
temperature shifts?Temperature was low at the time of
assessment.Site based administration to encourage facility
serviceperson staff to adjust the thermostat. Continue to
monitor condition and initiate a work order for Physical
Plant Operations to evaluate the HVAC system if
temperature does not improve.

Site

THERMAL
COMFORTHumidity is generally acceptable?
(Typically too high if higher than
60% relative humidity [RH] or tooHumidity was slightly elevated at the
time of assessment.

Site based facilities serviceperson should monitor this room. Site

THERMAL COMFORT	low if lower than 30% RH.) Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Site based facilities serviceperson should monitor this room. Site
AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.	
AIR CONDITIONING	Room is free of smell of mold or mildew?	Odor detected and microbial growth identified on books.	Remove books and thoroughly clean classroom. PPO
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.	
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.	

Room	Section	Question	Answer	Recommendation	Responsible
260	Inside Parameters:	Temp	RH	CO2	
		70.9	52	1322	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.	
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site
THERMAL	Room is usually comfortable? (If no,	Environmental parameters were not	Site based facilities serviceperson should monitor this room. Site

COMFORT please explain in the notes below.) within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
311	Inside Parameters:	Temp 72.2	RH 59.4	CO2 984	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
506	Inside Parameters:	Temp 69.9	RH 55.5	CO2 462	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site

THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Site based facilities serviceperson should monitor this room.	Site
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
507	Inside Parameters:	Temp	RH	CO2	
		71.9	55.1	911	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
513	Inside Parameters:	Temp	RH	CO2	
		73	56.1	995	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Floor was clean at the time of assessment.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? Exhaust fan is functioning properly.

Room	Section	Question	Answer	Recommendation	Responsible
519	Inside Parameters:	Temp	RH	CO2	
		71.5	56.1	703	

GENERAL CLEANLINESS Classrooms general appearance is clean and acceptable? General cleanliness of the room at the time of assessment was not acceptable. Site based administration should address general cleanliness with facility serviceperson staff.

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize. Site

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F- 76F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

AIR CONDITIONING Air flowing from air supply? Air supply/return ventilation is functioning.

AIR CONDITIONING Air is flowing without obstruction? Air flowing without obstruction at the time of assessments.

LOCAL EXHAUST FANS Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) It appears that the ventilation system is adequate based on room activities.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? Exhaust fan is functioning properly.

Room	Section	Question	Answer	Recommendation	Responsible

911	Inside Parameters:	Temp 65.9	RH 57	CO2 718	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site	
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site	
GENERAL CLEANLINESS	Room is free of pests?	Pests observed at the time of assessment.	Physical Plant Operation to initiate work order to evaluate pest issue within location and take appropriate action.	PPO	
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.			
DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.	Site	
DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.	Site	
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	PPO	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site	
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site	
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Site based facilities serviceperson should monitor this room.	Site	

Room	Section	Question	Answer	Recommendation	Responsible
912	Inside Parameters:	Temp 69.5	RH 58.5	CO2 663	
GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.	Site
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Site based facilities serviceperson should monitor this room.	Site

Room	Section	Question	Answer	Recommendation	Responsible
914	Inside Parameters:	Temp 69.8	RH 50.4	CO2 688	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Two rusted supply registers and one missing.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	Dust build up on walls.	Facilities serviceperson to clean as appropriate.	Site
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Dust and debris on ceiling tiles.	Facilities serviceperson to replace ceiling tiles.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Site based facilities serviceperson should monitor this room.	Site
AIR CONDITIONING	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
915	Inside Parameters:	Temp	RH	CO2	
		69.7	54.5	478	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
---------------------	--	---	--	--

GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

