

Aston A. Henry, Supervisor  
Risk Management Department

Telephone: 754 321-1900  
Fax: 754 321-1917

May 2, 2012

**Signature on File**

TO: Michelle Kefford, Principal  
**Flanagan High School**

FROM: Richard Rosa, Project Manager  
Facilities and Construction Management

SUBJECT: Indoor Air Quality (IAQ) Assessment

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed
_____	
_____	

On November 17, 2011, I conducted an assessment at **Flanagan High School**. Attached are findings and recommendations for further assessment, remediation, or corrective actions needed.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

*Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.*

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-1907.

cc: Area Superintendent  
Area Directors  
Shelley Meloni, Executive Director, Facilities and Construction Management  
Mark Dorsett, Acting Director, Physical Plant Operations Division, Maintenance  
Sonja Coley, Project Manager III, Facilities and Construction Management  
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division  
Aston Henry, Supervisor, Risk Management  
Broward Teachers Union  
Federation of Public Employees

RR/tc  
Enc.

# IAQ Assessment

Location Number   
 Evaluation Requested   
 Evaluation Date

Flanagan High

Time of Day

Outdoor Conditions      Temperature       Relative Humidity       Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="132"/>	<input type="text" value="74.6"/>	<input type="text" value="72 - 78"/>	<input type="text" value="49.5"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="774"/>	<input type="text" value="Max 700 &gt; Ambient"/>	<input type="text"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="40 square feet"/>		
Flooring	<input type="text" value="Carpet"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>
HVAC Return Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>
Ceiling at Supply Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>
Surfaces in Room	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>

**Observations**

**Findings**

- Dust build up on HVAC supply and return grills and on ceiling at supply grills
- Dust build up on elevated horizontal surfaces
- Incorrect filter spacers in FISH 131 (AHU)
- Visible staining and dust build up on wall entering vault area

**Site Based Maintenance:**

- Clean HVAC supply and return grills with Wexcide disinfectant solution and wipe down ceiling at supply grills.
- Wipe down wall entering vault area with Wexcide due to previous leak above ceiling. - Clean dust build up from elevated horizontal surfaces.
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

**Physical Plant Operations:**

- Install correct filter spacers in FISH 131 AHU.

- NOTE: Work order EQ02278 generated 1-24-12