

Tools for Schools Phase II - Indoor Air Quality

Follow-up Action Plan for Site Based



Hallandale High

86.2 61.6 565

Principal: Ms. Rosemary Chambers

Walkthrough Date: 5/19/2005

Temp RH Co2
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
201	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
201	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
201	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
320	2	Site Based	Missing ceiling tile.	Facilities serviceperson to replace ceiling tiles.
417	2	Site Based	Supply vents obstructed by accoustical panels.	Facilities serviceperson to clear supply vents.
417	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
417	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
417	2	Site Based	Odor detected at the time of assessment. Sweaty weight room	Facilities serviceperson to open supply vents.
417	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
424	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
424	2	Site Based	Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.
424	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
526	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Response	Recommendation
526	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
544	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
544	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
601B	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
608	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
608	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
608	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
608	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
620	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
620	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
804	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
804	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.