

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

FISH	Question	Answer	Recommendation	RP
111	Temp 76.1	RH 48.8	CO2 901	
	Classroom is free of animals and pets?	No animals identified at the time of assessment.		
	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	Room is free of pests?	No pests observed at the time of assessment.		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..		
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
148	Temp 72.8	RH 57	CO2 1070	

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Classroom is free of animals and pets? Water poured down floor drains once per week (approx. 1 quart of water). Water run in sinks at least once per week (about 2 cups of water).	Fish tank in room. It appears as though water is poured down the floor drain at least once a week. It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return register at the time of assessment.  Two broken supply/return grills.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.  Physical Plant Operations to evaluate and repair as appropriate.	Site  PPO
	Room is free of pests? Floor is cleaned on a regular basis?	No pests observed at the time of assessment. Floor was clean at the time of assessment.		

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

FISH	Question	Answer	Recommendation	RP
	Temperature in my classroom is generally comfortable (72F-78F)? Classroom is free of significant temperature shifts? Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment. Temperature was acceptable at the time of assessment. Environmental parameters were within acceptable range at the time of assessment.. Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO

203	Temp 0	RH 0	CO2 0	
-----	-----------	---------	----------	--

You are informed about the potential allergies of your students?	Air Handler Room
Activities and/or room conditions are modified to address student allergies?	Air Handler Room
Classroom is dusted/vacuumed thoroughly and regularly?	Air Handler Room
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Air Handler Room
Room is free of pests?	Air Handler Room
Floor is cleaned on a regular basis?	Air Handler Room
Temperature in my classroom is generally comfortable (72F-78F)?	Air Handler Room
Classroom is free of significant temperature shifts?	Air Handler Room
Room is usually comfortable? (If no, please explain in the notes below.)	Air Handler Room

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

FISH	Question	Answer	Recommendation	RP
231	Temp 72.2	RH 55.5	CO2 1177	
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
	Room is free of pests?	No pests observed at the time of assessment.		
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
301	Temp	RH	CO2	

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	77.1	48	1021	
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	See previous recommendation	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was elevated at the time of assessment.	See previous recommendation	
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	See previous recommendation	
303	Temp 73.3	RH 55.4	CO2 1011	

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.		

307	Temp 71.9	RH 59	CO2 1031	
-----	--------------	----------	-------------	--

	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
	Room is free of pests?	No pests observed at the time of assessment.		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust system/ventilation in room. Identified in error.		

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

FISH	Question	Answer	Recommendation	RP
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		Site
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
		Dust observed on supply and return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
		Signs of water intrusion. Leak under sink.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
504	Temp 72	RH 55	CO2 731	
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
		Dust observed on supply and return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
		Damaged ceiling tiles.	Facilities serviceperson to remove and replace ceiling tiles.	Site
601	Temp	RH	CO2	

RH - Relative Humidity  
RP - Responsible Party

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	73.2	55.6	832	
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
		Pests observed at the time of the assessment. Ants on ceiling.	Physical Plant Operation to initiate work order to evaluate pest issue within location and take appropriate action.	PPO
		Minor signs of visible microbial growth on ceiling.	Facilities serviceperson to wipe down room with District approved germicidal cleaner. Remove and replace ceiling tiles as necessary.	Site
601A	Temp 0	RH 0	CO2 0	

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

FISH	Question	Answer	Recommendation	RP
	You are informed about the potential allergies of your students?	Storage Room		
	Activities and/or room conditions are modified to address student allergies?	Storage Room		
	Classroom is free of animals and pets?	Storage Room		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Storage Room		
	Room is free of pests?	Storage Room		
	Temperature in my classroom is generally comfortable (72F-78F)?	Storage Room		
703	Temp 72	RH 57.6	CO2 968	
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.  Dust observed on supply and return register at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.  Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site  Site
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
707	Temp 70.7	RH 58.6	CO2 768	
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

FISH	Question	Answer	Recommendation	RP
		Temperature was low at the time of the assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
900	Temp 73.8	RH 59	CO2 736	
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Room is free of smell of mold or mildew?	Musty odor emanating from carpet.	Physical Plant Operations to evaluate carpet and make recommendations for cleaning.	PPO
	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

FISH	Question	Answer	Recommendation	RP
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	Room is free of pests?	No pests observed at the time of assessment.		
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust system/ventilation in room. Identified in error.		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	No exhaust system/ventilation in room. Identified in error.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

906	Temp 74.5	RH 54.3	CO2 421	
-----	--------------	------------	------------	--

You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
--	--	--	------

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.  Cabinet under sink is damaged.	Site based administration should address general cleanliness with facility serviceperson staff.  Physical Plant Operations to evaluate and repair as appropriate.	Site  PPO
		Dust observed on supply and return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site

910	Temp 71	RH 65.4	CO2 608	
-----	------------	------------	------------	--

	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of the assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	Classroom is free of significant temperature shifts?	Temperature was low at the time of the assessment.	See previous recommendation	

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

FISH	Question	Answer	Recommendation	RP
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of the assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment.. Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	See previous recommendation Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site
929	Temp 76	RH 55.8	CO2 1176	
	Temperature in my classroom is generally comfortable (72F-78F)? Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment. Temperature was acceptable at the time of assessment. Dust build up on window screens.	Facilities serviceperson to thoroughly clean and sanitize.	Site
943	Temp 74	RH 61.3	CO2 883	
	Temperature in my classroom is generally comfortable (72F-78F)? Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment. Humidity was slightly elevated at the time of the assessment. Environmental parameters were within acceptable range at the time of assessment.. Dust build up on windows.	Physical Plant Operations to evaluate and repair as appropriate. See previous recommendation Facilities serviceperson to thoroughly clean and sanitize.	PPO  Site
951	Temp	RH	CO2	

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	74.9	58.5	923	
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	Locker room and showers cleaned regularly and properly?	Issues not applicable. Room is not a locker room.		
	Soiled clothes and towels are removed regularly?	Issues not applicable. Room is not a locker room.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
952	Temp 74.4	RH 61.8	CO2 1035	
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site

**Summary**

**Hollywood Hills High  
TfS IAQ Walkthrough  
5-1-2008**

Temp 77.4 RH 55.1 CO2 463

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
		Humidity was slightly elevated at the time of the assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
953	Temp 74	RH 62.6	CO2 999	
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
		Humidity was slightly elevated at the time of the assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	See previous recommendation	
		Dust impaction on ceiling tiles above teachers desk.	Facilities serviceperson to thoroughly clean or remove and replace ceiling tiles.	Site