

# Northeast High

## IAQ Walkthrough 5/11/2005

1241

Outside Temp  RH%  CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
001	Temp <input type="text" value="76.5"/> RH% <input type="text" value="58.3"/> CO2 <input type="text" value="903"/>	Occupants: <input type="text"/>			
	<b>EXCESS MOISTURE IN CLASSROOMS</b>				
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	<b>THERMAL COMFORT</b>				
	Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was elevated at the time of assessment.	See other recommendation		
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was elevated at the time of assessment.	See other recommendation		
	Walkthrough	Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
002	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
	<b>ANIMALS IN THE CLASSROOM</b>				
	Activities and/or room conditions are modified to address student allergies?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>GENERAL CLEANLINESS</b>				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
002	Temp	<input type="text"/>	RH%	<input type="text"/>	CO2	<input type="text"/>	Occupants:	<input type="text"/>			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None						
	Walkthrough										
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based					2
004	Temp	<input type="text" value="74.5"/>	RH%	<input type="text" value="60.1"/>	CO2	<input type="text" value="1478"/>	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			This is for 4N	There does not appear to be a dusting issue within this room.	None					
	Room is free of pests?			This is for 4N	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations				1
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?			It is normally about 65 degrees, even when it is 95 outside. Sometimes the air shuts off and it gets very humid and stuffy.	Temperature was acceptable at the time of assessment.	None					
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			It is normally about 65 degrees, even when it is 95 outside. Sometimes the air shuts off and it gets very humid and stuffy.	Humidity was acceptable at the time of assessment.	None					
	Room is usually comfortable? (If no, please explain in the notes below.)			It is normally about 65 degrees, even when it is 95 outside. Sometimes the air shuts off and it gets very humid and stuffy.	CO2 level was slightly elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations				2
	Temperature in my classroom is generally comfortable (72F-76F)?			It is normally about 65 degrees, even when it is 95 outside. Sometimes the air shuts off and it gets very humid and stuffy.	Temperature was acceptable at the time of assessment.	None					
	Walkthrough										
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based					2
005	Temp	<input type="text" value="72.2"/>	RH%	<input type="text" value="53.8"/>	CO2	<input type="text" value="1852"/>	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No major pests are present, but there are bugs from time to time. Some bugs have appeared in my desk. And I do not store food or eating utensils in my desk/classroom!! YUK.	No dust observed on supply/return registers at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
005	Temp	72.2	RH%	53.8	CO2	1852	Occupants:				
	Classroom is dusted/vacuumed thoroughly and regularly?		No major pests are present, but there are bugs from time to time. Some bugs have appeared in my desk. And I do not store food or eating utensils in my desk/classroom!! YUK.	There does not appear to be a dusting issue within this room.	None						
	Walkthrough			Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based					2
015	Temp	77.7	RH%	58.5	CO2	1233	Occupants:	2			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?		Mildew and mold on the shelves and baseboards.	No odor detected at the time of assessment.	None						
	ANIMALS IN THE CLASSROOM										
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None						
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None						
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None						
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		This room is way too cold. If the air is raised in this classroom, then the surrounding rooms have no air. The humidity is very high. It is probably close to 65 degrees or colder in here.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		This room is way too cold. If the air is raised in this classroom, then the surrounding rooms have no air. The humidity is very high. It is probably close to 65 degrees or colder in here.	Humidity was acceptable at the time of assessment.	None						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
015	Temp	77.7	RH%	58.5	CO2	1233	Occupants:	2			
	Room is usually comfortable? (If no, please explain in the notes below.)	This room is way too cold. If the air is raised in this classroom, then the surrounding rooms have no air. The humidity is very high. It is probably close to 65 degrees or colder in here.			Environmental parameters were within acceptable range at the time of assessment..	None					
	Temperature in my classroom is generally comfortable (72F-76F)?	This room is way too cold. If the air is raised in this classroom, then the surrounding rooms have no air. The humidity is very high. It is probably close to 65 degrees or colder in here.			Temperature was elevated at the time of assessment.	See other recommendation.					
016	Temp	76	RH%	61.8	CO2	1229	Occupants:	0			
	<b>AIR CONDITIONING</b>										
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None					
	Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None					
	<b>Walkthrough</b>										
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
025	Temp	73.8	RH%	64.6	CO2	1270	Occupants:	15			
	<b>AIR CONDITIONING</b>										
	Room is free of smell of mold or mildew?	(26N) Room often has a moldy smell when air is off.			Odor detected and microbial growth identified. Visible growth on walls.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				1
	<b>ANIMALS IN THE CLASSROOM</b>										
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	<b>DRAIN TRAPS IN THE CLASSROOM</b>										
	Water poured down floor drains once per week (approx. 1 quart of water).				No issues identified at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
025	Temp	73.8	RH% 64.6	CO2 1270	Occupants: 15			
	Water run in sinks at least once per week (about 2 cups of water).			No issues identified at the time of assessment.	None			
	<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			(26N) Floor was generally not cleaned or swept, but now there is a different custodian, she expressed that it will be cleaned now.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			(26N) Floor was generally not cleaned or swept, but now there is a different custodian, she expressed that it will be cleaned now.	There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			(26N) Floor was generally not cleaned or swept, but now there is a different custodian, she expressed that it will be cleaned now.	Floor was clean at the time of assessment.	None		
	<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?			(26N) Extremely cold. By 11:00am temperature is down to 65 degrees and continues to fall by end of school. Appears that it is off when we come in in the morning, but is turned on early. Once on, it does not shut off to regulate the temperature.	Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			(26N) Extremely cold. By 11:00am temperature is down to 65 degrees and continues to fall by end of school. Appears that it is off when we come in in the morning, but is turned on early. Once on, it does not shut off to regulate the temperature.	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)			(26N) Extremely cold. By 11:00am temperature is down to 65 degrees and continues to fall by end of school. Appears that it is off when we come in in the morning, but is turned on early. Once on, it does not shut off to regulate the temperature.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			(26N) Extremely cold. By 11:00am temperature is down to 65 degrees and continues to fall by end of school. Appears that it is off when we come in in the morning, but is turned on early. Once on, it does not shut off to regulate the temperature.	Temperature was acceptable at the time of assessment.	None		

101B

Temp 73.4 RH% 54 CO2 1135 Occupants: 1

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Signs of water intrusion along wall with window.

Physical Plant Operations to evaluate for leaks and repair as appropriate.

Physical Plant Operations

1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<b>101B</b>	Temp	73.4	RH% 54	CO2 1135	Occupants:	1	
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		Office is usually freezing.		Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Office is usually freezing.		Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Office is usually freezing.		Temperature was acceptable at the time of assessment.	None	
<b>101J</b>	Temp	72.9	RH% 56.8	CO2 1121	Occupants:	2	
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?		Ater heavy rains there is a mildew order		No odor detected at the time of assessment. Check for roof leaks.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations 1
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Air is usually extremely cold		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?		Air is usually extremely cold		There does not appear to be a dusting issue within this room.	None	
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?		Bathroom exhaust fan needs improvement.		No issues identified at the time of assessment.	None	
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		Too cold		Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Too cold		Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Too cold		Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
102	Temp	73.3	RH% 54.6	CO2 1203	Occupants:		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?		the bathroom located in the clinic does not have an exhaust fan.	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		Most of the time we are freezing. Air Conditioner has to be turned off for a short while just so we can warm up., the office temperature is very inconsistent. Fluctuates from very warm (and stuffy) to very, very cold.	Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Most of the time we are freezing. Air Conditioner has to be turned off for a short while just so we can warm up., the office temperature is very inconsistent. Fluctuates from very warm (and stuffy) to very, very cold.	Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Most of the time we are freezing. Air Conditioner has to be turned off for a short while just so we can warm up., the office temperature is very inconsistent. Fluctuates from very warm (and stuffy) to very, very cold.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Most of the time we are freezing. Air Conditioner has to be turned off for a short while just so we can warm up., the office temperature is very inconsistent. Fluctuates from very warm (and stuffy) to very, very cold.	Temperature was acceptable at the time of assessment.	None		

102D	Temp	73.3	RH% 54.6	CO2 1203	Occupants:		
------	------	------	----------	----------	------------	--	--

**THERMAL COMFORT**

	Classroom is free of significant temperature shifts?		Temperature shifts from extremely cold to hot - it is not usually stable.	Temperature was acceptable at the time of assessment.	None		
--	--	--	---	---	------	--	--

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
<b>102D</b>	<b>Temp</b>	<input type="text" value="73.3"/>	<b>RH%</b>	<input type="text" value="54.6"/>	<b>CO2</b>	<input type="text" value="1203"/>	<b>Occupants:</b>	<input type="text"/>		
	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature shifts from extremely cold to hot - it is not usually stable.			Environmental parameters were within acceptable range at the time of assessment.	None				
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature shifts from extremely cold to hot - it is not usually stable.			Temperature was acceptable at the time of assessment.	None				
<b>111H</b>	<b>Temp</b>	<input type="text" value="72.6"/>	<b>RH%</b>	<input type="text" value="57.4"/>	<b>CO2</b>	<input type="text" value="906"/>	<b>Occupants:</b>	<input type="text" value="1"/>		
	<b>GENERAL CLEANLINESS</b>									
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None				
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None				
	Floor is cleaned on a regular basis?				Carpet was stained and rippled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations			2
	Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations			1
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None				
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None				
<b>111J</b>	<b>Temp</b>	<input type="text" value="72.6"/>	<b>RH%</b>	<input type="text" value="59.7"/>	<b>CO2</b>	<input type="text" value="894"/>	<b>Occupants:</b>	<input type="text" value="1"/>		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>									
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations			1
	<b>GENERAL CLEANLINESS</b>									
	Classroom is dusted/vacuumed thoroughly and regularly?				Carpet was stained and rippled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations			2
	<b>THERMAL COMFORT</b>									
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>111L</i>	Temp	<input type="text" value="72.4"/>	RH% <input type="text" value="59.6"/>	CO2 <input type="text" value="864"/>	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?			Odor detected. Appears to be from HVAC.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	1
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?			Carpet has not been shampooed since last year. It is swept when I leave a note requesting it be swept/vacuumed. Carpet is very old, very thin and retains an odor of dust/mold. It really should be replaced. Furniture not dusted routinely.	There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?			Carpet has not been shampooed since last year. It is swept when I leave a note requesting it be swept/vacuumed. Carpet is very old, very thin and retains an odor of dust/mold. It really should be replaced. Furniture not dusted routinely.	Carpet was stained and rippled.	Physical Plant Operations to evaluate and repair as appropriate. However, site based administration to encourage staff to keep doors and windows closed.	Physical Plant Operations 2
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?			It is usually 66-68 degrees in this office. Sometimes it will be 70 degrees for 45 minutes then go back to 68. It is always freezing in here.	Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			It is usually 66-68 degrees in this office. Sometimes it will be 70 degrees for 45 minutes then go back to 68. It is always freezing in here.	Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)			It is usually 66-68 degrees in this office. Sometimes it will be 70 degrees for 45 minutes then go back to 68. It is always freezing in here.	Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?			It is usually 66-68 degrees in this office. Sometimes it will be 70 degrees for 45 minutes then go back to 68. It is always freezing in here.	Temperature was acceptable at the time of assessment.	None	

*122*

Temp  RH%  CO2  Occupants:

**ANIMALS IN THE CLASSROOM**

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
122	Temp	74.6	RH% 52.8	CO2 1540	Occupants:	19	
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Sometimes there are ants in the room.			No dust observed on supply/return registers at the time of assessment.	None		
Room is free of pests?	Temperature in room is not consistent. Sometimes there are ants in the room. Temperature in room is not consistent.			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
<b>LOCAL EXHAUST FANS</b>							
My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No fume hood in this classroom. None needed. No bathroom in this classroom. Last 2 questions do not apply			No issues identified at the time of assessment.	None		
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?	Room temperature fluctuates - sometimes, hot sometimes cold. Lately it has been very, very hot. I have 38 computers in this room. They are on all day. They generate heat. So if the air conditioning is not working it is so hot that we are sweating!!!!			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)	Room temperature fluctuates - sometimes, hot sometimes cold. Lately it has been very, very hot. I have 38 computers in this room. They are on all day. They generate heat. So if the air conditioning is not working it is so hot that we are sweating!!!!			Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	Room temperature fluctuates - sometimes, hot sometimes cold. Lately it has been very, very hot. I have 38 computers in this room. They are on all day. They generate heat. So if the air conditioning is not working it is so hot that we are sweating!!!!			Temperature was acceptable at the time of assessment.	None		

124	Temp	74.8	RH% 57.1	CO2 1587	Occupants:	30
-----	------	------	----------	----------	------------	----

**AIR CONDITIONING**

Air is flowing without obstruction?

Air flowing without obstruction at the time of assessments. None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
124	Temp	74.8	RH% 57.1	CO2 1587	Occupants: 30		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		The air conditioning is an issue. It is either off completely or too cold.		No dust observed on supply/return registers at the time of assessment.	None		
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?		The A/C is either too cold or completely off.		Temperature was acceptable at the time of assessment.			
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The A/C is either too cold or completely off.		Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		The A/C is either too cold or completely off.		Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?		The A/C is either too cold or completely off.		Temperature was acceptable at the time of assessment.	None		
<b>Walkthrough</b>							
				Live plant in room.	Occupant to remove live plant.	Site Based	1
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
132	Temp	73.9	RH% 52.5	CO2 1612	Occupants: 17		
<b>AIR CONDITIONING</b>							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
<b>ANIMALS IN THE CLASSROOM</b>							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		When it rains, the water runs down the inside wall of the room in 2 places.		Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
<b>GENERAL CLEANLINESS</b>							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
132	Temp	73.9	RH% 52.5	CO2 1612	Occupants: 17			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	There are spills on the floor that were made by the custodial staff over winter break that are STILL on the floor.			Return vent damaged.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Classroom is dusted/vacuumed thoroughly and regularly?	There are spills on the floor that were made by the custodial staff over winter break that are STILL on the floor.			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?	There are spills on the floor that were made by the custodial staff over winter break that are STILL on the floor.			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?	There are spills on the floor that were made by the custodial staff over winter break that are STILL on the floor.			Floor was clean at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	There are spills on the floor that were made by the custodial staff over winter break that are STILL on the floor.			No issues identified relating to spill clean up practices at the time of assessment..	None		
136	Temp	73.7	RH% 54.6	CO2 1602	Occupants:			
	<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment. Dust observed on return air grill.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
145	Temp	72.8	RH% 63.4	CO2 1156	Occupants: 33			
	<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
	<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>DRAIN TRAPS IN THE CLASSROOM</b>							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
145	Temp	72.8	RH% 63.4	CO2 1156	Occupants: 33		
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No gaps in windows or doors identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		
147	Temp	73.3	RH% 64.2	CO2 1173	Occupants: 13		
	<b>AIR CONDITIONING</b>						
	Room is free of smell of mold or mildew?			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
	Windows/doors are operable and are kept closed?			Windows and doors are operable and are kept closed.	None		
	<b>ANIMALS IN THE CLASSROOM</b>						
	Classroom is free of animals and pets?			ants and spiders	No animals identified at the time of assessment.	None	
	<b>DRAIN TRAPS IN THE CLASSROOM</b>						
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

147

Temp  RH%  CO2  Occupants:

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Signs of water intrusion. Stained ceiling tiles in hallway.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
Cold water pipes free of continuous condensation?		No visible condensation at the time of assessment.	None		
Windows, windowsills and window frames free of continuous condensation?		No visible condensation at the time of assessment.	None		

**GENERAL CLEANLINESS**

Room is free of pests?	I have ants and spiders near back outside door	No pests observed at the time of assessment.	None		
------------------------	--	--	------	--	--

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?	it is too hot and moist!!	Temperature was acceptable at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	it is too hot and moist!!	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	it is too hot and moist!!	No gaps in windows or doors identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	it is too hot and moist!!	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	it is too hot and moist!!	Temperature was acceptable at the time of assessment.	None		

**Walkthrough**

Excessive amounts of paper in room.	Site based administration should work with room occupant to encourage occupant to reduce clutter.	Site Based		2
-------------------------------------	---	------------	--	---

154

Temp  RH%  CO2  Occupants:

**EXCESS MOISTURE IN CLASSROOMS**

Area around and under classroom sinks free of leaks?	Back lab sink leaks underneath and the faucet at the front sink leaks when turned on.	Signs of water intrusion.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
--	---	---------------------------	--	---------------------------	---

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?	The floor has a serious mold problem. Although the floor is cleaned daily, there is an accumulation of dirt and dust under table and around the perimeter.	There does not appear to be a dusting issue within this room.	None		
--	--	---	------	--	--

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
154	Temp	73.2	RH% 61.9	CO2 1133	Occupants: 14		
	Classrooms general appearance is clean and acceptable?	The floor has a serious mold problem. Although the floor is cleaned daily, there is an accumulation of dirt and dust under table and around the perimeter.			General cleanliness of the room at the time of assessment was acceptable.	None	
	Room is free of pests?	The floor has a serious mold problem. Although the floor is cleaned daily, there is an accumulation of dirt and dust under table and around the perimeter.			No pests observed at the time of assessment.	None	
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?	The temperature in the room often fluctuates. At times it can be very warm, and later in the day it can get chilly. You need to adjust your clothing to stay comfortable.			Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	The temperature in the room often fluctuates. At times it can be very warm, and later in the day it can get chilly. You need to adjust your clothing to stay comfortable.			Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	The temperature in the room often fluctuates. At times it can be very warm, and later in the day it can get chilly. You need to adjust your clothing to stay comfortable.			Temperature was acceptable at the time of assessment.	None	
<b>Walkthrough</b>							
		Weather threshold to exterior door is damaged.			Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
		No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.			Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
		It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.			Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based	1
		Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.			Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1

155A

Temp 73.6 RH% 61.5 CO2 1166 Occupants: 23

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

ants are a problem. there were moldy ceiling tiles- one removed and not replaced. registers need to be cleaned

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<b>155A</b>	Temp	73.6	RH% 61.5	CO2 1166	Occupants: 23		
Room is free of pests?			ants are a problem.there were moldy ceiling tiles- one removed and not replaced. registers need to be cleaned	No pests observed at the time of assessment.	None		
Walkthrough				It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based	1
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
<b>174</b>	Temp	73.8	RH% 54.6	CO2 471	Occupants: 8		
<b>AIR CONDITIONING</b>							
Air flowing from air supply?			does not apply to me	Air flowing without obstruction at the time of assessments.	None		
Room is free of smell of chemicals?			does not apply to me	Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
Room is free of smell of kitchen/food?			does not apply to me	No odor detected at the time of assessment.	None		
Room is free of smell of mold or mildew?			does not apply to me	No odor detected at the time of assessment.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
Bathroom exhaust fan is functioning properly?			does not apply to me	No issues identified at the time of assessment.	None		
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			does not apply to me	No issues identified at the time of assessment.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?			does not apply to me	No issues identified at the time of assessment.	None		
Other exhaust fans that may exist in the classroom are functioning properly?			does not apply to me	No issues identified at the time of assessment.	None		
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?			no a/c in kitchen	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
<b>174</b>	<b>Temp</b>	<input type="text" value="73.8"/>	<b>RH%</b>	<input type="text" value="54.6"/>	<b>CO2</b>	<input type="text" value="471"/>	<b>Occupants:</b>	<input type="text" value="8"/>
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		no a/c in kitchen	Humidity was acceptable at the time of assessment.	None			
	Room is usually comfortable? (If no, please explain in the notes below.)		no a/c in kitchen	Temperature was acceptable at the time of assessment.	None			
	Temperature in my classroom is generally comfortable (72F-76F)?		no a/c in kitchen	Temperature was acceptable at the time of assessment.	None			
<b>184A</b>	<b>Temp</b>	<input type="text" value="76"/>	<b>RH%</b>	<input type="text" value="59.6"/>	<b>CO2</b>	<input type="text" value="959"/>	<b>Occupants:</b>	<input type="text" value="32"/>
<b>AIR CONDITIONING</b>								
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None			
	Room is free of smell of vehicle exhaust?			No odor detected at the time of assessment.	None			
<b>EXCESS MOISTURE IN CLASSROOMS</b>								
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based		2
<b>GENERAL CLEANLINESS</b>								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		classroom is a garage--air conditioning temp is freezing,like a meat locker. The cement floor is also filthy.	No dust observed on supply/return registers at the time of assessment.	None			
	Classroom is dusted/vacuumed thoroughly and regularly?		classroom is a garage--air conditioning temp is freezing,like a meat locker. The cement floor is also filthy.	There does not appear to be a dusting issue within this room.	None			
	Floor is cleaned on a regular basis?		classroom is a garage--air conditioning temp is freezing,like a meat locker. The cement floor is also filthy.	Floor was clean at the time of assessment.	None			
	Room is free of pests?		classroom is a garage--air conditioning temp is freezing,like a meat locker. The cement floor is also filthy.	No pests observed at the time of assessment.	None			
<b>LOCAL EXHAUST FANS</b>								
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No issues identified at the time of assessment.	None			
<b>LOCKER ROOM</b>								
	Locker room and showers cleaned regularly and properly?			No issues identified at the time of assessment.	None			
	Soiled clothes and towels are removed regularly?			No issues identified at the time of assessment.	None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

184A

Temp  RH%  CO2  Occupants:

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?	cannot control temp,,,high ceiling, cement floor	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	cannot control temp,,,high ceiling, cement floor	Humidity was acceptable at the time of assessment.	None		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	cannot control temp,,,high ceiling, cement floor	No gaps in windows or doors identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	cannot control temp,,,high ceiling, cement floor	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	cannot control temp,,,high ceiling, cement floor	Temperature was acceptable at the time of assessment.	None		

185A

Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Room is free of smell of chemicals?	Occasionally there is a chemical odor.	Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
-------------------------------------	--	--	--	---------------------------	---

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Visible signs of microbial growth on wall and spaces between tiles.	No leaks or signs of water intrusion identified. No visible microbial growth.	None		
Indoor surfaces of exterior walls free of continuous condensation?	Visible signs of microbial growth on wall and spaces between tiles.	No visible condensation at the time of assessment.	None		
Windows, windowsills and window frames free of continuous condensation?	Visible signs of microbial growth on wall and spaces between tiles.	No visible condensation at the time of assessment.	None		

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?	Mold on wall behind teachers desk. Black spots on the white filter in HVAC grill.	There does not appear to be a dusting issue within this room.	None		
--	---	---	------	--	--

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?	Freezing in the room. Have to wear several layers of clothing and sometimes gloves.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)	Freezing in the room. Have to wear several layers of clothing and sometimes gloves.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	Freezing in the room. Have to wear several layers of clothing and sometimes gloves.	Temperature was acceptable at the time of assessment.	None		

**Walkthrough**

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
185A	Temp	<input type="text" value="75.9"/>	RH% <input type="text" value="60.8"/>	CO2 <input type="text" value="1031"/>	Occupants: <input type="text" value="0"/>		
				Settlement cracks to the rear of the classroom.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
194A	Temp	<input type="text" value="75.2"/>	RH% <input type="text" value="58.4"/>	CO2 <input type="text" value="916"/>	Occupants: <input type="text" value="0"/>		
<b>ANIMALS IN THE CLASSROOM</b>							
					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>GENERAL CLEANLINESS</b>							
				Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	None	
<b>THERMAL COMFORT</b>							
				Classroom is free of significant temperature shifts?	too cold	Temperature was acceptable at the time of assessment.	None
				Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	too cold	Humidity was acceptable at the time of assessment.	None
				Room is usually comfortable? (If no, please explain in the notes below.)	too cold	Environmental parameters were within acceptable range at the time of assessment..	None
				Temperature in my classroom is generally comfortable (72F-76F)?	too cold	Temperature was acceptable at the time of assessment.	None
<b>Walkthrough</b>							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Space heater in room.	Occupant to remove heater.	Site Based	1
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
201	Temp	76.3	RH% 48.2	CO2 484	Occupants:	0	
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		too cold or too hot	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)		too cold or too hot	Temperature was elevated at the time of assessment.	See other recommendation		
	Temperature in my classroom is generally comfortable (72F-76F)?		too cold or too hot	Temperature was elevated at the time of assessment.	See other recommendation.		
<b>Walkthrough</b>							
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
				Carpet was stained and rippled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
212	Temp	76	RH% 49.8	CO2 997	Occupants:	38	
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?			Odor detected and microbial growth identified. Roof leaks throughout the room.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		roof leaks	Signs of water intrusion. Walls.	See other recommendation.		
	Windows, windowsills and window frames free of continuous condensation?		roof leaks	No visible condensation at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		mildew is a problem. county will not install dehumidifiers but they are on the music basic equipment list and I see them in other schools. Mold has been at times growing on uniforms. Instrument cases too. Been damage to equipment. On weekends it is hard t	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
212	Temp <input type="text" value="76"/> RH% <input type="text" value="49.8"/> CO2 <input type="text" value="997"/>	Occupants: <input type="text" value="38"/>			
Room is free of pests?	mildew is a problem. county will not install dehumidifiers but they are on the music basic equipment list and I see them in other schools. Mold has been at times growing on uniforms. Instrument cases too. Been damage to equipment. On weekends it is hard t	Pests observed at the time of assessment (FISH 217P)	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
<b>THERMAL COMFORT</b>					
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Humidity was acceptable at the time of assessment.	None		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		No gaps in windows or doors identified at the time of assessment.	None		
<b>Walkthrough</b>					
		Carpet was stained and rippled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
218	Temp <input type="text" value="75.5"/> RH% <input type="text" value="60.3"/> CO2 <input type="text" value="1024"/>	Occupants: <input type="text"/>			
<b>AIR CONDITIONING</b>					
Room is free of smell of kitchen/food?		No odor detected at the time of assessment.	None		
Room is free of smell of mold or mildew?		No odor detected at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>					
Room is free of pests?	MUSTY SMELL -	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
218A	Temp <input type="text" value="75.5"/> RH% <input type="text" value="60.3"/> CO2 <input type="text" value="1024"/>	Occupants: <input type="text"/>			
<b>AIR CONDITIONING</b>					
Room is free of smell of mold or mildew?	WE NEED HELP WITH MOLD CONTROL	No odor detected at the time of assessment and no visible microbial growth.	None		
<b>GENERAL CLEANLINESS</b>					
Room is free of pests?	THIS IS A STORAGE/FILE AREA WHICH NEEDS TO BE ADDRESSED FOR MOLD.	No pests observed at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<b>218B</b>	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		I have mold spores growing on the door and walls. i also have a roof tile that has mold from a leak	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	Indoor surfaces of exterior walls free of continuous condensation?		I have mold spores growing on the door and walls. i also have a roof tile that has mold from a leak	No visible condensation at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
<b>218C</b>	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?			Odor detected and no microbial growth identified. Live plants, stuffed animals, cloth chairs, area rug and pillows in room.	Occupant should remove live plants, stuffed animals, cloth chairs, area rug and pillows.	Site Based	1
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Joyce does a good job of cleaning each night. We do have a ant problem which seems to be related to the construction next door.	No dust observed on supply/return registers at the time of assessment.	None		
	Room is free of pests?		Joyce does a good job of cleaning each night. We do have a ant problem which seems to be related to the construction next door.	No pests observed at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
244	Temp	<input type="text" value="76"/>	RH% <input type="text" value="58.6"/>	CO2 <input type="text" value="759"/>	Occupants: <input type="text" value="27"/>		
<b>AIR CONDITIONING</b>							
Room is free of smell of mold or mildew?			Odor detected and no microbial growth identified. Carpet is stained.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2	
<b>GENERAL CLEANLINESS</b>							
Room is free of pests?			No pests observed at the time of assessment.	None			
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?			generally too cold in cooler weather months.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)			generally too cold in cooler weather months.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			generally too cold in cooler weather months.	Temperature was acceptable at the time of assessment.	None		
<b>Walkthrough</b>							
			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2	
244A	Temp	<input type="text" value="76"/>	RH% <input type="text" value="58.6"/>	CO2 <input type="text" value="759"/>	Occupants: <input type="text"/>		
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?			room is missing vents and blows arctic air.	Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			room is missing vents and blows arctic air.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			room is missing vents and blows arctic air.	Temperature was acceptable at the time of assessment.	None		
<b>Walkthrough</b>							
			Supply vent missing.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2	
251	Temp	<input type="text" value="74.4"/>	RH% <input type="text" value="55.4"/>	CO2 <input type="text" value="1072"/>	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
Room is free of smell of mold or mildew?			Often I have parents enter the office and comment that it smells of mildew.	Odor detected and no microbial growth identified.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
<b>GENERAL CLEANLINESS</b>							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
251	Temp	74.4	RH%	55.4	CO2	1072	Occupants:	
	Classroom is dusted/vacuumed thoroughly and regularly?	There is a fine black dust that always coats my desk. I am concerned it may be blowing out of the air vents.			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?	There is a fine black dust that always coats my desk. I am concerned it may be blowing out of the air vents.			Floor was clean at the time of assessment.	None		
	Walkthrough				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
251B	Temp		RH%		CO2		Occupants:	
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	The temperature in my office is frequently very cold.			No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	The temperature in my office is frequently very cold.			No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	The temperature in my office is frequently very cold.			No issues identified at the time of assessment.	None		
	Walkthrough				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
259	Temp	73.1	RH%	60.6	CO2	1448	Occupants:	26
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
	Walkthrough							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
259	Temp	73.1	RH% 60.6	CO2 1448	Occupants: 26		
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
259E	Temp	73.4	RH% 55.4	CO2 1448	Occupants: 20		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles, stains on carpet, damage to wall plaster and visible microbial growth in refrigerator pan.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
260E	Temp	72.7	RH% 59.9	CO2 1116	Occupants:		
	<b>AIR CONDITIONING</b>						
	Room is free of smell of mold or mildew?		Walls are craking from some form of mold or mildew in planningm area	No odor detected at the time of assessment.	None		
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Carpet in hallway is stained.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None		
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		
	<b>THERMAL COMFORT</b>						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
260E	Temp	72.7	RH%	59.9	CO2	1116	Occupants:	
Classroom is free of significant temperature shifts?	The room is too cold. I must wear layers of clothing because once I leave my room it is warm. (Temperature extremes). It is uncomfortable to work in a freezing cold room nor does this aid in testing, preparing for tests or general class work.			Temperature was acceptable at the time of assessment.	None			
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	The room is too cold. I must wear layers of clothing because once I leave my room it is warm. (Temperature extremes). It is uncomfortable to work in a freezing cold room nor does this aid in testing, preparing for tests or general class work.			Humidity was acceptable at the time of assessment.	None			
Room is usually comfortable? (If no, please explain in the notes below.)	The room is too cold. I must wear layers of clothing because once I leave my room it is warm. (Temperature extremes). It is uncomfortable to work in a freezing cold room nor does this aid in testing, preparing for tests or general class work.			Environmental parameters were within acceptable range at the time of assessment.	None			
Temperature in my classroom is generally comfortable (72F-76F)?	The room is too cold. I must wear layers of clothing because once I leave my room it is warm. (Temperature extremes). It is uncomfortable to work in a freezing cold room nor does this aid in testing, preparing for tests or general class work.			Temperature was acceptable at the time of assessment.	None			
261	Temp	72.7	RH%	65.3	CO2	1486	Occupants:	22
<b>AIR CONDITIONING</b>								
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None			
Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None			
<b>EXCESS MOISTURE IN CLASSROOMS</b>								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based		2
<b>GENERAL CLEANLINESS</b>								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	I BELIEVE THE DUST IS A RESULT OF THE AIR SYSTEM AND NOT LACK OF CUSTODIAL CARE.			No dust observed on supply/return registers at the time of assessment.	None			
Classroom is dusted/vacuumed thoroughly and regularly?	I BELIEVE THE DUST IS A RESULT OF THE AIR SYSTEM AND NOT LACK OF CUSTODIAL CARE.			There does not appear to be a dusting issue within this room.	None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
261	Temp	72.7	RH% 65.3	CO2 1486	Occupants:	22	
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?	MY STUDENTS COMPLAIN ABOUT HOW COLD THE ROOM IS; THE WEST SIDE HAS A VERY STRONG, CONSTANT, COLD DRAFT OF AIR.			Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	MY STUDENTS COMPLAIN ABOUT HOW COLD THE ROOM IS; THE WEST SIDE HAS A VERY STRONG, CONSTANT, COLD DRAFT OF AIR.			Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	MY STUDENTS COMPLAIN ABOUT HOW COLD THE ROOM IS; THE WEST SIDE HAS A VERY STRONG, CONSTANT, COLD DRAFT OF AIR.			Temperature was acceptable at the time of assessment.	None	
265	Temp	72.7	RH% 64.5	CO2 1393	Occupants:	0	
<b>AIR CONDITIONING</b>							
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None	
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None	
	Room is free of smell of mold or mildew?				Odor detected and no microbial growth identified.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations 2
	Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None	
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

265

Temp  RH%  CO2

Occupants:

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

Room is free of pests?

No pests observed at the time of assessment.

None

Spills and other such issues requiring custodial assistance are addressed in a timely manner?

No issues identified relating to spill clean up practices at the time of assessment..

None

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No issues identified at the time of assessment.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

the room is too warm and humid ...at the end of the school day there is condensation on the desks--classroom papers and books generally feel damp and there is always a musty odor in the room

Temperature was acceptable at the time of assessment.

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

the room is too warm and humid ...at the end of the school day there is condensation on the desks--classroom papers and books generally feel damp and there is always a musty odor in the room

Humidity was slightly elevated at the time of assessment.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Physical Plant Operations

2

Room is usually comfortable? (If no, please explain in the notes below.)

the room is too warm and humid ...at the end of the school day there is condensation on the desks--classroom papers and books generally feel damp and there is always a musty odor in the room

Temperature was acceptable at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

the room is too warm and humid ...at the end of the school day there is condensation on the desks--classroom papers and books generally feel damp and there is always a musty odor in the room

Temperature was acceptable at the time of assessment.

None

266

Temp  RH%  CO2

Occupants:

THERMAL COMFORT

Classroom is free of significant temperature shifts?

cold classroom.

Humidity was slightly elevated at the time of assessment .

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Physical Plant Operations

2

Room is usually comfortable? (If no, please explain in the notes below.)

cold classroom.

Temperature was acceptable at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

cold classroom.

Temperature was acceptable at the time of assessment.

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
266	Temp	72.9	RH% 65.4	CO2 1431	Occupants: 15		
Walkthrough							
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
278	Temp	72.6	RH% 58.7	CO2 1574	Occupants: 28		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			There is a mildew smell that even parents have commented on. This building also went through a "mildew-abatement" treatment a few years ago. The air gets shut off on Friday and re-started on Monday so there MUST be moisture in the duct work/	No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			My room is usually too cold (67-69 degrees), but that changes daily so that it is impossible to dress accordingly.	Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			My room is usually too cold (67-69 degrees), but that changes daily so that it is impossible to dress accordingly.	Environmental parameters were within acceptable range at the time of assessment..	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
278	Temp	72.6	RH% 58.7	CO2 1574	Occupants: 28			
	Temperature in my classroom is generally comfortable (72F-76F)?	My room is usually too cold (67-69 degrees), but that changes daily so that it is impossible to dress accordingly.			Temperature was acceptable at the time of assessment.	None		
282	Temp	72	RH% 62	CO2 1676	Occupants: 14			
	<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?				Odor detected at the time of assessment. Air freshener, scented cleaners or non-approved chemicals found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
	<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		
	Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
	<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
	<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
283	Temp	72.1	RH% 61	CO2 1755	Occupants: 23		
	<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles and moisture in light fixtures.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			some of these are vague at best..i for example..does that mean mopped or just swept..what is a regular basis? once a month?	No dust observed on supply/return registers at the time of assessment.	None	
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?			At times it can be too cold...the size of my classes vary considerably so that could account for it.	Temperature was acceptable at the time of assessment.	None	
289	Temp	71.9	RH% 61.1	CO2 1778	Occupants: 25		
	<b>AIR CONDITIONING</b>						
	Room is free of smell of mold or mildew?			Odor detected and no microbial growth identified. Odor appears to be coming from HVAC ducts.	Physical Plant operations to evaluate and clean HVAC ducts.	Physical Plant Operations	2
	<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
289	Temp	71.9	RH% 61.1	CO2 1778	Occupants: 25		
	Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation at the time of assessment.	None	
	Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None	
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	
	<b>LOCAL EXHAUST FANS</b>						
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None	
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?		The room is either too cold or too hot - no happy medium		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		The room is either too cold or too hot - no happy medium		No gaps in windows or doors identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		The room is either too cold or too hot - no happy medium		Temperature was low at the time of assessment.	See other recommendation.	
	Temperature in my classroom is generally comfortable (72F-76F)?		The room is either too cold or too hot - no happy medium		Temperature was low at the time of assessment.	See other recommendation.	

308	Temp	72.4	RH% 55.4	CO2 991	Occupants:	
-----	------	------	----------	---------	------------	--

**AIR CONDITIONING**

Windows/doors are operable and are kept closed?	Windows do not open	No issues identified at the time of assessment.	None
---	---------------------	---	------

**ANIMALS IN THE CLASSROOM**

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
308	Temp	72.4	RH% 55.4	CO2 991	Occupants: <input type="text"/>		
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
<b>DRAIN TRAPS IN THE CLASSROOM</b>							
	Water run in sinks at least once per week (about 2 cups of water).			No issues identified at the time of assessment.		None	
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		There has been a leak at the door for years. It leaks when it rains. It is dangerous as students enter on the wet floor; we do have a mat there to help avoid slipping.	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.		Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Better wax needs to be used so that it will last. Rolling chairs remove wax quickly and looks dirty.	No dust observed on supply/return registers at the time of assessment.		None	
	Floor is cleaned on a regular basis?		Better wax needs to be used so that it will last. Rolling chairs remove wax quickly and looks dirty.	Floor was clean at the time of assessment.		None	
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?		There are no exhaust fans	No exhaust fans in room. Identified in error.		None	
	Other exhaust fans that may exist in the classroom are functioning properly?		There are no exhaust fans	No exhaust fans in room. Identified in error.		None	
<b>Walkthrough</b>							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.		Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

311

Temp  RH%  CO2

Occupants:

**AIR CONDITIONING**

Room is free of smell of mold or mildew?

Ductwork needs to be cleaned and filters replaced at least once a month due to the high dust produced by ceramic clay projects

Odor detected and no microbial growth identified. Odor appears to be from HVAC ducts.

Physical Plant operations to evaluate and clean HVAC ducts.

Physical Plant Operations

2

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

This class room is used for ceramics and numerous night school art courses. There is a lot of dust produced by these courses. The air filters and ductwork need to be cleaned no less than once a month. Currently they are cleaned quarterly.

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

This class room is used for ceramics and numerous night school art courses. There is a lot of dust produced by these courses. The air filters and ductwork need to be cleaned no less than once a month. Currently they are cleaned quarterly.

There does not appear to be a dusting issue within this room.

None

Classrooms general appearance is clean and acceptable?

This class room is used for ceramics and numerous night school art courses. There is a lot of dust produced by these courses. The air filters and ductwork need to be cleaned no less than once a month. Currently they are cleaned quarterly.

General cleanliness of the room at the time of assessment was acceptable.

None

**THERMAL COMFORT**

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

Holes around pipes and the paint is blistering on exterior wall.

Physical Plant Operations to evaluate for roof leaks and repair as appropriate.

Physical Plant Operations

1

**Walkthrough**

Pests observed at the time of assessment.

Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.

Physical Plant Operations

1

Live plants in room.

Occupant to remove live plants.

Site Based

1

321

Temp  RH%  CO2

Occupants:

**ANIMALS IN THE CLASSROOM**

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
321	Temp	76	RH%	45.5	CO2	465	Occupants:				
	You are informed about the potential allergies of your students?								Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>DRAIN TRAPS IN THE CLASSROOM</b>										
	Water run in sinks at least once per week (about 2 cups of water).			Unsure if water is run down sink.	No issues identified at the time of assessment.				None		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Staining on ceiling tiles.	Signs of water intrusion. Appears to be roof leaks. Ceiling tiles and walls are stained and damaged in 321 and 321B.				Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	<b>THERMAL COMFORT</b>										
	Classroom is free of significant temperature shifts?			Air conditioning frequently goes down. They repair and then it stops working again.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.				Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?			Air conditioning frequently goes down. They repair and then it stops working again.	Temperature was acceptable at the time of assessment.				None		
	Walkthrough										
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.				Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
325A	Temp	76.1	RH%	43.7	CO2	523	Occupants:				
	<b>GENERAL CLEANLINESS</b>										
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.				None		
	Walkthrough										
					Signs of water intrusion. Stained ceiling tiles.				Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
					Pests observed at the time of assessment.				Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
					Dust and debris on screen above exterior door.				Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
401H	Temp	73.8	RH%	49.1	CO2	764	Occupants:	9			
<b>AIR CONDITIONING</b>											
Room is free of smell of mold or mildew?											
					No odor detected at the time of assessment.	None					
<b>GENERAL CLEANLINESS</b>											
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?											
			There are times when I come in and there are small dust globs on my desk that I think come from the ac unit. I use air freshner in my room because it sometimes smells moldy , probably from the library books outside.			No dust observed on supply/return registers at the time of assessment.		None			
Room is free of the use of scented cleaners and air fresheners?											
			There are times when I come in and there are small dust globs on my desk that I think come from the ac unit. I use air freshner in my room because it sometimes smells moldy , probably from the library books outside.			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.		None			
404	Temp	73.5	RH%	53.7	CO2	780	Occupants:				
<b>AIR CONDITIONING</b>											
Room is free of smell of mold or mildew?											
			The room usually smells of mildew. Particularly on Monday morning.			Odor detected and no microbial growth identified. Appears to be from HVAC return.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.		Site Based	2
<b>EXCESS MOISTURE IN CLASSROOMS</b>											
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?											
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.		Facilities serviceperson to replace stained ceiling tiles.		Site Based	2	
<b>THERMAL COMFORT</b>											
Classroom is free of significant temperature shifts?											
			The classroom is cold and the adjoining lab is generally warm.			Temperature was acceptable at the time of assessment.		None			
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)											
			The classroom is cold and the adjoining lab is generally warm.			Humidity was acceptable at the time of assessment.		None			
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)											
			The classroom is cold and the adjoining lab is generally warm.			No gaps in windows or doors identified at the time of assessment.		None			
Room is usually comfortable? (If no, please explain in the notes below.)											
			The classroom is cold and the adjoining lab is generally warm.			Environmental parameters were within acceptable range at the time of assessment..		None			
Temperature in my classroom is generally comfortable (72F-76F)?											
			The classroom is cold and the adjoining lab is generally warm.			Temperature was acceptable at the time of assessment.		None			
<b>Walkthrough</b>											
					Upholstered couches in room.		Occupant to remove couches.		Site Based	1	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
852	Temp	<input type="text" value="75.9"/>	RH% <input type="text" value="60.8"/>	CO2 <input type="text" value="471"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
853	Temp	<input type="text" value="76"/>	RH% <input type="text" value="53.3"/>	CO2 <input type="text" value="717"/>	Occupants: <input type="text" value="10"/>		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
854	Temp	<input type="text" value="76.1"/>	RH% <input type="text" value="68.3"/>	CO2 <input type="text" value="558"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None		
855	Temp	<input type="text" value="76.3"/>	RH% <input type="text" value="65.4"/>	CO2 <input type="text" value="718"/>	Occupants: <input type="text" value="14"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		The A/C return needs to be cleaned more often. The last time was during the Winter Break.		No dust observed on supply/return registers at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		The room seems to be very cold in the early morning, and then seems to warm up approximately 10 degrees by noon, by 1:30pm the room is again very comfortable. Right now (12:30pm- it is stifling!)		Temperature was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
855	Temp	76.3	RH% 65.4	CO2 718	Occupants: 14			
	Room is usually comfortable? (If no, please explain in the notes below.)	The room seems to be very cold in the early morning, and then seems to warm up approximately 10 degrees by noon, by 1:30pm the room is again very comfortable. Right now (12:30pm- it is stifling!)			Temperature was elevated at the time of assessment.	See other recommendation.		
	Temperature in my classroom is generally comfortable (72F-76F)?	The room seems to be very cold in the early morning, and then seems to warm up approximately 10 degrees by noon, by 1:30pm the room is again very comfortable. Right now (12:30pm- it is stifling!)			Temperature was elevated at the time of assessment.	See other recommendation		
856	Temp	76.6	RH% 47.8	CO2 639	Occupants: 29			
	<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
	<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	My classroom is either cold or hot. Sometimes it is too cold or too hot. The air quality is bad and the smell of mold is horrible! I suffer from allergies and this is a hazard to my health.			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?	My classroom is either cold or hot. Sometimes it is too cold or too hot. The air quality is bad and the smell of mold is horrible! I suffer from allergies and this is a hazard to my health.			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?	My classroom is either cold or hot. Sometimes it is too cold or too hot. The air quality is bad and the smell of mold is horrible! I suffer from allergies and this is a hazard to my health.			Floor was clean at the time of assessment.	None		
	<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?	Is either too hot or too cold. It is never comfortable!			Temperature was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Is either too hot or too cold. It is never comfortable!			Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Is either too hot or too cold. It is never comfortable!			Temperature was elevated at the time of assessment.	See other recommendation.		
	Temperature in my classroom is generally comfortable (72F-76F)?	Is either too hot or too cold. It is never comfortable!			Temperature was elevated at the time of assessment.	See other recommendation.		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

857

Temp  RH%  CO2  Occupants:

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?	I would like to see my room cleaner, the floor mop at least one time a month	There does not appear to be a dusting issue within this room.	None
Food, if any, is stored in tightly sealed containers?	I would like to see my room cleaner, the floor mop at least one time a month	No issues identified at the time of assessment.	None
Spills and other such issues requiring custodial assistance are addressed in a timely manner?	I would like to see my room cleaner, the floor mop at least one time a month	No issues identified relating to spill clean up practices at the time of assessment..	None

**LOCAL EXHAUST FANS**

Bathroom exhaust fan is functioning properly?	There are not bathroom or lockers in my room.	No issues identified at the time of assessment.	None
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	There are not bathroom or lockers in my room.	No issues identified at the time of assessment.	None
My classroom has sufficient exhaust systems based on the activities/functionality of the room?	There are not bathroom or lockers in my room.	No issues identified at the time of assessment.	None
Other exhaust fans that may exist in the classroom are functioning properly?	There are not bathroom or lockers in my room.	No issues identified at the time of assessment.	None

**Walkthrough**

Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
Signs of water intrusion at window of South wall.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1

858

Temp  RH%  CO2  Occupants:

**GENERAL CLEANLINESS**

Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None
Room is free of the use of scented cleaners and air fresheners?		No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None

**Walkthrough**

Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
---	--	---------------------------	---