

Aston A. Henry, Supervisor
Risk Management Department

Telephone: 754 321-1900
Fax: 754 321-1917

April 17, 2012

Signature on File

TO: Enid Valdez, Principal
Piper High School

FROM: Robert Krickovich, Coordinator I, LEA
Facilities and Construction Management

SUBJECT: Indoor Air Quality (IAQ) Assessment

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed

On January 9, 2012 I conducted an assessment at **Piper High School**. Attached are findings and recommendations for further assessment, remediation, or corrective actions needed.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-1907.

cc: Area Superintendent
Area Directors
Shelley Meloni, Executive Director, Facilities and Construction Management
Mark Dorsett, Acting Director, Physical Plant Operations Division, Maintenance
Sonja Coley, Project Manager III, Facilities and Construction Management
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Aston Henry, Supervisor, Risk Management
Broward Teachers Union
Federation of Public Employees

RK/tc
Enc.

IAQ Assessment

Piper High School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="199"/>	<input type="text" value="73.5"/>	<input type="text" value="72 - 78"/>	<input type="text" value="50.1"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="1404"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="3"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>	<input type="text" value="None"/>	<input type="text" value="None"/>
Wall Type	<input type="text" value="Drywall"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>	<input type="text" value="None"/>	<input type="text" value="None"/>
Flooring	<input type="text" value="12 x 12 Vinyl"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>	<input type="text" value="None"/>	<input type="text" value="None"/>

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>
HVAC Supply Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>
HVAC Return Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings

- CO2 level was slightly elevated
- Dust build up on HVAC supply and return grills
- Dust and debris build up on flooring in corners and edges of room
- Ceiling tiles not installed properly
- Non-approved chemicals in the room -- 2 gallons of bleach, 1 gallon of Wexcide, 1 quart of PineSol, 1 gallon of Windex, box of Borax, toilet bowl cleaner, 2 cans of Raid, Comet cleaner, Sanilite cleaner (phosphoric acid, oxalic acid).

Site Based Maintenance:

- Clean HVAC supply and return grills with Wexcide disinfectant solution
- Clean and sanitize flooring
- Properly install ceiling tiles to prevent dust and debris from entering the occupied space
- Remove non-approved chemicals from room.
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:

- Evaluate HVAC system for proper operation and repair as appropriate to lower CO2

- NOTE: Work orders EQ022286 generated 1-25-12