

Piper High

1901

IAQ Walkthrough 5/16/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
025	Temp <input type="text" value="69.2"/> RH% <input type="text" value="38.3"/> CO2 <input type="text" value="2135"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING				
	Room is free of smell of mold or mildew?	Odor detected at the time of assessment.	Change both A/C filters.	Site Based	2
	ANIMALS IN THE CLASSROOM				
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
	GENERAL CLEANLINESS				
	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	None		
	Room is free of pests?	No pests observed at the time of assessment.	None		
030	Temp <input type="text" value="73.2"/> RH% <input type="text" value="40.0"/> CO2 <input type="text" value="2200"/>	Occupants: <input type="text" value="1"/>			
	ANIMALS IN THE CLASSROOM				
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		2
	GENERAL CLEANLINESS				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
030	Temp	73.2	RH% 40.0	CO2 2200	Occupants: 1		
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
Walkthrough					Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
105	Temp	69.9	RH% 48.3	CO2 1094	Occupants: 3		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 2
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 2	
106	Temp	70.5	RH% 48.5	CO2 1295	Occupants: 3		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 2
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 2
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
106	Temp	70.5	RH% 48.5	CO2 1295	Occupants: 3			
	Classroom is dusted/vacuumed thoroughly and regularly?	Carpet needs to be vacuumed on a regular basis. Room needs to be dusted more frequently.			Carpet was stained and torn.	Remove carpet. Install tile floor.	Physical Plant Operations	2
	Floor is cleaned on a regular basis?	Carpet needs to be vacuumed on a regular basis. Room needs to be dusted more frequently.			Carpet was stained and torn.	Remove carpet. Install tile floor.	Physical Plant Operations	1
107	Temp	71.1	RH% 47.9	CO2 1263	Occupants: 2			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Trash bag should be changed every day to ensure that germs from used tissues do not remain in the classroom. The floor should be mopped more regularly.			No dust observed on supply/return registers at the time of assessment.	None		
	Floor is cleaned on a regular basis?	Trash bag should be changed every day to ensure that germs from used tissues do not remain in the classroom. The floor should be mopped more regularly.			Floor was clean at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?	Trash bag should be changed every day to ensure that germs from used tissues do not remain in the classroom. The floor should be mopped more regularly.			No issues identified regarding trash removal practices.	None		
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
110	Temp	71.9	RH% 50.2	CO2 736	Occupants: 4			
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
GENERAL CLEANLINESS								
	Floor is cleaned on a regular basis?	The custodian cleans between my use of the room (day school) and night school use of the room. Night school teacher does not leave the room in clean condition, trash cans filled with food containers, etc.			Floor was clean at the time of assessment.	None		
	Food, if any, is stored in tightly sealed containers?	The custodian cleans between my use of the room (day school) and night school use of the room. Night school teacher does not leave the room in clean condition, trash cans filled with food containers, etc.			No unsealed food items were observed at the time of assessment.	None		
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
111	Temp	74.4	RH% 45.6	CO2 1309	Occupants: 22		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.		Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
LOCAL EXHAUST FANS							
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			No activities occur in the classroom other than normal instruction.		It appears that the ventilation system is adequate based on room activities.	None	
114	Temp	72.9	RH% 46.4	CO2 1297	Occupants: 19		
AIR CONDITIONING							
Air is flowing without obstruction?			The room smells of personal odors constantly. This is sickening. There are too many people and not adequate ventilation to remove the foul and stale air.		Air flowing without obstruction at the time of assessments.	None	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.		None		
Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.		None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
114	Temp	72.9	RH% 46.4	CO2 1297	Occupants: 19		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			The ladies restroom in the 100 planning area is TOTALLY inadequate in every respect. It is overused, old, and dirty. The exhaust fan does not work properly, the bathroom was not built to accommodate the large number of users and it is a health hazard.	Bathroom exhaust fan is functioning properly.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			The ladies restroom in the 100 planning area is TOTALLY inadequate in every respect. It is overused, old, and dirty. The exhaust fan does not work properly, the bathroom was not built to accommodate the large number of users and it is a health hazard.	It appears that the ventilation system is adequate based on room activities.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?			The ladies restroom in the 100 planning area is TOTALLY inadequate in every respect. It is overused, old, and dirty. The exhaust fan does not work properly, the bathroom was not built to accommodate the large number of users and it is a health hazard.	It appears that the ventilation system is adequate based on room activities.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			In the morning the room is hot and very stuffy. It is very difficult to breathe. It is NEVER aired out. It smells of humanity. It feels as if there is not enough oxygen in the room. The room needs AC and fresh air at all times.	Temperature was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			In the morning the room is hot and very stuffy. It is very difficult to breathe. It is NEVER aired out. It smells of humanity. It feels as if there is not enough oxygen in the room. The room needs AC and fresh air at all times.	No gaps in windows or doors identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)			In the morning the room is hot and very stuffy. It is very difficult to breathe. It is NEVER aired out. It smells of humanity. It feels as if there is not enough oxygen in the room. The room needs AC and fresh air at all times.	Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
114	Temp <input type="text" value="72.9"/> RH% <input type="text" value="46.4"/> CO2 <input type="text" value="1297"/> Temperature in my classroom is generally comfortable (72F-76F)?	Occupants: <input type="text" value="19"/> Temperature was acceptable at the time of assessment.	None		
115	Temp <input type="text" value="70.8"/> RH% <input type="text" value="44.2"/> CO2 <input type="text" value="918"/> ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students?	Occupants: <input type="text" value="2"/> This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS Floor is cleaned on a regular basis?	Floors do need to be cleaned more frequently. Other than that the room is well maintained and the cleaning staff pleasant to work with. Floor was clean at the time of assessment.	None		
116	Temp <input type="text" value="71.1"/> RH% <input type="text" value="53.7"/> CO2 <input type="text" value="806"/> AIR CONDITIONING Room is free of smell of mold or mildew?	Occupants: <input type="text" value="20"/> No microbial growth identified. No odor identified at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	ART SUPPLIES Art supplies okay?	No art supplies in room. Room not being used as an art room.	None		
	Following good handling and storage practices for art supplies?	No art supplies in room. Room not being used as an art room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
116	Temp	<input type="text" value="71.1"/>	RH%	<input type="text" value="53.7"/>	CO2	<input type="text" value="806"/>	Occupants:	<input type="text" value="20"/>
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			floor should be mopped once a week	No dust observed on supply/return registers at the time of assessment.	None			
Classroom is dusted/vacuumed thoroughly and regularly?			floor should be mopped once a week	There does not appear to be a dusting issue within this room.	None			
Floor is cleaned on a regular basis?			floor should be mopped once a week	Floor was clean at the time of assessment.	None			
Room is free of pests?			floor should be mopped once a week	No pests observed at the time of assessment.	None			
117	Temp	<input type="text" value="74.0"/>	RH%	<input type="text" value="53.0"/>	CO2	<input type="text" value="1208"/>	Occupants:	<input type="text" value="21"/>
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None			
Floor is cleaned on a regular basis?				Carpet was stained and torn. Install tile floor.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations		1
118	Temp	<input type="text" value="70.0"/>	RH%	<input type="text" value="54.5"/>	CO2	<input type="text" value="651"/>	Occupants:	<input type="text" value="2"/>
AIR CONDITIONING								
Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None			
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
118	Temp	70.0	RH% 54.5	CO2 651	Occupants: 2		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Candy = ants. We have sales and machines, ergo I have ants. Floor is swept w/ a straw broom circa 1950. Clean??? Neat!	There does not appear to be a dusting issue within this room.	None	
	Room is free of pests?			Candy = ants. We have sales and machines, ergo I have ants. Floor is swept w/ a straw broom circa 1950. Clean??? Neat!	No pests observed at the time of assessment.	None	
	LOCAL EXHAUST FANS						
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			It appears that the ventilation system is adequate based on room activities.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No gaps in windows or doors identified at the time of assessment.	None		

119	Temp	72.5	RH% 51.2	CO2 815	Occupants: 13		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			If the air conditioning is off, the room has a musty smell due to the fact that it has leaked in this classroom for more than twenty years.	No odor detected at the time of assessment.	None	
	LOCAL EXHAUST FANS						
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			I am in a classroom without a bathroom, kitchen etc., therefore, some of these questions are not applicable to my room. I teach high school and the activities we do in class do not involve anything that would cause fumes.	It appears that the ventilation system is adequate based on room activities.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
119	Temp	<input type="text" value="72.5"/>	RH%	<input type="text" value="51.2"/>	CO2	<input type="text" value="815"/>	Occupants:	<input type="text" value="13"/>
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	The temperature tends to shift periodically even without adjustments to the thermometer.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	The temperature tends to shift periodically even without adjustments to the thermometer.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	The temperature tends to shift periodically even without adjustments to the thermometer.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
Walkthrough								
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations		1
120	Temp	<input type="text" value="71.7"/>	RH%	<input type="text" value="51.1"/>	CO2	<input type="text" value="585"/>	Occupants:	<input type="text" value="2"/>
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
	Room is free of pests?				No pests observed at the time of assessment.	None		
121	Temp	<input type="text" value="71.1"/>	RH%	<input type="text" value="51.2"/>	CO2	<input type="text" value="601"/>	Occupants:	<input type="text" value="2"/>
AIR CONDITIONING								
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
121	Temp	71.1	RH% 51.2	CO2 601	Occupants: 2		
ART SUPPLIES							
Art supplies okay?				No art supplies in room. Room not being used as an art room.	None		
122	Temp	72.6	RH% 48.3	CO2 705	Occupants: 6		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		A new part was placed in my air conditioning because the room was always below 60degrees. The part worked for about 2 months but broke again. I can have the thermostat placed at 80 and it will still be 55 or 60 in here.		No gaps in windows or doors identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		A new part was placed in my air conditioning because the room was always below 60degrees. The part worked for about 2 months but broke again. I can have the thermostat placed at 80 and it will still be 55 or 60 in here.		Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?		A new part was placed in my air conditioning because the room was always below 60degrees. The part worked for about 2 months but broke again. I can have the thermostat placed at 80 and it will still be 55 or 60 in here.		Temperature was acceptable at the time of assessment.	None		
127	Temp	73.8	RH% 44.9	CO2 1022	Occupants: 3		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
127	Temp	73.8	RH% 44.9	CO2 1022	Occupants: 3		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
Walkthrough							
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
				Soiled and stained carpet. Replace with tile floor.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
128	Temp	72.4	RH% 44.3	CO2 874	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
133	Temp	70.7	RH% 48.5	CO2 876	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Carpet is old; this is one of the few rooms that still has the old carpet. Every morning the desk is covered with a layer of black fibers, perhaps dust & old insulation fibers coming out of the air ducts.	No dust observed on supply/return registers at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
133	Temp	70.7	RH% 48.5	CO2 876	Occupants:		
Classroom is dusted/vacuumed thoroughly and regularly?	Carpet is old; this is one of the few rooms that still has the old carpet. Every morning the desk is covered with a layer of black fibers, perhaps dust & old insulation fibers coming out of the air ducts.			There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?	Carpet is old; this is one of the few rooms that still has the old carpet. Every morning the desk is covered with a layer of black fibers, perhaps dust & old insulation fibers coming out of the air ducts.			Carpet was stained and torn. Install new tile floor.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Spills and other such issues requiring custodial assistance are addressed in a timely manner?	Carpet is old; this is one of the few rooms that still has the old carpet. Every morning the desk is covered with a layer of black fibers, perhaps dust & old insulation fibers coming out of the air ducts.			No issues identified relating to spill clean up practices at the time of assessment..	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?	Thermostat does not appear to regulate room temperature.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)	Thermostat does not appear to regulate room temperature.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?	Thermostat does not appear to regulate room temperature.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

144

Temp 75.1 RH% 60.0 CO2 1061 Occupants: 19

AIR CONDITIONING

Room is free of smell of chemicals?

No odor detected at the time of assessment. None

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
144	Temp	75.1	RH% 60.0	CO2 1061	Occupants: 19			
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None			
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None			
	Walkthrough							
				Soiled and stained carpet. Install tile floor	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2	
145	Temp	71.1	RH% 45.5	CO2 758	Occupants: 10			
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None			
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None			
	Room is free of pests?			No pests observed at the time of assessment.	None			
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		OFTEN VERY COLD!		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	3
	Room is usually comfortable? (If no, please explain in the notes below.)		OFTEN VERY COLD!		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
145	Temp	71.1	RH%	45.5	CO2	758	Occupants:	10			
	Temperature in my classroom is generally comfortable (72F-76F)?	OFTEN VERY COLD!			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				3
145B	Temp	76.4	RH%	48.7	CO2	758	Occupants:	4			
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	I came to Piper in August and found the office I had been assigned (Audiovisual) had not had the floor cleaned or waxed in YEARS! Room also very dusty (dust balls), but room was washed, stripped and waxed at my request and has been fairly well maintained			No dust observed on supply/return registers at the time of assessment.	None					
	Classroom is dusted/vacuumed thoroughly and regularly?	I came to Piper in August and found the office I had been assigned (Audiovisual) had not had the floor cleaned or waxed in YEARS! Room also very dusty (dust balls), but room was washed, stripped and waxed at my request and has been fairly well maintained			There does not appear to be a dusting issue within this room.	None					
	Floor is cleaned on a regular basis?	I came to Piper in August and found the office I had been assigned (Audiovisual) had not had the floor cleaned or waxed in YEARS! Room also very dusty (dust balls), but room was washed, stripped and waxed at my request and has been fairly well maintained			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
151	Temp	73.7	RH%	50.7	CO2	1060	Occupants:	32			
	DRAIN TRAPS IN THE CLASSROOM										
	Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None					
	GENERAL CLEANLINESS										
	Room is free of pests?				No pests observed at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
155	Temp	73.5	RH% 49.8	CO2 810	Occupants: 14		
AIR CONDITIONING							
	Air flowing from air supply?	Located output but not intake; cannot reach vents to test.		Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?	Located output but not intake; cannot reach vents to test.		Air flowing without obstruction at the time of assessments.	None		
ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?	Only allergies are to latex gloves; students may bring vinyl instead to remedy this.		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?	There is a periodic leak in the ceiling; it may have been fixed this year. A nearby tile was removed because of discoloration, and never replace (no dripping since, though.) One sink drain in room 155A has a leak; attempts to fix it have not been succe		No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	There is a periodic leak in the ceiling; it may have been fixed this year. A nearby tile was removed because of discoloration, and never replace (no dripping since, though.) One sink drain in room 155A has a leak; attempts to fix it have not been succe		No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	I am located in room 155, or room 206, depending on which set of room numbers are used. I am also reporting for room 155A, a prep area behind my classroom. Dust accumulates on top of cupboards and up high on walls.		There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
160	Temp	73.8	RH% 48.9	CO2 1097	Occupants:	21	
AIR CONDITIONING							
	Room is free of smell of chemicals?			No odor detected at the time of assessment.	None		
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?			Stained and soiled carpet.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of smell of vehicle exhaust?			No odor detected at the time of assessment.	None		
	Windows/doors are operable and are kept closed?			Windows and doors are operable and are kept closed.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	Classroom is free of animals and pets?			No animals identified at the time of assessment.	None		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	If not regularly used, toilets flushed once each week.			It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None		
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None		
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
160	Temp	73.8	RH% 48.9	CO2 1097	Occupants: 21		
	Cold water pipes free of continuous condensation?			No condensation on pipes at the time of assessment.	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No issues identified at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Carpet was stained and torn.	Install new tile floor.	Physical Plant Operations	1
	Food, if any, is stored in tightly sealed containers?			No unsealed food items were observed at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Room is free of the use of scented cleaners and air fresheners?			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None		
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		
LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			It appears that the ventilation system is adequate based on room activities.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None		
THERMAL COMFORT							
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No gaps in windows or doors identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
162	Temp	71.7	RH% 49.2	CO2 997	Occupants: 21		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	
GENERAL CLEANLINESS							
	Room is free of pests?				No pests observed at the time of assessment.	None	
163	Temp	72.6	RH% 49.6	CO2 1102	Occupants: 29		
AIR CONDITIONING							
	Air flowing from air supply?				I cannot check the air flow in the room. Vents are located in the ceiling and the ceiling is too high for me to check. But the air is comfortable in the room. The room smells when the carpet gets cleaned.	Air flowing without obstruction at the time of assessments.	None
	Room is free of smell of chemicals?				I cannot check the air flow in the room. Vents are located in the ceiling and the ceiling is too high for me to check. But the air is comfortable in the room. The room smells when the carpet gets cleaned.	No odor detected at the time of assessment.	None
	Room is free of smell of mold or mildew?				I cannot check the air flow in the room. Vents are located in the ceiling and the ceiling is too high for me to check. But the air is comfortable in the room. The room smells when the carpet gets cleaned.	Carpet stained and soiled.	Site based administration should address general cleanliness with facility serviceperson staff. Site Based 2
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
163	Temp	72.6	RH% 49.6	CO2 1102	Occupants: 29		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			What is meant by regular basis? daily, biweekly,weekly, etc. I do not keep food in the room. Some question I am not aware of such as air supply/return.	No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?			What is meant by regular basis? daily, biweekly,weekly, etc. I do not keep food in the room. Some question I am not aware of such as air supply/return.	There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?			What is meant by regular basis? daily, biweekly,weekly, etc. I do not keep food in the room. Some question I am not aware of such as air supply/return.	Remove carpet. Install tile floor.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
	Room is free of the use of scented cleaners and air fresheners?			What is meant by regular basis? daily, biweekly,weekly, etc. I do not keep food in the room. Some question I am not aware of such as air supply/return.	No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	
164	Temp	73.6	RH% 51.3	CO2 1441	Occupants: 21		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
172	Temp	73.4	RH% 46.8	CO2 948	Occupants: 4		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			At times air in classroom smells musty and stale. When I adjust the thermostat cooler it usually clears up with time.	No odor detected at the time of assessment.	None	
	EXCESS MOISTURE IN CLASSROOMS						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
172	Temp	73.4	RH% 46.8	CO2 948	Occupants: 4			
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	One ceiling tile has evidence of a roof leak.			No leaks or signs of water intrusion identified.	None		
	LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	No activities occur in classroom that would require the addition of an exhaust fan or fume hood.			Bathroom exhaust fan is functioning properly.	None		
		Faculty restroom in 200 administrative office may not have a functioning exhaust fan.						
173	Temp	71.6	RH% 47.0	CO2 800	Occupants: 4			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	thermostat has not functioned properly since the beginning of December. I have put in several requests but nothing has been corrected so far.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	thermostat has not functioned properly since the beginning of December. I have put in several requests but nothing has been corrected so far.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Walkthrough							
					Soiled and stained carpet. Install tile floor.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
174	Temp	73.7	RH% 46.9	CO2 1092	Occupants: 16		
AIR CONDITIONING							
	Air flowing from air supply?			Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of mold or mildew?			Stained and soiled carpet.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water run in sinks at least once per week (about 2 cups of water).		There is a sink in the closet between 222 and 223 that needs the drain cleaned.	It appears as though water is poured down the floor drain at least once a week.	None		
GENERAL CLEANLINESS							
	Room is free of pests?		Room 222 has old-stained carpet that is atrocious. About once a week, we have a visit from a roach or two - but there are so many stains on the carpet that we do not notice them right away! Please help!	No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		The air in room 222 is very sporadic. . .either very warm or very cold.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The air in room 222 is very sporadic. . .either very warm or very cold.	Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		The air in room 222 is very sporadic. . .either very warm or very cold.	No gaps in windows or doors identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
174	Temp	73.7	RH% 46.9	CO2 1092	Occupants: 16			
	Room is usually comfortable? (If no, please explain in the notes below.)	The air in room 222 is very sporadic. . .either very warm or very cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	The air in room 222 is very sporadic. . .either very warm or very cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Walkthrough				Soiled and stained carpet. Install tile floor.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
175	Temp	71.5	RH% 46.3	CO2 826	Occupants:			
	AIR CONDITIONING							
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?				Stained and soiled carpet	Install tile floor.	Physical Plant Operations	1
	LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None		
	THERMAL COMFORT							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
177	Temp	74.0	RH% 43.3	CO2 847	Occupants:		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Classroom lavatories/water fountains free of leaks?				No leaks or signs of water intrusion identified.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None		
191	Temp	73.8	RH% 55.4	CO2 1222	Occupants:	33	
AIR CONDITIONING							
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None		
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
201	Temp	72.7	RH% 53.8	CO2 1033	Occupants: 28		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None		
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
202	Temp	72.1	RH% 53.4	CO2 888	Occupants: 13		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
202	Temp	72.1	RH% 53.4	CO2 888	Occupants: 13		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.		None		
Walkthrough							
			Soiled and stained carpet. Install tile floor.		Physical Plant Operations to evaluate and repair as appropriate.		Physical Plant Operations 1
204	Temp	71.9	RH% 53.1	CO2 1006	Occupants: 26		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			Can not smell the mold or mildew all of the time		No odor detected at the time of assessment.		None
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		Site Based 3
DRAIN TRAPS IN THE CLASSROOM							
Water run in sinks at least once per week (about 2 cups of water).			It appears as though water is poured down the floor drain at least once a week.		None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Have requested sink in room to be cleaned since August.Still has not been scrubbed and paint removed from previous teacher who was in room. Counter tops dirty. Air supply has minimal dust on bottom openings. Floor has not been waxed since last school ye		No dust observed on supply/return registers at the time of assessment.		None
Classroom is dusted/vacuumed thoroughly and regularly?			Have requested sink in room to be cleaned since August.Still has not been scrubbed and paint removed from previous teacher who was in room. Counter tops dirty. Air supply has minimal dust on bottom openings. Floor has not been waxed since last school ye		There does not appear to be a dusting issue within this room.		None
Classrooms general appearance is clean and acceptable?			Have requested sink in room to be cleaned since August.Still has not been scrubbed and paint removed from previous teacher who was in room. Counter tops dirty. Air supply has minimal dust on bottom openings. Floor has not been waxed since last school ye		General cleanliness of the room at the time of assessment was acceptable.		None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
204	Temp	<input type="text" value="71.9"/>	RH% <input type="text" value="53.1"/>	CO2 <input type="text" value="1006"/>	Occupants: <input type="text" value="26"/>		
	Floor is cleaned on a regular basis?	Have requested sink in room to be cleaned since August. Still has not been scrubbed and paint removed from previous teacher who was in room. Counter tops dirty. Air supply has minimal dust on bottom openings. Floor has not been waxed since last school ye			Floor was clean at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	Have requested sink in room to be cleaned since August. Still has not been scrubbed and paint removed from previous teacher who was in room. Counter tops dirty. Air supply has minimal dust on bottom openings. Floor has not been waxed since last school ye			No issues identified relating to spill clean up practices at the time of assessment..	None	
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?	no bathroom in room			Bathroom exhaust fan is functioning properly.	None	
	THERMAL COMFORT						
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	
204A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?						
208	Temp	<input type="text" value="71.4"/>	RH% <input type="text" value="50.0"/>	CO2 <input type="text" value="880"/>	Occupants: <input type="text" value="27"/>		
	ANIMALS IN THE CLASSROOM						
	Classroom is free of animals and pets?	mouse (wild)			No pests observed at the time of assessment.	None	
	DRAIN TRAPS IN THE CLASSROOM						
	Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	mouse in room 2 days ago			No dust observed on supply/return registers at the time of assessment.	None	
	Room is free of pests?	mouse in room 2 days ago			No pests observed at the time of assessment.	None	
	THERMAL COMFORT						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
208	Temp	71.4	RH% 50.0	CO2 880	Occupants: 27		
	Classroom is free of significant temperature shifts?		students complain its too cold, thermostate does not control room temperature	Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)		students complain its too cold, thermostate does not control room temperature	Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?		students complain its too cold, thermostate does not control room temperature	Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
210	Temp	65.6	RH% 57.3	CO2 592	Occupants: 14		
AIR CONDITIONING							
	Air is flowing without obstruction?		Questions a and b are N/A	Air flowing without obstruction at the time of assessments.	None		
	Windows/doors are operable and are kept closed?		Questions a and b are N/A	Windows and doors are operable and are kept closed.	None		
DRAIN TRAPS IN THE CLASSROOM							
	Water run in sinks at least once per week (about 2 cups of water).		The sink is not neccessary for TV production.	It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?		The air conditioning is broken in Television Production Room 316 (210). It is extremely cold in the classroom. Some days it hard to for me and the students to focus.	There does not appear to be a dusting issue within this room.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?		N/A for this section, no bathroom	Bathroom exhaust fan is functioning properly.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)		N/A for this section, no bathroom	It appears that the ventilation system is adequate based on room activities.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		N/A for this section, no bathroom	It appears that the ventilation system is adequate based on room activities.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?		N/A for this section, no bathroom	Exhaust fan is functioning properly.	None		
THERMAL COMFORT							
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		It is really cold in the classroom. The thermostat has been broken for nearly two years.	Humidity was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
210	Temp	65.6	RH%	57.3	CO2	592	Occupants:	14			
	Room is usually comfortable? (If no, please explain in the notes below.)	It is really cold in the classroom. The thermostat has been broken for nearly two years.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based		2		
	Temperature in my classroom is generally comfortable (72F-76F)?	It is really cold in the classroom. The thermostat has been broken for nearly two years.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based		2		
211	Temp	68.3	RH%	60.1	CO2	669	Occupants:	3			
	DRAIN TRAPS IN THE CLASSROOM										
	Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None					
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None					
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None					
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None					
	LOCAL EXHAUST FANS										
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	How do I know if bathroom exhaust fan is working? No n/a here!			It appears that the ventilation system is adequate based on room activities.	None					
212	Temp	70.1	RH%	64.5	CO2	724	Occupants:	27			
	DRAIN TRAPS IN THE CLASSROOM										
	Water poured down floor drains once per week (approx. 1 quart of water).	Floor drain backs up raw sewage. Last year about 3 occasions. This year once. Flooding about 300 square feet room area. had to leave with students to another room. Wash out sinks do not work. Work orders in place two years.			It appears as though water is poured down the floor drain at least once a week.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

215

Temp RH% CO2

Occupants:

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks or signs of water intrusion identified.

None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

None

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

Floor is cleaned on a regular basis?

Remove stained and soiled carpet. Replace with tile floor

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

2

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

Bathroom exhaust fan is functioning properly.

None

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Tends to be very cold during the first half of the day

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Temperature in my classroom is generally comfortable (72F-76F)?

Tends to be very cold during the first half of the day

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

218

Temp RH% CO2

Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

Room is direct walkthrough to clinic bathrooms. It is used by handicapped students and all teachers who teach in the 200 building.

No odor detected at the time of assessment.

None

Windows/doors are operable and are kept closed?

Room is direct walkthrough to clinic bathrooms. It is used by handicapped students and all teachers who teach in the 200 building.

Windows and doors are operable and are kept closed.

None

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
218	Temp	73.6	RH% 45.7	CO2 943	Occupants: 4		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
219	Temp	72.7	RH% 45.0	CO2 847	Occupants: 3		
	AIR CONDITIONING						
	Room is free of smell of kitchen/food?		Odors from 200 planning (room in back of mine) seep into my class at times	No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Room is free of pests?		roaches have been seen in the class today (1/21/05) & last week	No pests observed at the time of assessment.	None		
220	Temp	72.3	RH% 43.8	CO2 879	Occupants: 4		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?		At times a stale smell. Smell will usually clear itself once AC thermostat is adjusted.	Stained and soiled carpet.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		One ceiling tile has evidence of water (stained)leak.	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?		I do not need a local exhaust fan or fume hood for classroom activities.	Bathroom exhaust fan is functioning properly.	None		
			Faculty restroom located in 200 office does not seem to have an exhaust fan.				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
230	Temp	74.6	RH% 49.3	CO2 600	Occupants:		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	If not regularly used, toilets flushed once each week.			It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None		
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None		
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			The gym, upstairs gym/wt.rm, locker rooms seems to be the last that is attended to, especially after a game or sporting event.P.E. teachers are left to clean up the next morning.	No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?			The gym, upstairs gym/wt.rm, locker rooms seems to be the last that is attended to, especially after a game or sporting event.P.E. teachers are left to clean up the next morning.	There does not appear to be a dusting issue within this room.	None	
	Classrooms general appearance is clean and acceptable?			The gym, upstairs gym/wt.rm, locker rooms seems to be the last that is attended to, especially after a game or sporting event.P.E. teachers are left to clean up the next morning.	General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?			The gym, upstairs gym/wt.rm, locker rooms seems to be the last that is attended to, especially after a game or sporting event.P.E. teachers are left to clean up the next morning.	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
230	Temp	74.6	RH% 49.3	CO2 600	Occupants:			
	Room is free of pests?	The gym, upstairs gym/wt.rm, locker rooms seems to be the last that is attended to, especially after a game or sporting event.P.E. teachers are left to clean up the next morning.			No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	The gym, upstairs gym/wt.rm, locker rooms seems to be the last that is attended to, especially after a game or sporting event.P.E. teachers are left to clean up the next morning.			No issues identified relating to spill clean up practices at the time of assessment..	None		
	Trash is removed daily and trash bags are changed as appropriate?	The gym, upstairs gym/wt.rm, locker rooms seems to be the last that is attended to, especially after a game or sporting event.P.E. teachers are left to clean up the next morning.			No issues identified regarding trash removal practices.	None		
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None		
LOCKER ROOM								
	Locker room and showers cleaned regularly and properly?				Issues not applicable. Room is not a locker room.	None		
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
237	Temp	76.2	RH% 58.9	CO2 778	Occupants:	5		
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS								
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
237	Temp	76.2	RH%	58.9	CO2	778	Occupants:	5			
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None						
	Room is free of pests?			No pests observed at the time of assessment.	None						
277	Temp	75.3	RH%	50.7	CO2	1942	Occupants:	22			
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None						
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None						
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None						
	Room is free of pests?			No pests observed at the time of assessment.	None						
280A	Temp	75.8	RH%	56.2	CO2	515	Occupants:				
	AIR CONDITIONING										
	Windows/doors are operable and are kept closed?			Windows and doors are operable and are kept closed.	None						
	EXCESS MOISTURE IN CLASSROOMS										
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None						
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
280A	Temp	75.8	RH% 56.2	CO2 515	Occupants:		
	Room is free of pests?				No pests observed at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	
301	Temp	75.7	RH% 48.1	CO2 805	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				Carpet soiled and stained.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	EXCESS MOISTURE IN CLASSROOMS						
	Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
	Indoor surfaces of exterior walls free of continuous condensation?				No condensation at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				There is a leak in the ceiling that has not been fixed in years. Water comes in and with it mold.	No dust observed on supply/return registers at the time of assessment.	None
	Room is free of pests?				There is a leak in the ceiling that has not been fixed in years. Water comes in and with it mold.	No pests observed at the time of assessment.	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
301	Temp	75.7	RH% 48.1	CO2 805	Occupants:		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			There is a leak in the ceiling that has not been fixed in years. Water comes in and with it mold.	No issues identified relating to spill clean up practices at the time of assessment..	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Room 301 is fine but many rooms such as room 311 and room 316/317 have temperatures less than 65 degrees	Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)			Room 301 is fine but many rooms such as room 311 and room 316/317 have temperatures less than 65 degrees	Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?			Room 301 is fine but many rooms such as room 311 and room 316/317 have temperatures less than 65 degrees	Temperature was acceptable at the time of assessment.	None	
434C	Temp	80.1	RH% 62.5	CO2 1096	Occupants:		
AIR CONDITIONING							
	Air flowing from air supply?				No odor detected at the time of assessment.	None	
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None	
	Room is free of smell of chemicals?				No odor detected at the time of assessment.	None	
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None	
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
434C	Temp	80.1	RH% 62.5	CO2 1096	Occupants:		
	Indoor surfaces of exterior walls free of continuous condensation?				No condensation at the time of assessment.	None	
	Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	Food, if any, is stored in tightly sealed containers?				No unsealed food items were observed at the time of assessment.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	
LOCKER ROOM							
	Soiled clothes and towels are removed regularly?				Issues not applicable. Room is not a locker room.	None	
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
434C	Temp	80.1	RH% 62.5	CO2 1096	Occupants:		
Classroom is free of significant temperature shifts?			air conditioner are so loud one cannot run them and hear/speak. They must be off to teach.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	1
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			air conditioner are so loud one cannot run them and hear/speak. They must be off to teach.	Humidity was acceptable at the time of assessment.	None		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			air conditioner are so loud one cannot run them and hear/speak. They must be off to teach.	No gaps in windows or doors identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			air conditioner are so loud one cannot run them and hear/speak. They must be off to teach.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?			air conditioner are so loud one cannot run them and hear/speak. They must be off to teach.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
456C	Temp	70.6	RH% 44.5	CO2 967	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			I am in a portable.	No odor detected at the time of assessment.	None		
Room is free of smell of vehicle exhaust?			I am in a portable.	No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
456C	Temp	70.6	RH% 44.5	CO2 967	Occupants:		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None		
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		
THERMAL COMFORT							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No gaps in windows or doors identified at the time of assessment.	None		

531 Temp 76.3 RH% 67.5 CO2 890 Occupants: 18

ANIMALS IN THE CLASSROOM

Classroom is free of animals and pets?

No animals identified at the time of assessment. None

GENERAL CLEANLINESS

Room is free of pests?

No pests observed at the time of assessment. None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
535	Temp	77.0	RH% 65.3	CO2 993	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
Classroom lavatories/water fountains free of leaks?				No leaks or signs of water intrusion identified.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		Air continually shuts off. Kept temperature in room when this happens (frequently) and it was 80 degrees. One day, during the spring (this has been going on since the new building has been constructed) it reached up to 83 degrees.		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Air continually shuts off. Kept temperature in room when this happens (frequently) and it was 80 degrees. One day, during the spring (this has been going on since the new building has been constructed) it reached up to 83 degrees.		Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Air continually shuts off. Kept temperature in room when this happens (frequently) and it was 80 degrees. One day, during the spring (this has been going on since the new building has been constructed) it reached up to 83 degrees.		No gaps in windows or doors identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		Air continually shuts off. Kept temperature in room when this happens (frequently) and it was 80 degrees. One day, during the spring (this has been going on since the new building has been constructed) it reached up to 83 degrees.		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?		Air continually shuts off. Kept temperature in room when this happens (frequently) and it was 80 degrees. One day, during the spring (this has been going on since the new building has been constructed) it reached up to 83 degrees.		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
542A	Temp	77.2	RH% 64.1	CO2 995	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
If not regularly used, toilets flushed once each week.				It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None		
Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None		
Water run in sinks at least once per week (about 2 cups of water).				It appears as though water is poured down the floor drain at least once a week.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
544	Temp	78.8	RH% 62.7	CO2 960	Occupants:	27	
AIR CONDITIONING							
Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None		
Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
544	Temp	78.8	RH% 62.7	CO2 960	Occupants: 27			
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None			
Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.		None			
Room is free of pests?			No pests observed at the time of assessment.		None			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?			There is no air conditioning coming into our room. When maintenance comes to check it, they say its flowing. If it is, its barely there. It gets close to 95 degrees in here during the very hot months. Especially when there are 30 kids packed in here.		Temperature was elevated at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			There is no air conditioning coming into our room. When maintenance comes to check it, they say its flowing. If it is, its barely there. It gets close to 95 degrees in here during the very hot months. Especially when there are 30 kids packed in here.		Humidity was acceptable at the time of assessment.		None	
Room is usually comfortable? (If no, please explain in the notes below.)			There is no air conditioning coming into our room. When maintenance comes to check it, they say its flowing. If it is, its barely there. It gets close to 95 degrees in here during the very hot months. Especially when there are 30 kids packed in here.		Temperature was elevated at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	
Temperature in my classroom is generally comfortable (72F-76F)?			There is no air conditioning coming into our room. When maintenance comes to check it, they say its flowing. If it is, its barely there. It gets close to 95 degrees in here during the very hot months. Especially when there are 30 kids packed in here.		Temperature was elevated at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	

545 Temp 75.6 RH% 64.1 CO2 863 Occupants: 22

THERMAL COMFORT

Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment. None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
548	Temp	76.0	RH% 63.5	CO2 650	Occupants:		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
560	Temp	77.5	RH% 61.2	CO2 928	Occupants:	19	
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		electrical outlets do not work (half of the room only) request in but it has been 6 months	No dust observed on supply/return registers at the time of assessment.	None		
	Room is free of pests?		electrical outlets do not work (half of the room only) request in but it has been 6 months	No pests observed at the time of assessment.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
572	Temp	78.8	RH% 62.9	CO2 1022	Occupants:		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Food, if any, is stored in tightly sealed containers?				No unsealed food items were observed at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	3
574	Temp	79.5	RH% 62.3	CO2 1147	Occupants:	25	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None		
Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
GENERAL CLEANLINESS							
Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
574	Temp	79.5	RH% 62.3	CO2 1147	Occupants: 25		
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	3
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
578	Temp	77.8	RH% 58.9	CO2 904	Occupants:		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of drains with facility serviceperson staff.	Site Based	2
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None		
	Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
618C	Temp	<input type="text" value="82.3"/>	RH% <input type="text" value="69.0"/>	CO2 <input type="text" value="903"/>	Occupants: <input type="text" value="22"/>			
AIR CONDITIONING								
Room is free of smell of mold or mildew?					No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM								
You are informed about the potential allergies of your students?					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Physical Plant Operations	2
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None		
THERMAL COMFORT								
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)					Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
624C	Temp	<input type="text" value="75.9"/>	RH% <input type="text" value="46.3"/>	CO2 <input type="text" value="2009"/>	Occupants: <input type="text"/>			
AIR CONDITIONING								
Windows/doors are operable and are kept closed?					Windows and doors are operable and are kept closed.	None		
680C	Temp	<input type="text" value="71.3"/>	RH% <input type="text" value="53.2"/>	CO2 <input type="text" value="2499"/>	Occupants: <input type="text"/>			
EXCESS MOISTURE IN CLASSROOMS								
Indoor surfaces of exterior walls free of continuous condensation?					No condensation at the time of assessment.	None		
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?					Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCKER ROOM								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
680C	Temp	71.3	RH% 53.2	CO2 2499	Occupants: <input type="text"/>		
	Locker room and showers cleaned regularly and properly?				Issues not applicable. Room is not a locker room.	None	
905C	Temp	75.1	RH% 52.9	CO2 2817	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Air flowing from air supply?		A.C. filters and units need to be clean		Air flowing without obstruction at the time of assessments.	None	
	Windows/doors are operable and are kept closed?		A.C. filters and units need to be clean		Windows and doors are operable and are kept closed.	None	
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		rust on light panels		No leaks or signs of water intrusion identified.	None	
	Windows, windowsills and window frames free of continuous condensation?		rust on light panels		No condensation on windows at the time of assessment.	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		A.C. filters and unit needs to be cleaned. Trash bags need to be changed when trash is emptied.		Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?		A.C. filters and unit needs to be cleaned. Trash bags need to be changed when trash is emptied.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?		A.C. filters and unit needs to be cleaned. Trash bags need to be changed when trash is emptied.		Floor was clean at the time of assessment.	None	
	Trash is removed daily and trash bags are changed as appropriate?		A.C. filters and unit needs to be cleaned. Trash bags need to be changed when trash is emptied.		No issues identified regarding trash removal practices.	None	
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
905C	Temp	<input type="text" value="75.1"/>	RH% <input type="text" value="52.9"/>	CO2 <input type="text" value="2817"/>	Occupants: <input type="text"/>		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No gaps in windows or doors identified at the time of assessment.	None		
991T	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		The lockerroom and coaches office is a mess. Roaches run rampant. Toilets are not cleaned on a thri-daily basis - which is needed. It is trash filled and smells.		No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?		The lockerroom and coaches office is a mess. Roaches run rampant. Toilets are not cleaned on a thri-daily basis - which is needed. It is trash filled and smells.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classrooms general appearance is clean and acceptable?		The lockerroom and coaches office is a mess. Roaches run rampant. Toilets are not cleaned on a thri-daily basis - which is needed. It is trash filled and smells.		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?		The lockerroom and coaches office is a mess. Roaches run rampant. Toilets are not cleaned on a thri-daily basis - which is needed. It is trash filled and smells.		Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 1
	Room is free of the use of scented cleaners and air fresheners?		The lockerroom and coaches office is a mess. Roaches run rampant. Toilets are not cleaned on a thri-daily basis - which is needed. It is trash filled and smells.		No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?		The lockerroom and coaches office is a mess. Roaches run rampant. Toilets are not cleaned on a thri-daily basis - which is needed. It is trash filled and smells.		No issues identified relating to spill clean up practices at the time of assessment..	None	
	Trash is removed daily and trash bags are changed as appropriate?		The lockerroom and coaches office is a mess. Roaches run rampant. Toilets are not cleaned on a thri-daily basis - which is needed. It is trash filled and smells.		There appears to be an issue regarding daily trash removal practices.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2