

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
113	75.2	52%	1728	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Cleanliness	Confirm that the office area is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 52% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	Check comfort factors.	Environmental parameters were generally within acceptable ranges. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
116	74	52%	1535	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There was evidence of a roof leak. Occupant indicated leak has been corrected.	Location should replace the affected ceiling tile and monitor area to ensure roof repair is effective.
	General Classroom Information	Environmental Parameters	There were 17 occupants in the classroom at the time of the assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
122	75.2	51%	2052	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		0 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
Maintain Student Health Records	Track health-related complaints by students and staff.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.

125

75.6	51%	2417
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		1 occupant in classroom at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
General Cleanliness	Check for pests.	There were no pests observed on the date of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Overall, the general cleanliness appeared adequate on the date of assessment. The flooring system appeared in need of cleaning.	It is recommended the custodial staff thoroughly clean the flooring system in this room.

134

72	52%	1842
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
-------------------------------	--	--	--

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	Teacher occupant reported there have been roaches in her classroom; however, not recently.	Location should monitor situation and initiate a workorder in the event pest problem reoccurs.
Thermal Comfort	General items to watch for.	The teacher occupant indicated there are temperature fluctuations throughout the day in this classroom. On the date of assessment, the temperature was within acceptable range.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	There was no apparent problem with the ventilation in this classroom on the date of the assessment.	No corrective action recommended at this time.

166

75.8	49%	2537
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
General Classroom Information		32 occupants in classroom at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Teacher reported that there are roaches in the classroom at least once per month.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
General Classroom Information		Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces. Teacher reported floor is only cleaned three times per year.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.

171

75.1	52%	1855
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
172	General Classroom Information		There were 13 occupants at the time of assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	Teacher reported students spill soda and it is cleaned later in the day.	No corrective action recommended at this time.
	76.9	54%	2456	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
173	General Classroom Information		Ants were observed on date of assessment.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
	General Classroom Information		There were 27 occupants at the time of assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	Floor is swept but not washed regularly. Room is not dusted unless I do it.			
	71.8	51%	1708	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		There were 31 occupants at the time of assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
		The floors in my room are not swept thoroughly and if the trash is not on the floor often times it is not removed.		

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
174	74.7 <i>Temp</i>	54% <i>RH</i>	2327 <i>Co2</i>	
	General Classroom Information		There were 15 occupants at the time of assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was elevated	Maintenance to inspect and repair as appropriate to lower Co2 level.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Teacher reported that there is no heat for cold days and has to turn off the A/C unit to control temperature.	Maintenance needs to inspect HVAC for proper operation.
	There is no heat in this room and the room is supplied with a steady stream of cold air.			
176	72.9 <i>Temp</i>	53 <i>RH</i>	2376 <i>Co2</i>	
	General Classroom Information		There were 25 occupants at the time of assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Cleanliness	Confirm that the classroom is cleaned properly	There was excessive dust accumulation on the floor on the date of the assessment.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	General Cleanliness	Check for pests.	No pests were observed in the classroom on the date of assessment. Teacher indicates she is spraying RAID in the classroom on Fridays.	Teacher should be advised utilizing unapproved chemicals in the classroom is prohibited. In the event there is a pest issue, the location should initiate a work order to address the issue.
177	74 <i>Temp</i>	52% <i>RH</i>	1267 <i>Co2</i>	
	General Classroom Information		10 occupants in classroom at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
178A	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
		Overall our school maintains a clean work place.		
		72.2	53%	1487
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
178B	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	Sink was "burping" sewer gas. Occupant is now aware that water needs to be run. Hasn't been a problem.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	Occupant indicates condensation appears on glass in early morning when it is hot and humid outside. Environmental parameters were within acceptable ranges on date of assessment.	No corrective action recommended at this time.
	General Classroom Information		34 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Walls near return grill are dirty. Occupant alleges spotting is mold.	Wipe down walls with wexide.
		There is a lot of dust and debris on the return vents into the classroom from the ceiling. Dust also collects high up on the wall under the air return vents.		
		72.9	52%	1371
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
		Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	Teacher reported there is condensation on windows when it is hot outside.
	General Classroom Information		24 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
178P			
	74	52%	1815
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		There were 25 occupants at the time of assessment. Teacher was not present. Environmental parameters were generally within acceptable ranges. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
178S			
	74.3	52%	1880
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
General Classroom Information		There were 21 occupants at the time of assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
General Classroom Information		Stained ceiling tile on northeast wall.	Maintenance to inspect for leak and repair as appropriate and replace ceiling tiles.
General Cleanliness	Check for pests.	Ants were identified and are really bad in this wing.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
187	73.6 <i>Temp</i>	52% <i>RH</i>	1350 <i>Co2</i>	
	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Health Officer's Office	Ensure that the ventilation system is properly operating.	Ventilation is working properly.	No corrective action recommended at this time.
188	73.6 <i>Temp</i>	52% <i>RH</i>	1355 <i>Co2</i>	
	General Classroom Information		0 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.		Site based administration will provide information to site based staff.
	Health and Hygiene Education	Provide information about IAQ and health.		Site based administration will provide information to site based staff.
	Health Officer's Office	Ensure that the ventilation system is properly operating.	Ventilation is working properly.	No corrective action recommended at this time.
	heath	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		Site based administration will provide information to site based staff.
	The air in my classroom (188) is sometimes stale and makes my eyes water especially in the afternoon. I have problems breathing when I enter the classroom in the am until I leave in the pm. During my working hours I am not able to fill my lungs to capacity and have a wheezing sound in my chest. This is less severe after I leave school in the afternoon.			
192	73.4 <i>Temp</i>	52% <i>RH</i>	1624 <i>Co2</i>	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Classroom Information		There were no occupants at the time of assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
General Classroom Information		Signs of water intrusion identified.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		Site based administration will provide information to site based staff.
Health and Hygiene Education	Establish an information and counseling program regarding smoking.		Site based administration will provide information to site based staff.
<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around; align-items: center;"> <div style="border: 1px solid black; padding: 2px 10px;">72.7</div> <div style="border: 1px solid black; padding: 2px 10px;">53%</div> <div style="border: 1px solid black; padding: 2px 10px;">1542</div> </div> <div style="display: flex; justify-content: space-around; margin-top: 5px;"> <i>Temp</i> <i>RH</i> <i>Co2</i> </div>			
General Classroom Information		There were 3 occupants at the time of assessment. Environmental parameters were generally within acceptable ranges. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 53% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Teacher reported room becomes warmer in later part of day.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	Determine how your classroom is ventilated.	Dust was observed on the return registers at the time of the assessment.	Custodial staff should clean and sanitize the return registers in this classroom.
<div style="border: 1px solid black; width: 100%; height: 20px; margin-top: 10px;"></div>			

198

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
199	73.1 <i>Temp</i>	53% <i>RH</i>	1027 <i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		0 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
203	71.5 <i>Temp</i>	55% <i>RH</i>	1327 <i>Co2</i>	
	General Classroom Information		23 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	There is a cooking class next door and if they burn something the odor comes into the room.	No corrective action recommended at this time.
231	72.4 <i>Temp</i>	51% <i>RH</i>	976 <i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Mold was identified on corkboard behind teacher desk. Reported frequent leaks. Light lense has signs of water intrusion. Water damage to wall near windows.	Maintenance to inspect for leaks and repair as appropriate.
	General Cleanliness	Check for pests.	Ants were observed at time of assessment.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
	General Cleanliness	Confirm that the classroom is cleaned properly	Food items on floor. Baseboard missing on east wall.	Site to remove food items. Maintenance to replace baseboard.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Dust and debris was observed on the air supply and return registers and closet systems at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.

There is a problem with mold throughout the building (rooms 233, 232, 231). The quality of the air needs to be checked as one teacher is reporting increased allergy problems.

232

73.4	54%	886
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Signs of water intrusion on southeast wall. Repairs that were done on northeast wall are becoming wet again. Corkboard needs to be removed.	Maintenance to inspect for leaks and repair as appropriate and remove corkboard.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. However, supply vents were full of dust.	Custodial staff should clean and sanitize the air supply vents in this classroom.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 54% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
285	<div style="border: 1px solid black; padding: 5px;"> Water seeps in under the doors and "sits" until it evaporates. Bugs enter from under the doors and feed on paper and some supplies. Dust accumulates under the tables, teacher work stations and around the baseboards and needs to be swept daily. I am concerned with mold in the walls and air passages. </div>		
	75.5	43%	631
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Moisture, Leaks, and Spills	Inspect the building for signs of moisture, leaks, or spills.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Moisture, Leaks, and Spills	Look for signs of water damage.	There were signs of previous water intrusion. Part of ceiling and flooring has been patched.	Monitor the effectiveness of repairs.
4N	<div style="border: 1px solid black; padding: 5px;"> Moisture part was put in because we do have a bad roof that leaks a lot, we call maintenance each time they try to patch, and hten change out stained ceiling tiles afterward. </div>		
	78.6	47%	1472
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
General Classroom Information		1 occupant in classroom at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 47% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
714	<div style="border: 1px solid black; height: 20px; width: 100%;"></div>		
	74.9	51%	1340
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Signs of water intrusion. Apparent leak of chilled water line has been repaired. Ceiling tiles are stained.	Install new ceiling tiles.
General Classroom Information		27 occupants in classroom at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Flooring appeared dirty.	Clean and sanitize flooring.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ceiling tiles have fallen down due to what appears to be excessive moisture.			
723	76 <i>Temp</i>	49% <i>RH</i>	1150 <i>Co2</i>
General Classroom Information		29 occupants in classroom at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. However, flooring was dusty.	Clean and sanitize flooring.
724	72.9 <i>Temp</i>	50% <i>RH</i>	1082 <i>Co2</i>
General Classroom Information		29 occupants in classroom at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Teacher reported the room is generally too cold. Temperature was within recommended range.	No corrective action recommended at this time.
General Classroom Information		Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		Site based administration will provide information to site based staff.
Health and Hygiene Education	Provide information about IAQ and health.		Site based administration will provide information to site based staff.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
729	74.8 <i>Temp</i>	55% <i>RH</i>	1156 <i>Co2</i>	
	General Classroom Information		24 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
743	75.4 <i>Temp</i>	49% <i>RH</i>	1118 <i>Co2</i>	
	General Classroom Information		23 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
755	74.5 <i>Temp</i>	42% <i>RH</i>	978 <i>Co2</i>	
	General Classroom Information		24 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces. Teacher advised brings in unauthorized cleaning supplies.	Custodial staff should thoroughly clean all environmental surfaces within classroom.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>		
93C	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment. Teacher advised students had previously complained about odors but have had no complaints recently.	No corrective action recommended at this time.	
		78.4	53%	1917	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
Cafeteria	Thermal Comfort	Humidity level.	The humidity was 53% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.	
	Thermal Comfort	General items to watch for.	Temperature was within range at time of assessment. Teacher feels that A/C is not functioning optimally. The Co2 reading was slightly elevated; however, it is not at a level warranting follow-up action.	Maintenance needs to inspect HVAC for proper operation.	
		My classroom is a portable and the outside of it is GREEN. Many of the students and the staff that work in this portable have a cough that does not go away.			
		69.8	47%	568	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
Portable 29	General Cleanliness	Confirm that the classroom is cleaned properly	Teacher reported that there have been incidents where the trash cans have not been cleaned out and the bathrooms are not being cleaned in a timely manner.	Custodial staff should clean trash cans and bathrooms regularly and in a timely manner.	
	General Cleanliness	Clean spills promptly.	Teacher reported that floors are not being mopped.	Clean spills in a timely manner and clean and sanitize flooring.	
		79.2	48%	1440	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Classroom Information		General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Classroom Information		Stained ceiling tile.	Install new ceiling tiles.
Health and Hygiene Education	Establish an information and counseling program regarding smoking.	Teacher indicated he identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
Health Officer's Office	Ensure that the ventilation system is properly operating.	Teacher indicated he identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.	Teacher indicated he identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
Maintain Student Health Records	Track health-related complaints by students and staff.	Teacher indicated he identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
<hr/>			
Portables	<input type="text"/>	<input type="text"/>	
	<input type="text"/>	<input type="text"/>	<input type="text"/>
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	General Cleanliness	Check for pests.	Teacher floats to various portables.
Thermal Comfort	General items to watch for.	Teacher floats to various portables.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	Teacher floats to various portables.	No corrective action recommended at this time.
<hr/>			