

Jeffrey S. Moquin, Director
Risk Management Department

Telephone: 754-321-3200
Facsimile: 754-321-3290

September 6, 2006

Signature on File

TO: Dr. David Basile, Principal
South Plantation High School

FROM: Kenneth I. Partee, Project Manager Occupational Health and Environmental Control
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 146C

On August 22, 2006 I conducted an assessment of FISH 146C at **South Plantation High School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Verda Farrow, Area Superintendent
Michaelle Pope, Area Director
Jeffrey S. Moquin, Director, Risk Management
Wayne Thrasher, Project Manager, Facilities and Construction Management
Ralph Eckhardt, Broward Teachers Union
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

KP/tc
Enc.

IAQ Assessment

Location Number

South Plantation High School

Evaluation Requested

Time of Day

Evaluation Date

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="146C"/>	<input type="text" value="75.6"/>	<input type="text" value="72 - 78"/>	<input type="text" value="57.2"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="541"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="3"/>
Noticeable Odor		<input type="text" value="No"/>	Visible water damage / staining?		Visible microbial growth?		Amount of material affected
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Plaster/Homasote"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
HVAC Return Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>

Observations

Findings:

- A/C filter was clogged at the time of the assessment and was changed immediately
- Dust and debris on HVAC supply and return grills
- Minor dust build up on environmental surfaces
- A/C unit was not set to fresh air at the time of the assessment. Switched over to fresh air.
- Non-approved chemicals in room (air fresheners)
- Area is under construction and there is dust accumulating from the construction project

Recommendations:

Site Based Maintenance:

- Ensure that A/C filters are changed regularly
- Clean HVAC supply and return grills with Wexcide disinfectant solution
- Clean environmental surfaces throughout the room
- Ensure that A/C unit is set ot fresh air
- Remove non-approved chemicals from room (air fresheners)
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate