

Taravella High

Outdoor Parameter Measurements:

WalkthroughDate: 5/27/2004

Temp

RH

Co2

83

55%

435

Category	Detail	Assessment Comments	Recommended Corrective Action
004	78.2 <i>Temp</i>	40% <i>RH</i>	3119 <i>Co2</i>
General Classroom Information		29 occupants in classroom at time of assessment.	
General Classroom Information		Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
I am good about cleaning and disinfecting the desks and other surface area; the floor in my room needs attention from the custodian.			
023	82.6 <i>Temp</i>	35% <i>RH</i>	4295 <i>Co2</i>
General Classroom Information		22 occupants in classroom at time of assessment.	
General Classroom Information		Co2 level was extremely elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
General Classroom Information		A/C vents and coils dirty.	Maintenance to inspect and repair as appropriate.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Flooring is dirty and cobwebs on the ceiling.	Clean and sanitize flooring and clean ceiling.
Locker Room	Maintain cleanliness and reduce excess moisture in the locker room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
12			
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Teacher declined survey walkthrough due to final exam.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	Teacher declined survey walkthrough due to final exam.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Teacher declined survey walkthrough due to final exam.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	Teacher declined survey walkthrough due to final exam.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	Teacher declined survey walkthrough due to final exam.	No corrective action recommended at this time.
Seems to be some moisture in the walls. There is no odor or any issues, just think there might be some excess moisture.			

203

72.4	49%	1675
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Dust and debris was observed on the return registers at the time of the assessment.	Custodial staff should clean and sanitize the return registers in this classroom.

Our classrooms are freezing. I also feel that there is a lot of mold and mildew in the air ducts at our school. I believe that our entire school should be checked for air quality in each classroom and have all the ducts cleaned. People are always getting sick.

204

74	45%	1417
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
General Classroom Information		Minor dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Two air supply and two return air grills.	No corrective action recommended at this time.

I like a chilly room, but mine is getting downright cold this year. I've had to wear 2 sweaters and actually need gloves on some days. What happened to the pleasant temps of the last few year -- chilly enough for comfort and to keep the kids awake without us sweating to death????

206

73.3	51%	1911
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information

Co2 level was slightly elevated at time of assessment.

Maintenance to inspect and repair as appropriate to lower Co2 level.

General Classroom Information

Dust and debris was observed on the air supply and return registers at the time of the assessment.

Custodial staff should clean and sanitize the air supply and return registers in this classroom.

General Cleanliness

Confirm that the classroom is cleaned properly

General cleanliness appeared adequate on date of assessment.

No corrective action recommended at this time.

The general cleanliness of my classroom could be improved. The floor needs to be mopped on a more regular basis. The room is utilized all day and again for night school. With the amount of traffic in and out of the room the floor is never clean.

212

74	50%	1759
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom

Take special care with asthmatic or other sensitive students.

No animals in the classroom.

No corrective action recommended at this time.

Excess Moisture in Classrooms

Check for leaks or signs of moisture from plumbing or roofs.

There were no problems observed at time of assessment.

No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Four air supply and one return air register grill.	No corrective action recommended at this time.
	Ventilation is poor. If students expose scents to the room (perfume, cologne, body sprays, etc.) the smell lingers all day and gives people headaches. Also, my room is full of dust. The root cause of many allergy attacks and sinus infections most likely.			
308	68.8	54%	1516	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Return air grill is not functioning properly.	Maintenance to inspect and repair as appropriate.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
312	63	52%	1541	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Room is extremely cold and Co2 level was slightly elevated at time of assessment.	Maintenance to check HVAC for proper operation and inspect and repair as appropriate to lower Co2 level.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	The air vents from the A/C are filthy.		

316

67.7	56	1411
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
General Classroom Information		Dirty ceiling tiles.	Install new ceiling tiles.
Locker Room	Verify that showers and other locker room areas are cleaned regularly and properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Room is too cold.	Check HVAC for proper operation.

320

69.3	55	1662
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	Water builds up and does not flow through the drain trap properly.	Maintenance to inspect and repair as appropriate.
General Classroom Information		Ceiling tiles are stained.	Install new ceiling tiles.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
322	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Teacher reported the room is generally too cold. Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level and check HVAC for proper operation.
		The offices and hallways around my room continue to be dirty. Kids leave their garbage (food and trash) on the floors in the hallway near my room. I have asked for help in getting my room and floors cleaned but nothing has been done.		
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
424	Art Supplies	Follow good safety, handling, and storage practices.		Site based administration will provide information to site based staff.
	General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Teacher reported the room is generally too cold.	Check HVAC for proper operation.
	Ventilation	Determine how your classroom is ventilated.	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	71.8	56%	1316	
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Return air grill is not functioning properly.	Maintenance to inspect and repair as appropriate.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
425					
		72	56%	1265	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Sink was dirty.	Clean sink area.	
	Thermal Comfort	Humidity level.	the humidity was 56% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.	
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.		
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.		
	I completed this survey for room 425 and the auditorium.				
426		70.1	56%	870	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There is bubbling and peeling on the west wall. Complaints of excess moisture in the wall.	Maintenance to inspect for leak and repair as appropriate and replace ceiling tiles.	
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.	
	General Cleanliness	Confirm that the classroom is cleaned properly	Ceiling tiles around air supply vents are dirty.	Clean ceiling tiles.	
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
Local Exhaust Fans	General items.	Exhaust fans are extremely dirty.	Clean exhaust fans.		

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
523	77.6 <i>Temp</i>	43% <i>RH</i>	1900 <i>Co2</i>	
	General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	Maintain Student Health Records	Track health-related complaints by students and staff.		Site based administration will provide information to site based staff.
525	76.1 <i>Temp</i>	44% <i>RH</i>	1978 <i>Co2</i>	
		I don't understand the answer choices very wel.		
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Three stained ceiling tiles.	Install new ceiling tiles.
	Thermal Comfort	Humidity level.	The humidity was 44% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
527	76.1 <i>Temp</i>	41% <i>RH</i>	1670 <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
533	77.2 <i>Temp</i>	47% <i>RH</i>	2008 <i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 47% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	Ventilation	Determine how your classroom is ventilated.	Four air supply and one return register.	No corrective action recommended at this time.
540	75.8 <i>Temp</i>	44% <i>RH</i>	2007 <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	Fish tank in classroom with baby shark.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
542	76.7 <i>Temp</i>	46% <i>RH</i>	2343 <i>Co2</i>	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>								
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.								
555	<div style="border: 1px solid black; width: 100%; height: 15px; margin-bottom: 5px;"></div> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="border: 1px solid black; width: 25%; text-align: center;">76.9</td> <td style="border: 1px solid black; width: 25%; text-align: center;">51%</td> <td style="border: 1px solid black; width: 25%; text-align: center;">1421</td> <td style="width: 25%;"></td> </tr> <tr> <td style="text-align: center;"><i>Temp</i></td> <td style="text-align: center;"><i>RH</i></td> <td style="text-align: center;"><i>Co2</i></td> <td></td> </tr> </table>	76.9	51%	1421		<i>Temp</i>	<i>RH</i>	<i>Co2</i>			
76.9	51%	1421									
<i>Temp</i>	<i>RH</i>	<i>Co2</i>									
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.								
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Signs of water damage/intrusion on the north wall. Drywall is bubbling.	Maintenance to inspect for leak and repair as appropriate and replace drywall.								
556	<div style="border: 1px solid black; width: 100%; height: 15px; margin-bottom: 5px;"></div> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="border: 1px solid black; width: 25%; text-align: center;">77.4</td> <td style="border: 1px solid black; width: 25%; text-align: center;">50%</td> <td style="border: 1px solid black; width: 25%; text-align: center;">1532</td> <td style="width: 25%;"></td> </tr> <tr> <td style="text-align: center;"><i>Temp</i></td> <td style="text-align: center;"><i>RH</i></td> <td style="text-align: center;"><i>Co2</i></td> <td></td> </tr> </table>	77.4	50%	1532		<i>Temp</i>	<i>RH</i>	<i>Co2</i>			
77.4	50%	1532									
<i>Temp</i>	<i>RH</i>	<i>Co2</i>									
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.								
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.								
557	<div style="border: 1px solid black; width: 100%; height: 15px; margin-bottom: 5px;"></div> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="border: 1px solid black; width: 25%; text-align: center;">76</td> <td style="border: 1px solid black; width: 25%; text-align: center;">50%</td> <td style="border: 1px solid black; width: 25%; text-align: center;">1402</td> <td style="width: 25%;"></td> </tr> <tr> <td style="text-align: center;"><i>Temp</i></td> <td style="text-align: center;"><i>RH</i></td> <td style="text-align: center;"><i>Co2</i></td> <td></td> </tr> </table>	76	50%	1402		<i>Temp</i>	<i>RH</i>	<i>Co2</i>		Room temperature changes for no reason -- Too Cold	
76	50%	1402									
<i>Temp</i>	<i>RH</i>	<i>Co2</i>									
General Classroom Information		Signs of water intrusion on north wall.	Maintenance to inspect for leak and repair as appropriate.								
General Classroom Information		One stained ceiling tile. Old roof leak has been repaired.	Install new ceiling tiles.								
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.								

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
558	76.3 <i>Temp</i>	51% <i>RH</i>	1771 <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 51% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Two air supply and one return air vent.	No corrective action recommended at this time.
	All the years here and the air conditioning cannot be regulated.			
561	71.9 <i>Temp</i>	57% <i>RH</i>	1338 <i>Co2</i>	
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Five air supply and two return air vents.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
		Exhaust from the kiln room next door blows through the vent into my room.		
562	71.5	57%	1359	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		25 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
565				
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Water intrusion on north wall and water damage.	Maintenance to inspect for leak and repair as appropriate.
	General Classroom Information		21 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Adjust thermostat to raise temperature slightly.	Adjust thermostat.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
567	69.5 <i>Temp</i>	58% <i>RH</i>	1443 <i>Co2</i>	
	General Classroom Information		26 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Ceiling tiles are dirty.	Install new ceiling tiles.
	General Classroom Information		Minor dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	Thermal Comfort	Humidity level.	The humidity was 58% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Room is too cold.	Adjust thermostat.
601	76.5 <i>Temp</i>	47% <i>RH</i>	1722 <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
604	76.7 <i>Temp</i>	47% <i>RH</i>	2009 <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	The room needs to be swept and dusted on a regular basis.			

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
605A	75.3 <i>Temp</i>	45% <i>RH</i>	1573 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 45% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.		
	Ventilation	Check for unexplained odors.	Air freshner in room.	Remove air freshner.
	High levels of Co2 have been found in my area in the past. Allergic reactions are significant when in this workplace.			
605B	74.2 <i>Temp</i>	44% <i>RH</i>	1556 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
609	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.	
		Co2 level remains far above acceptable limits.			
		73.9	47%	1542	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
610	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.	
	Thermal Comfort	Humidity level.	The humidity was 47% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.	
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.	
		Dust is a huge problem for allergies!!!! The temperature control tends to change from one extreme to another leading people to become sick.			
	75.5	44%	1779		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>		
611	General Classroom Information		22 occupants in classroom at time of assessment.	No corrective action recommended at this time.	
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.	
		73.2	47%	1624	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.	

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
612	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
		I have had bronchial problems since I have been in that room (1989). Many of my students also have been sick for long periods of time, when they have had no health problems before. I am concerned.		
		74.3	47%	1470
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
614	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
		My room is very cold and often dusty. Many students sneeze frequently.		
	76.3	47%	2009	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
617	General Classroom Information		3 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Dust was observed on the return registers at the time of the assessment.	Custodial staff should clean and sanitize the return registers in this classroom.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	Room is exceptionally cold whenever A/C is on.			
	74.7	45%	1830	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

702

74.7	49%	2685
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		30 occupants in classroom at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.

I think the A/C vents need to be cleaned. The room is generally dusty. It is swept every day but the traffic in the room results in a dusty film on the floor. I used a swiffer and the floor was really bad.

707

73.1	48%	2656
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		35 occupants in classroom at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

707 is ALWAYS cold - new record low this year: 58 on 9/2. Students say some teachers block their air vents. I would assume this makes the rest of us colder and creates some sort of air cleanliness problem. Some of us bring swiffers or brooms and sweep our own rooms at times.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
709	73.4 <i>Temp</i>	48% <i>RH</i>	2452 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		14 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 level was elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
710	73.8 <i>Temp</i>	49% <i>RH</i>	2258 <i>Co2</i>	
	General Classroom Information		2 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	Ventilation	Determine how your classroom is ventilated.	Three air supply and one return register grill.	No corrective action recommended at this time.
	There is too much dust in the school in general. Vents and A/C system need to be cleaned out.			
711	73.3 <i>Temp</i>	50% <i>RH</i>	2639 <i>Co2</i>	
	General Classroom Information		30 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
724		My room is often unswept for several days at a time. Trash is always emptied. Very dusty in this room.		
		74.2	56%	1518
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		27 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Locker Room	Verify that showers and other locker room areas are cleaned regularly and properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Five air supply and one return air grill.	No corrective action recommended at this time.
810		Leaks in shower stalls in girls locker room cause major mildew smell.		
		76.9	40%	946
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	General Classroom Information		34 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Leaking pipe within false ceiling plenum and stained ceiling tiles.	Maintenance to inspect for leak and repair as appropriate and replace ceiling tiles.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
811	73.3	43%	841	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		26 occupants in classroom at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.	
813	75.4	42%	821	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		22 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 43% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.	
822	73.5	46%	1131	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	Fish tanks found in classroom. Stagnant water in one of them because filtration is not working.	Clean fish tanks.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		29 occupants in classroom at time of assessment.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies	Learn about your supplies.		Site based administration will provide information to site based staff.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 46% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Minor dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
<p>There are numerous water spots on my ceiling next to the A/C vents. The temperature is way below what it is supposed to be. Eric Althouse from the Department of Education has tried unsuccessfully to get Jeff Moquin to do something about it but his efforts have been futile. I now have asthma because of the poor environmental conditions at our school. Please contact me at your convenience as I would like to talk to you about this more in detail. 954-344-2300 at work or at 561-487-8063 at home. Thank you.</p>			
835	73	45%	994
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		27 occupants in classroom at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
838	73.36 <i>Temp</i>	48% <i>RH</i>	1006 <i>Co2</i>	
	General Classroom Information		24 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
	Our school is so cold that students and teachers are VERY uncomfortable and the students have constant complaints because they have a hard time concentrating when they are worried about just keeping warm.			
839	72.5 <i>Temp</i>	46% <i>RH</i>	914 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		19 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	Students leave half eaten lunches all over the school.			
847	72.9 <i>Temp</i>	47% <i>RH</i>	988 <i>Co2</i>	
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	the humidity was 47% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
901	75.2 <i>Temp</i>	53% <i>RH</i>	1082 <i>Co2</i>	
	General Classroom Information		32 occupants in classroom at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Minor dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Waxing to be done on a schedule with the rest of the school? Has not been done yet and floors need upkeep.			
906	74.7 <i>Temp</i>	55% <i>RH</i>	916 <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Industrial and Vocational Education Supplies	Learn about your supplies.		Site based administration will provide information to site based staff.
	Industrial and Vocational Education Supplies	Minimize exposure to hazardous materials.		Site based administration will provide information to site based staff.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
P-11	Dust collection system (Shaker and Shaker Filters) are not maintained. Therefore dust accumulates.		
	76.6	56%	1479
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Roof leaks have been repaired. However, ceiling tiles are stained.	Install new ceiling tiles.
General Classroom Information		Dust accumulation on the stand alone air supply grills/cover.	Custodial staff should clean and sanitize the air supply grills in this classroom.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Carpeting is stained and soiled.	Remove carpet and install new tile floor.
P-14	Air filters MUST be changed monthly, and carpet should be cleaned periodically.		
	82.1	57%	1224
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	Animals in the Classroom	General items to watch for.	No animals in the classroom.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Door was open when temperature, humidity and Co2 readings were done. Teacher leaves the door to the portable open due to the mold smell. Aluminum foil was identified on the portable windows.	Maintenance needs to inspect HVAC for proper operation.
General Cleanliness	Clean spills promptly.	Dirty ceiling tiles, dirty carpeting, dirty light diffusers. Dust and debris build up on A/C grills. A/C vent covers in need of repair. Portable is extremely dirty. Consider full renovation of portable.	Maintenance to inspect and repair as appropriate.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
P-25				
		81.5	35%	3107
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	General Classroom Information		Carpeting is stained and torn.	Remove carpet and install new tile floor.
	General Classroom Information		22 occupants at time of assessment. Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	Health Officer's Office	Ensure that the ventilation system is properly operating.	Dust and debris was observed on the air supply at the time of the assessment.	Custodial staff should clean and sanitize the air supply in this classroom.
P-3		Any indoor air problems can be easily solved by a thorough dusting and an occasional vacuuming. I can dust shades and other areas, only on teacher's planning days, because of the amount released into the classroom. My portable has been vacuumed only once this year, and this was at my request. Dusting and vacuuming will go a long way in improving the health of our students and teachers, and in preventing future problems.		
		78.3	36%	3123
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	Excess Moisture in Classrooms		Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment. However, ceiling tiles are badly damaged.
	General Classroom Information		2 occupants at time of assessment. Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
P-8		82.4	40%	3271
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Classroom Information		3 occupants at time of assessment. Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
General Classroom Information		Only one stand alone A/C unit was working at time of assessment.	Maintenance needs to inspect HVAC for proper operation.
General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment with the exception of dirty sofas.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	Carpeting is stained and torn.	Remove carpet and install new tile floor.

P-9

80.2	39%	3414
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		29 occupants at time of assessment. Co2 level was elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment with the exception of the flooring.	Clean and sanitize flooring.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

I have to keep my portable at a very low temperature because the second it heats up I immediately have problems with my allergies and breathing stemming from my allergies. I always keep my portable COLD and that is how I am getting through the school year. Also, I understand I have to help maintain a clean classroom, but am I the only one who should do it? My classroom is not fully swept unless I do it (not to mention the dust that builds up...yuk!).

	<i>Category</i>		<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Site	<input data-bbox="380 126 533 165" type="text"/> <i>Temp</i>	<input data-bbox="577 126 730 165" type="text"/> <i>RH</i>	<input data-bbox="758 126 905 165" type="text"/> <i>Co2</i>		
General Information	<input data-bbox="604 337 1936 376" type="text"/>			A/C duct work throughout school needs cleaning.	Maintenance to inspect and repair as appropriate.