

Western High

IAQ Walkthrough 5/12/2005

2831

Outside Temp RH% CO2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
102	Temp	<input type="text" value="70.8"/>	RH% <input type="text" value="52.8"/>	CO2 <input type="text" value="1250"/>	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?			There appears to be an issue regarding daily trash removal practices.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
104	Temp	<input type="text" value="75"/>	RH% <input type="text" value="53.8"/>	CO2 <input type="text" value="1420"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Air flowing from air supply?			Air was not flowing qualitatively at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Air is flowing without obstruction?			Air was not flowing qualitatively at the time of assessment.	See other recommendation.		
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	Windows/doors are operable and are kept closed?			Windows and doors are operable and are kept closed.	None		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
104	Temp	75	RH% 53.8	CO2 1420	Occupants:			
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?				There appears to be an issue regarding daily trash removal practices.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?				THERE IS NO AIR COMING FROM VENTS AT ALL. VENTS ARE FILTY DIRTY AND CLOGGED WITH DIRT/DUST, ETC. CIELING TILES ARE COLORED	Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				THERE IS NO AIR COMING FROM VENTS AT ALL. VENTS ARE FILTY DIRTY AND CLOGGED WITH DIRT/DUST, ETC. CIELING TILES ARE COLORED	Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)				THERE IS NO AIR COMING FROM VENTS AT ALL. VENTS ARE FILTY DIRTY AND CLOGGED WITH DIRT/DUST, ETC. CIELING TILES ARE COLORED	Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				THERE IS NO AIR COMING FROM VENTS AT ALL. VENTS ARE FILTY DIRTY AND CLOGGED WITH DIRT/DUST, ETC. CIELING TILES ARE COLORED	Temperature was acceptable at the time of assessment.	None	
Walkthrough								
					Dust and debris on HVAC filters.	Facilities serviceperson to replace HVAC filters.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
119	Temp	<input type="text" value="75.5"/>	RH% <input type="text" value="51"/>	CO2 <input type="text" value="1385"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		
124	Temp	<input type="text" value="76.1"/>	RH% <input type="text" value="50.6"/>	CO2 <input type="text" value="1419"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
201	Temp	<input type="text" value="74.3"/>	RH% <input type="text" value="55.1"/>	CO2 <input type="text" value="1811"/>	Occupants: <input type="text" value="34"/>		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
201	Temp	74.3	RH% 55.1	CO2 1811	Occupants: 34		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		
	Walkthrough						
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
201B	Temp		RH%	CO2	Occupants:		
	Walkthrough						
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	1
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
203	Temp	75.9	RH% 57.8	CO2 2008	Occupants:		
	AIR CONDITIONING						
	Air is flowing without obstruction?			Air was not flowing qualitatively at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Mold and mildew is prevalent in the air supply. Air vents are dirty and ceiling around air vents is dirty. Vents are clogged with lint and dust.						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
203	Temp	75.9	RH% 57.8	CO2 2008	Occupants: <input type="text"/>			
	Room is free of smell of mold or mildew?	Mold and mildew is prevalent in the air supply. Air vents are dirty and ceiling around air vents is dirty. Vents are clogged with lint and dust.			Odor detected at the time of assessment. Appears to be coming from HVAC vents.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	1
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
ART SUPPLIES								
	Exposure minimized for art supplies?				No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS								
	Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None		
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Sweeping occurs irregularly; once in two to three weeks, dusting once every two or three months if ever in the regular school year. Mopping once a school year. Extra trash often has to be put in the hallway to have removed. Desks are never washed and gr			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	Sweeping occurs irregularly; once in two to three weeks, dusting once every two or three months if ever in the regular school year. Mopping once a school year. Extra trash often has to be put in the hallway to have removed. Desks are never washed and gr			There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments				Response	Recommendation	Responsible	Priority	
203	Temp	75.9	RH%	57.8	CO2	2008	Occupants:		
	Classrooms general appearance is clean and acceptable?	Sweeping occurs irregularly; once in two to three weeks, dusting once every two or three months if ever in the regular school year. Mopping once a school year. Extra trash often has to be put in the hallway to have removed. Desks are never washed and gr				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Sweeping occurs irregularly; once in two to three weeks, dusting once every two or three months if ever in the regular school year. Mopping once a school year. Extra trash often has to be put in the hallway to have removed. Desks are never washed and gr				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?	Sweeping occurs irregularly; once in two to three weeks, dusting once every two or three months if ever in the regular school year. Mopping once a school year. Extra trash often has to be put in the hallway to have removed. Desks are never washed and gr				No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	Sweeping occurs irregularly; once in two to three weeks, dusting once every two or three months if ever in the regular school year. Mopping once a school year. Extra trash often has to be put in the hallway to have removed. Desks are never washed and gr				No issues identified relating to spill clean up practices at the time of assessment..	None		
LOCAL EXHAUST FANS									
	Bathroom exhaust fan is functioning properly?	Student Government uses paint and banner ink which causes a chemical odor. No exhaust fans.				No issues identified at the time of assessment.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	Student Government uses paint and banner ink which causes a chemical odor. No exhaust fans.				No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	Student Government uses paint and banner ink which causes a chemical odor. No exhaust fans.				No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	Student Government uses paint and banner ink which causes a chemical odor. No exhaust fans.				No issues identified at the time of assessment.	None		
THERMAL COMFORT									

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
203	Temp	75.9	RH% 57.8	CO2 2008	Occupants:			
	Classroom is free of significant temperature shifts?	Often too cold...after long weekends, too warm, but within two days it becomes so cold it is unbearable.			Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Often too cold...after long weekends, too warm, but within two days it becomes so cold it is unbearable.			Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Often too cold...after long weekends, too warm, but within two days it becomes so cold it is unbearable.			No gaps in windows or doors identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Often too cold...after long weekends, too warm, but within two days it becomes so cold it is unbearable.			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Often too cold...after long weekends, too warm, but within two days it becomes so cold it is unbearable.			Temperature was acceptable at the time of assessment.	None		
	Walkthrough				Ceiling tiles broken, damaged or missing around HVAC vent.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
204	Temp	73.4	RH% 55.9	CO2 1762	Occupants:	14		
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	Walkthrough				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
208	Temp	72.9	RH% 57.5	CO2 1732	Occupants:			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
208	Temp	72.9	RH%	57.5	CO2	1732	Occupants:				
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	DRAIN TRAPS IN THE CLASSROOM										
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None						
	Water run in sinks at least once per week (about 2 cups of water).			No issues identified at the time of assessment.	None						
	Walkthrough										
				CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations					2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based					1
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
				Signs of water intrusion at sink cabinet.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations					1
212	Temp	74.5	RH%	54.5	CO2	1882	Occupants:	24			
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	GENERAL CLEANLINESS										
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None						
	Walkthrough										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
212	Temp	74.5	RH% 54.5	CO2 1882	Occupants: 24		
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
216	Temp	74.6	RH% 54.6	CO2 1973	Occupants: 22		
	ANIMALS IN THE CLASSROOM						
					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	THERMAL COMFORT						
					Temperature was acceptable at the time of assessment.	None	
					Temperature was acceptable at the time of assessment.	None	
	Walkthrough						
					Damaged ceiling tiles around HVAC supply vents.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations 2
308	Temp	75.5	RH% 53.4	CO2 1408	Occupants:		
	AIR CONDITIONING						
					Air was not flowing qualitatively at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 2
					Air was not flowing qualitatively at the time of assessment.	See other recommendation.	
					No odor detected at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
308	Temp	75.5	RH% 53.4	CO2 1408	Occupants:			
	Room is free of smell of mold or mildew?	over all conditions of the room is very poor			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?	room conditions make it difficult for special needs students				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
ART SUPPLIES								
	Art supplies okay?				No issues identified at the time of assessment.	None		
	Industrial supplies okay?				No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS								
	Area around and under classroom sinks free of leaks?	general poor conditions - over all			No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	general poor conditions - over all			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	Classroom lavatories/water fountains free of leaks?	general poor conditions - over all			No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	room is not a healthy environment for students or staff - staff are the only people that try to clean the room - room is in such poor condition tha it needs to be cleaned and painted professionally!			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	room is not a healthy environment for students or staff - staff are the only people that try to clean the room - room is in such poor condition tha it needs to be cleaned and painted professionally!			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?	room is not a healthy environment for students or staff - staff are the only people that try to clean the room - room is in such poor condition tha it needs to be cleaned and painted professionally!			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?	room is not a healthy environment for students or staff - staff are the only people that try to clean the room - room is in such poor condition tha it needs to be cleaned and painted professionally!			Floor was clean at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
308	Temp	75.5	RH%	53.4	CO2	1408	Occupants:	
	Food, if any, is stored in tightly sealed containers?	room is not a healthy environment for students or staff - staff are the only people that try to clean the room - room is in such poor condition tha it needs to be cleaned and painted professionally!			No issues identified at the time of assessment.	None		
	Room is free of pests?	room is not a healthy environment for students or staff - staff are the only people that try to clean the room - room is in such poor condition tha it needs to be cleaned and painted professionally!			No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	room is not a healthy environment for students or staff - staff are the only people that try to clean the room - room is in such poor condition tha it needs to be cleaned and painted professionally!			No issues identified relating to spill clean up practices at the time of assessment..	None		
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is inadequate based on room activities.	Physical Plant Operations to evaluate need for additional ventilation.	Physical Plant Operations	1
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	room is never at a comfortable temperature			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	room is never at a comfortable temperature			Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	room is never at a comfortable temperature			No gaps in windows or doors identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	room is never at a comfortable temperature			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	room is never at a comfortable temperature			Temperature was acceptable at the time of assessment.	None		
310	Temp	76.1	RH%	53.5	CO2	1552	Occupants:	15
AIR CONDITIONING								
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
310	Temp	76.1	RH% 53.5	CO2 1552	Occupants:	15		
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		
THERMAL COMFORT								
	Room is usually comfortable? (If no, please explain in the notes below.)		The students and I generally are freezing to death - you can ice skate in my room		Temperature was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?		The students and I generally are freezing to death - you can ice skate in my room		Temperature was elevated at the time of assessment.	See other recommendation.		
	Walkthrough				Heater in room.	Occupant to remove heater.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
320	Temp	74.5	RH% 54.9	CO2 1468	Occupants:		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
321A	Temp	75.5	RH% 60.1	CO2 1037	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
DRAIN TRAPS IN THE CLASSROOM							
	If not regularly used, toilets flushed once each week.		Some faculty restrooms are without ventilating fans (as well as soap and hot water !!)		No issues identified at the time of assessment.	None	
	Water poured down floor drains once per week (approx. 1 quart of water).		Some faculty restrooms are without ventilating fans (as well as soap and hot water !!)		No issues identified at the time of assessment.	None	
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		The east wall of the main building has been saturated with thick veins of mold intrusion for over ten years! One wall in the 321 area has been repaired cosmetically three times to no avail! External seepage, the real root of the cause ,has never been addr		Signs of water intrusion.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	Cold water pipes free of continuous condensation?		The east wall of the main building has been saturated with thick veins of mold intrusion for over ten years! One wall in the 321 area has been repaired cosmetically three times to no avail! External seepage, the real root of the cause ,has never been addr		Condensation on pipes at the time of assessment.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
321A	Temp	75.5	RH% 60.1	CO2 1037	Occupants: <input type="text"/>		
Indoor surfaces of exterior walls free of continuous condensation?	The east wall of the main building has been saturated with thick veins of mold intrusion for over ten years! One wall in the 321 area has been repaired cosmetically three times to no avail! External seepage, the real root of the cause ,has never been addr			Condensation on walls at the time of assessment.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	2
Windows, windowsills and window frames free of continuous condensation?	The east wall of the main building has been saturated with thick veins of mold intrusion for over ten years! One wall in the 321 area has been repaired cosmetically three times to no avail! External seepage, the real root of the cause ,has never been addr			Condensation on windows at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?				No pests observed at the time of assessment.	None		
Spills and other such issues requiring custodial assistance are addressed in a timely manner?				There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				No issues identified at the time of assessment.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?	Air conditioning units , often turned off on weekends to save money, are found off when teachers return to school after breaks. The hot and musty air quality onthese days contribute to numerous student signouts, teachers ready to pass out,and temps upstai			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
321A	Temp	75.5	RH% 60.1	CO2 1037	Occupants:		
Temperature in my classroom is generally comfortable (72F-76F)?	Air conditioning units , often turned off on weekends to save money, are found off when teachers return to school after breaks. The hot and musty air quality onthese days contribute to numerous student signouts, teachers ready to pass out,and temps upstai			Temperature was acceptable at the time of assessment.	None		
Walkthrough				Plaster on rear wall deteriorating.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
323	Temp	75.1	RH% 56.3	CO2 1320	Occupants:		
AIR CONDITIONING							
Room is free of smell of chemicals?	Mold and mildew are growing in and on the east wall.			No odor detected at the time of assessment.	None		
Room is free of smell of kitchen/food?	Mold and mildew are growing in and on the east wall.			No odor detected at the time of assessment.	None		
Room is free of smell of mold or mildew?	Mold and mildew are growing in and on the east wall.			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Most ceiling tiles are original tiles installed in 1981. Filthy! Leaks from condensation on a/c pipes caused bowls to be placed on floor to catch water as it dripped through ceiling tiles. Those tiles have been replaced.			Signs of water intrusion at ceiling and wall around door.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
323	Temp	75.1	RH% 56.3	CO2 1320	Occupants:		
Indoor surfaces of exterior walls free of continuous condensation?	Most ceiling tiles are original tiles installed in 1981. Filthy! Leaks from condensation on a/c pipes caused bowls to be placed on floor to catch water as it dripped through ceiling tiles. Those tiles have been replaced.			Condensation on walls at the time of assessment. Leak identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Windows, windowsills and window frames free of continuous condensation?	Most ceiling tiles are original tiles installed in 1981. Filthy! Leaks from condensation on a/c pipes caused bowls to be placed on floor to catch water as it dripped through ceiling tiles. Those tiles have been replaced.			Condensation on windows at the time of assessment. Temperature was within acceptable range and no leaks were identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Mold and mildew is growing through the west wall, 1-1/2" to 2" protusion over exit door and along the baseboards almost the entire length of the room. Temporary fixes done in the past twelve years include scraping the mold off and repainting over it. Mo			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	Mold and mildew is growing through the west wall, 1-1/2" to 2" protusion over exit door and along the baseboards almost the entire length of the room. Temporary fixes done in the past twelve years include scraping the mold off and repainting over it. Mo			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?	Mold and mildew is growing through the west wall, 1-1/2" to 2" protusion over exit door and along the baseboards almost the entire length of the room. Temporary fixes done in the past twelve years include scraping the mold off and repainting over it. Mo			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	Mold and mildew is growing through the west wall, 1-1/2" to 2" protusion over exit door and along the baseboards almost the entire length of the room. Temporary fixes done in the past twelve years include scraping the mold off and repainting over it. Mo			Floor was clean at the time of assessment.	None		
Room is free of pests?	Mold and mildew is growing through the west wall, 1-1/2" to 2" protusion over exit door and along the baseboards almost the entire length of the room. Temporary fixes done in the past twelve years include scraping the mold off and repainting over it. Mo			No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

323

Temp RH% CO2 Occupants:

THERMAL COMFORT

Classroom is free of significant temperature shifts?	Room has been cold more than 75% of the time. Students wear sweaters, jackets, and complain of cold. If room not cold - then a/c is off in the building.	Temperature was acceptable at the time of assessment.	None
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Room has been cold more than 75% of the time. Students wear sweaters, jackets, and complain of cold. If room not cold - then a/c is off in the building.	Humidity was acceptable at the time of assessment.	None
Room is usually comfortable? (If no, please explain in the notes below.)	Room has been cold more than 75% of the time. Students wear sweaters, jackets, and complain of cold. If room not cold - then a/c is off in the building.	Environmental parameters were within acceptable range at the time of assessment..	None
Temperature in my classroom is generally comfortable (72F-76F)?	Room has been cold more than 75% of the time. Students wear sweaters, jackets, and complain of cold. If room not cold - then a/c is off in the building.	Temperature was acceptable at the time of assessment.	None

Walkthrough

Signs of water intrusion. Leak identified. Eyewash station.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
---	--	---------------------------	---

323A

Temp RH% CO2 Occupants:

AIR CONDITIONING

Air flowing from air supply?	This is an inside storage closet.	Air flowing without obstruction at the time of assessments.	None
Air is flowing without obstruction?	This is an inside storage closet.	Air flowing without obstruction at the time of assessments.	None
Windows/doors are operable and are kept closed?	This is an inside storage closet.	No issues identified at the time of assessment.	None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?	This is an inside storage closet.	There does not appear to be a dusting issue within this room.	None
Room is free of pests?	This is an inside storage closet.	No pests observed at the time of assessment.	None

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?	This is an inside storage closet.	No issues identified at the time of assessment.	None
---	-----------------------------------	---	------

THERMAL COMFORT

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
323A	Temp	<input type="text" value="75"/>	RH% <input type="text" value="56.5"/>	CO2 <input type="text" value="1202"/>	Occupants: <input type="text"/>			
	Temperature in my classroom is generally comfortable (72F-76F)?	This is an inside storage closet.			Temperature was acceptable at the time of assessment.	None		
	Walkthrough				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
323B	Temp	<input type="text" value="75.3"/>	RH% <input type="text" value="57.1"/>	CO2 <input type="text" value="1240"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING							
	Air flowing from air supply?	Mold and mildew growing from east wall all along baseboards.			Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?	Mold and mildew growing from east wall all along baseboards.			Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of mold or mildew?	Mold and mildew growing from east wall all along baseboards.			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS							
	Indoor surfaces of exterior walls free of continuous condensation?	Kiln room - mold and mildew growing through east wall along baseboards.			Condensation on walls at the time of assessment. Wall along baseboard is damaged.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	Kiln room with two kilns and exhaust fan to outside.			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?	Kiln room with two kilns and exhaust fan to outside.			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?	Kiln room with two kilns and exhaust fan to outside.			Floor was clean at the time of assessment.	None		
	Room is free of pests?	Kiln room with two kilns and exhaust fan to outside.			No pests observed at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
323B	Temp	<input type="text" value="75.3"/>	RH% <input type="text" value="57.1"/>	CO2 <input type="text" value="1240"/>	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?		kiln exhaust fans.		No bathroom. Identified in error.	None		
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None		
325	Temp	<input type="text" value="76.5"/>	RH% <input type="text" value="56.2"/>	CO2 <input type="text" value="1793"/>	Occupants: <input type="text" value="36"/>		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Outside wall..covered with bulletin board (for art work) is buckled and am sure it is from moisture..am afraid to remove as am sure it is mildewed underneath		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?		Outside wall..covered with bulletin board (for art work) is buckled and am sure it is from moisture..am afraid to remove as am sure it is mildewed underneath		There does not appear to be a dusting issue within this room.	None		
Classrooms general appearance is clean and acceptable?		Outside wall..covered with bulletin board (for art work) is buckled and am sure it is from moisture..am afraid to remove as am sure it is mildewed underneath		General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?		Outside wall..covered with bulletin board (for art work) is buckled and am sure it is from moisture..am afraid to remove as am sure it is mildewed underneath		Floor was clean at the time of assessment.	None		
Walkthrough							
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
325B	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough							
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
332	Temp	<input type="text" value="71.7"/>	RH% <input type="text" value="62.5"/>	CO2 <input type="text" value="1532"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
332	Temp	71.7	RH% 62.5	CO2 1532	Occupants:		
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	Walkthrough				Wall under board at rear of room is buckled.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
339	Temp	73.2	RH% 62.1	CO2 1758	Occupants:	25	
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Note on the floor: It is swept daily; however, it has not been mopped since August of 2004 (it is now March 2005).		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?		Note on the floor: It is swept daily; however, it has not been mopped since August of 2004 (it is now March 2005).		There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?		Note on the floor: It is swept daily; however, it has not been mopped since August of 2004 (it is now March 2005).		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Walkthrough				CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
340	Temp	76.3	RH% 59.8	CO2 1844	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Signs of water intrusion. Stained ceiling tiles and damage to wall.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			I have cob webs, dust, dirt, etc. in visible and hidden areas.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?			I have cob webs, dust, dirt, etc. in visible and hidden areas.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?			I have cob webs, dust, dirt, etc. in visible and hidden areas.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?			I have cob webs, dust, dirt, etc. in visible and hidden areas.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Room is free of pests?			I have cob webs, dust, dirt, etc. in visible and hidden areas.	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)					Temperature and CO2 level were elevated at the time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations 2
Walkthrough							
					CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations 2

341 Temp 77.3 RH% 63.4 CO2 2062 Occupants: 29

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
341	Temp	77.3	RH%	63.4	CO2	2062	Occupants:	29			
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None						
	Walkthrough			CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations					2
343	Temp	75.3	RH%	59.2	CO2	1464	Occupants:	9			
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Staff does a fine job with my room.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	Classroom is dusted/vacuumed thoroughly and regularly?			Staff does a fine job with my room.	There does not appear to be a dusting issue within this room.	None					
	Walkthrough			HVAC return grill damaged.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations					2
344	Temp	75.5	RH%	61.1	CO2	1620	Occupants:	5			
	AIR CONDITIONING										
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None					
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None					
	ANIMALS IN THE CLASSROOM										
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	Walkthrough				Wall at main door and back of room and tackable wall surface damaged.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations				1
					Ceiling tiles broken, damaged or missing.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
421	Temp	75.8	RH% 57	CO2 1263	Occupants: 26			
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Food, if any, is stored in tightly sealed containers?				No issues identified at the time of assessment.	None		
LOCKER ROOM								
	Locker room and showers cleaned regularly and properly?				No issues identified at the time of assessment.	None		
	Soiled clothes and towels are removed regularly?				No issues identified at the time of assessment.	None		
Walkthrough								
					Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
					HVAC vent damaged.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
422	Temp	73.2	RH% 59.5	CO2 1059	Occupants:			
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
422	Temp	73.2	RH% 59.5	CO2 1059	Occupants: <input type="text"/>		
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None		
	Water run in sinks at least once per week (about 2 cups of water).			No issues identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	Indoor surfaces of exterior walls free of continuous condensation?			No visible condensation at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		air quality and moisture is a problem	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?			No issues identified at the time of assessment.	None		
LOCKER ROOM							
	Locker room and showers cleaned regularly and properly?		improper ventilation has always been a serious health issue	General cleanliness of the locker room and showers was not acceptable at the time of assessment.	Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.	Site Based	2
	Soiled clothes and towels are removed regularly?		improper ventilation has always been a serious health issue	Appears that clothes and towels are not removed regularly.	See other recommendation.		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
422	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="59.5"/>	CO2 <input type="text" value="1059"/>	Occupants: <input type="text"/>		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	
424	Temp	<input type="text" value="73.1"/>	RH% <input type="text" value="49.3"/>	CO2 <input type="text" value="1280"/>	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	LOCAL EXHAUST FANS						
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	
427	Temp	<input type="text" value="72.7"/>	RH% <input type="text" value="60.6"/>	CO2 <input type="text" value="895"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				Odor detected at the time of assessment.	Physical Plant operations to evaluate and clean HVAC ducts and replace ceiling tiles around vents.	Physical Plant Operations 1
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

427

Temp RH% CO2 Occupants:

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.

Facilities serviceperson to replace stained ceiling tiles.

Site Based

2

Classroom lavatories/water fountains free of leaks?

Signs of water intrusion.

Physical Plant Operations to evaluate for leaks and repair as appropriate.

Physical Plant Operations

1

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

Room is free of pests?

No pests observed at the time of assessment.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

When the air is turned off on the weekends and turned on again on Monday there is a significant smell of mildew in the air. The odor is present most of the time.

Temperature was acceptable at the time of assessment.

None

428

Temp RH% CO2 Occupants:

AIR CONDITIONING

Air flowing from air supply?

Air flowing without obstruction at the time of assessments.

None

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

I feel myself and my debaters have been sick more often this year because of the carpeting on the 3 walls. We have coughs (persistant)and nasal problems.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
428	Temp	75.8	RH% 53.2	CO2 1088	Occupants:		
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	The ceiling tiles are discolored and coming up. There was porn in the ceiling when we tried to fix the ceiling. Dust fell everywhere.			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	I have 3 walls covered in carpet. I have been sick constantly since being put into this room. The carpet needs to be removed. It is the old band room, now a debate room.			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	I have 3 walls covered in carpet. I have been sick constantly since being put into this room. The carpet needs to be removed. It is the old band room, now a debate room.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?	I have 3 walls covered in carpet. I have been sick constantly since being put into this room. The carpet needs to be removed. It is the old band room, now a debate room.			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	I have 3 walls covered in carpet. I have been sick constantly since being put into this room. The carpet needs to be removed. It is the old band room, now a debate room.			Dust and dirt accumulation on floor. Also, room was previously a band room and has carpet on walls.	Physical Plant Operations to evaluate and remove carpet as appropriate.	Physical Plant Operations	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?	My room is ALWAYS hot. When they turn the ac off for the week-end, on Fridays, it becomes unbearable Friday afternoon. The kids are all hot and come down here complaining.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	My room is ALWAYS hot. When they turn the ac off for the week-end, on Fridays, it becomes unbearable Friday afternoon. The kids are all hot and come down here complaining.			Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	My room is ALWAYS hot. When they turn the ac off for the week-end, on Fridays, it becomes unbearable Friday afternoon. The kids are all hot and come down here complaining.			Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	My room is ALWAYS hot. When they turn the ac off for the week-end, on Fridays, it becomes unbearable Friday afternoon. The kids are all hot and come down here complaining.			Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
513	Temp	72.5	RH% 52.1	CO2 1776	Occupants:	25		
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None		
THERMAL COMFORT								
Room is usually comfortable? (If no, please explain in the notes below.)			This room is freezing. It is usually in the 60s no matter what the weather is outside. It is very uncomfortable and the students complain every day.		Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?			This room is freezing. It is usually in the 60s no matter what the weather is outside. It is very uncomfortable and the students complain every day.		Temperature was acceptable at the time of assessment.	None		
514	Temp	71.7	RH% 54.6	CO2 1888	Occupants:	16		
AIR CONDITIONING								
Room is free of smell of mold or mildew?			g) When the air is broken or has been turned off for a period of time, like vacations, the room smells from mildew or mold		No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
514	Temp	71.7	RH% 54.6	CO2 1888	Occupants: 16		
523	Temp	71.4	RH% 55.5	CO2 2052	Occupants: 27		
AIR CONDITIONING							
	Room is free of smell of chemicals?			Odor detected at the time of assessment. Old specimen jars in room.	Occupant should remove old specimen jars that are not in use.	Site Based	2
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	Classroom is free of animals and pets?			Animals were identified at the time of assessment. Animal/pet dander is a major allergen source that could impact occupant allergies.	Location to ensure that housing of animal or pet is in conjunction with approved curriculum. If not the animal must be removed.	Site Based	1
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
ART SUPPLIES							
	Exposure minimized for science supplies?			Science supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.	Site Based	2
	Following good handling and storage practices for science supplies?			Science supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.	Site Based	2
	Science supplies okay?			Science supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.	Site Based	2
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
523	Temp	71.4	RH% 55.5	CO2 2052	Occupants: 27			
	Classroom is dusted/vacuumed thoroughly and regularly?	The room is full of old resources/materials, is cluttered and unpleasant.			Slight dust accumulation was observed on environmental surfaces at the time of assessment. Room is cluttered.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
	Classrooms general appearance is clean and acceptable?	The room is full of old resources/materials, is cluttered and unpleasant.			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?	The room is full of old resources/materials, is cluttered and unpleasant.			Floor was clean at the time of assessment.	None		
	Room is free of pests?	The room is full of old resources/materials, is cluttered and unpleasant.			No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	The room is full of old resources/materials, is cluttered and unpleasant.			No issues identified relating to spill clean up practices at the time of assessment..	None		
LOCAL EXHAUST FANS								
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None		
THERMAL COMFORT								
	Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
Walkthrough								
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
					CO2 level elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
527	Temp	72.2	RH% 57.3	CO2 1555	Occupants:			
AIR CONDITIONING								
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS								
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
527	Temp	72.2	RH% 57.3	CO2 1555	Occupants:		
GENERAL CLEANLINESS							
Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None		
531	Temp	73.1	RH% 59.3	CO2 1738	Occupants:	15	
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		Sometimes room is very cold!		Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		Sometimes room is very cold!		Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?		Sometimes room is very cold!		Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
531	Temp	73.1	RH% 59.3	CO2 1738	Occupants: 15		
Walkthrough				CO2 level elevated.		Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations 2
533	Temp	73.4	RH% 59.5	CO2 1895	Occupants: 34		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
You are informed about the potential allergies of your students?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
LOCKER ROOM							
Locker room and showers cleaned regularly and properly?				No issues identified at the time of assessment.		None	
Soiled clothes and towels are removed regularly?				No issues identified at the time of assessment.		None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			The temperature in the classroom is significantly below 70 degrees on a regular basis.	Temperature was acceptable at the time of assessment.		None	
Room is usually comfortable? (If no, please explain in the notes below.)			The temperature in the classroom is significantly below 70 degrees on a regular basis.	Environmental parameters were within acceptable range at the time of assessment..		None	
Temperature in my classroom is generally comfortable (72F-76F)?			The temperature in the classroom is significantly below 70 degrees on a regular basis.	Temperature was acceptable at the time of assessment.		None	
Walkthrough				Dust observed on supply/return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
538	Temp	73.9	RH% 53.7	CO2 2197	Occupants:		
AIR CONDITIONING							
	Room is free of smell of chemicals?			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of drains with facility serviceperson staff.	Site Based	2
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is not utilized regularly. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based	2
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No issues identified at the time of assessment.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		The room is freezing in the morning, but by the end of third hour (about 1:00) it gets really hot and stuffy.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The room is freezing in the morning, but by the end of third hour (about 1:00) it gets really hot and stuffy.	Humidity was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
538	Temp	73.9	RH% 53.7	CO2 2197	Occupants:			
	Room is usually comfortable? (If no, please explain in the notes below.)	The room is freezing in the morning, but by the end of third hour (about 1:00) it gets really hot and stuffy.			CO2 level was slightly elevated at the time of assessment	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?	The room is freezing in the morning, but by the end of third hour (about 1:00) it gets really hot and stuffy.			Temperature was acceptable at the time of assessment.	None		
544	Temp	73.1	RH% 52.8	CO2 2165	Occupants:	24		
AIR CONDITIONING								
	Room is free of smell of mold or mildew?	I know there is mold behind the chalk boards			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS								
	Classroom is dusted/vacuumed thoroughly and regularly?	My biggest problem is the dust. My allergies are primarily to dust- the book shelf is a big source of dust and my asthma acts up as a result. I would like to see more "vacuming" of the floors and the shelves.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	It is freezing usually-			Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	It is freezing usually-			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	It is freezing usually-			Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

601

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

There is a smell of mold and mildew in the classroom. Many Students feel sick (including myself) when they are in this room. I have experienced this smell and it affects my chest-breathing.

No odor detected at the time of assessment.

None

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No bathroom. Identified in error.

None

Walkthrough

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.

Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.

Site Based

1

608

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Windows, windowsills and window frames free of continuous condensation?

No visible condensation at the time of assessment.

None

GENERAL CLEANLINESS

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
608	Temp	70.7	RH% 57.2	CO2 1936	Occupants:		
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	
	Walkthrough						
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
					Plaster under window is deteriorating.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
					CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations 2
609	Temp	73.1	RH% 54.6	CO2 2026	Occupants:		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment. Clutter in room.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based 2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Sometimes is very stuffy. Sometimes is very cold and then it gets very warm. Temperature fluctuates.		Temperature was acceptable at the time of assessment.	None	
			Room could be cleaner: less dust.				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

617

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	The rug is 5 years old and is stained, dirty and never cleaned properly. The library collection is never dusted and the dust/mold causes you to sneeze, scratch and become irritated.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	The rug is 5 years old and is stained, dirty and never cleaned properly. The library collection is never dusted and the dust/mold causes you to sneeze, scratch and become irritated.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?	The rug is 5 years old and is stained, dirty and never cleaned properly. The library collection is never dusted and the dust/mold causes you to sneeze, scratch and become irritated.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	The rug is 5 years old and is stained, dirty and never cleaned properly. The library collection is never dusted and the dust/mold causes you to sneeze, scratch and become irritated.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize carpet.	Site Based	2
Spills and other such issues requiring custodial assistance are addressed in a timely manner?	The rug is 5 years old and is stained, dirty and never cleaned properly. The library collection is never dusted and the dust/mold causes you to sneeze, scratch and become irritated.	There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

Walkthrough

Drywall around windows and behind bookcases at windows is deteriorating.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
--	--	---------------------------	---

702

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
702	Temp	<input type="text" value="74.5"/>	RH% <input type="text" value="51.1"/>	CO2 <input type="text" value="2422"/>	Occupants: <input type="text" value="24"/>		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	c is NA		No issues identified at the time of assessment.	None		
Walkthrough							
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
				CO2 level elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
704	Temp	<input type="text" value="74.5"/>	RH% <input type="text" value="49.8"/>	CO2 <input type="text" value="2340"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)	usually cold...but I bring a sweater. I would rather be cold than hot.		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	usually cold...but I bring a sweater. I would rather be cold than hot.		Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				CO2 level elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
705	Temp	<input type="text" value="73.7"/>	RH% <input type="text" value="49.5"/>	CO2 <input type="text" value="2195"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

705

Temp RH% CO2

Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

Room is free of pests?

No pests observed at the time of assessment.

None

LOCAL EXHAUST FANS

Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)

No issues identified at the time of assessment.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

too cold

Temperature was acceptable at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

too cold

Temperature was acceptable at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

too cold

Temperature was acceptable at the time of assessment.

None

Walkthrough

CO2 level was elevated.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.

Physical Plant Operations

2

706

Temp RH% CO2

Occupants:

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Room is free of pests?

There are ants in the room.

No pests observed at the time of assessment.

None

THERMAL COMFORT

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
706	Temp	74.2	RH%	49.2	CO2	2305	Occupants:	13			
	Classroom is free of significant temperature shifts?	My room is uncomfortably cold. I usually have to wear 2-3 layers of clothing. However, some days the AC is not working properly and it is uncomfortable hot in the room and I am not dressed appropriately because I am expecting it to be cold.			Temperature was acceptable at the time of assessment.	None					
	Room is usually comfortable? (If no, please explain in the notes below.)	My room is uncomfortably cold. I usually have to wear 2-3 layers of clothing. However, some days the AC is not working properly and it is uncomfortable hot in the room and I am not dressed appropriately because I am expecting it to be cold.			Temperature was acceptable at the time of assessment.	None					
	Temperature in my classroom is generally comfortable (72F-76F)?	My room is uncomfortably cold. I usually have to wear 2-3 layers of clothing. However, some days the AC is not working properly and it is uncomfortable hot in the room and I am not dressed appropriately because I am expecting it to be cold.			Temperature was acceptable at the time of assessment.	None					
	Walkthrough				CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations				2
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
707	Temp	74.5	RH%	51.5	CO2	2644	Occupants:	29			
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)	Room 707 is always very cold.			Temperature was acceptable at the time of assessment.	None					

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
707	Temp <input type="text" value="74.5"/> RH% <input type="text" value="51.5"/> CO2 <input type="text" value="2644"/>	Occupants: <input type="text" value="29"/>			
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.	None		
	Room 707 is always very cold.				
	Walkthrough				
		CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
709	Temp <input type="text" value="71.8"/> RH% <input type="text" value="54.1"/> CO2 <input type="text" value="2400"/>	Occupants: <input type="text" value="19"/>			
	AIR CONDITIONING				
	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None		
	Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM				
	Activities and/or room conditions are modified to address student allergies?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS				
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation at the time of assessment.	None		
	GENERAL CLEANLINESS				
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
709	Temp	71.8	RH%	54.1	CO2	2400	Occupants:	19			
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None						
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None						
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None						
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None						
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No issues identified at the time of assessment.	None						
	THERMAL COMFORT										
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		room is usually too cold, but sometimes is too warm. It is very rarely a comfortable temperature.		Humidity was acceptable at the time of assessment.	None					
	Room is usually comfortable? (If no, please explain in the notes below.)		room is usually too cold, but sometimes is too warm. It is very rarely a comfortable temperature.		Temperature was acceptable at the time of assessment.	None					
	Temperature in my classroom is generally comfortable (72F-76F)?		room is usually too cold, but sometimes is too warm. It is very rarely a comfortable temperature.		Temperature was acceptable at the time of assessment.	None					
711	Temp	74.2	RH%	51.6	CO2	2431	Occupants:				
	AIR CONDITIONING										
	Room is free of smell of chemicals?			No odor detected at the time of assessment.	None						
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None						
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
711	Temp	74.2	RH% 51.6	CO2 2431	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			there are no exhaust fans and no bathroom fans	No issues identified at the time of assessment.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Either too hot or too cold. There appears to be no middle of the road.	Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Either too hot or too cold. There appears to be no middle of the road.	Humidity was acceptable at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)			Either too hot or too cold. There appears to be no middle of the road.	Supply vents closed at the time of assessment.	Facilities serviceperson to open supply vents.	2
	Temperature in my classroom is generally comfortable (72F-76F)?			Either too hot or too cold. There appears to be no middle of the road.	Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
711	Temp	<input type="text" value="74.2"/>	RH% <input type="text" value="51.6"/>	CO2 <input type="text" value="2431"/>	Occupants: <input type="text"/>			
714	Temp	<input type="text" value="77.1"/>	RH% <input type="text" value="48.2"/>	CO2 <input type="text" value="2632"/>	Occupants: <input type="text"/>			
AIR CONDITIONING								
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS								
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
	Classroom lavatories/water fountains free of leaks?				No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	3
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?				No pests observed at the time of assessment.	None		
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?		Temperatures much too cold or hot _ extremes and very humid		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Temperatures much too cold or hot _ extremes and very humid		Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Temperatures much too cold or hot _ extremes and very humid		Supply and return vents closed at the time of assessment.	Facilities serviceperson to open supply and return vents.	Site Based	1
	Temperature in my classroom is generally comfortable (72F-76F)?		Temperatures much too cold or hot _ extremes and very humid		Temperature was elevated at the time of assessment.	See other recommendation.		
Walkthrough								
					CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
715	Temp	75.4	RH% 49.5	CO2 2430	Occupants: 27s			
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Spills and other such issues requiring custodial assistance are addressed in a timely manner?					No issues identified relating to spill clean up practices at the time of assessment..	None		
Walkthrough								
					CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
716	Temp	74.9	RH% 49	CO2 2317	Occupants:			
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
DRAIN TRAPS IN THE CLASSROOM								
Water poured down floor drains once per week (approx. 1 quart of water).					No floor drain in room.	None		
Water run in sinks at least once per week (about 2 cups of water).					No sink in room.	None		
GENERAL CLEANLINESS								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
716	Temp	74.9	RH% 49	CO2 2317	Occupants:		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None		
	LOCKER ROOM						
	Locker room and showers cleaned regularly and properly?			Issues not applicable. Room is not a locker room.	None		
	Walkthrough						
				CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
717	Temp	74.4	RH% 50.6	CO2 2345	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Room is free of the use of scented cleaners and air fresheners?			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Room is almost always quite cold. Occasionally it is too hot.	Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is almost always quite cold. Occasionally it is too hot.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is almost always quite cold. Occasionally it is too hot.	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
717	Temp	<input type="text" value="74.4"/>	RH% <input type="text" value="50.6"/>	CO2 <input type="text" value="2345"/>	Occupants: <input type="text"/>		
Walkthrough				CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
902	Temp	<input type="text" value="71.9"/>	RH% <input type="text" value="58.6"/>	CO2 <input type="text" value="755"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Dust and debris on ceiling tiles. Ceiling tiles are high and need to be replaced by PPO.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment. High ceiling.	Physical Plant operations to evaluate and clean supply/return vents.	Physical Plant Operations	2
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Room is free of pests?				No pests observed at the time of assessment.	None		
904	Temp	<input type="text" value="71.3"/>	RH% <input type="text" value="61.4"/>	CO2 <input type="text" value="727"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
904	Temp	71.3	RH% 61.4	CO2 727	Occupants:		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment. High ceiling.	Physical Plant operations to evaluate and clean supply/return registers.	Physical Plant Operations	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
LOCKER ROOM							
	Locker room and showers cleaned regularly and properly?			No issues identified at the time of assessment.	None		
Walkthrough							
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. High ceiling.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2