

Jeffrey S. Moquin, Director
Risk Management Department

Telephone: 754-321-3200
Facsimile: 754-321-3290

September 22, 2006

Signature on File

TO: Ms. Aimee Zekofsky, Principal
Apollo Middle School

FROM: Kenneth I. Partee, Project Manager Occupational Health and Environmental Control
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 103A, 160, 168, 201, 201I, 201J, 201Q, 201R, 201T and Portable 996C

On September 18, 2006 I conducted an assessment of FISH 103A, 160, 168, 201, 201I, 201J, 201Q, 201R, 201T and Portable 996C at **Apollo Middle School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Sam Gregg, Area Superintendent
Margaret Underhill, Area Director
Jeffrey S. Moquin, Director, Risk Management
Rodney Williams, Project Manager, Facilities and Construction Management
Diane Watts, Broward Teachers Union
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

KP/tc
Enc.

IAQ Assessment

Apollo Middle School

Location Number 1661
 Evaluation Requested September 15, 2006
 Evaluation Date September 18, 2006

Time of Day 1:35 pm

Outdoor Conditions Temperature 97.9 Relative Humidity 40.6 Ambient CO2 505

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
103A	75.8	72 - 78	47.6	30% - 60%	516	Max 700 > Ambient	2
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
No		Yes		Yes		Perimeter at wall	
Ceiling Type	Cement		Yes	Yes	Perimeter at wall		
Wall Type	Plaster		No	No	None		
Flooring	Carpet		No	No	None		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	No	Yes	Yes	Remove and replace ceiling tiles
Walls	No	Yes	Yes	Paint as appropriate
Flooring	Yes	No	No	
HVAC Supply Grills	Yes	No	No	
HVAC Return Grills	Yes	No	No	
Ceiling at Supply Grills	Yes	No	No	
Surfaces in Room	Yes	No	No	

Observations

Findings:

- Visible microbial growth on ceiling around perimeter of the room
- Paint is peeling on the back wall

Recommendations:

Site Based Maintenance:

- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:

- Remove and replace ceiling tiles around perimeter of the room
- Evaluate for cause of paint peeling on back wall and repaint wall as appropriate

IAQ Assessment

Apollo Middle School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="160"/>	<input type="text"/>	<input type="text" value="72 - 78"/>	<input type="text"/>	<input type="text" value="30% - 60%"/>	<input type="text"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text"/>
Noticeable Odor	<input type="text" value="No"/>		Visible water damage / staining?	Visible microbial growth?	Amount of material affected		
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings: (Storage Room)
 - During heavy rain the roof drain overflows into hallway 018 and 019

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:
 - Evaluate roof drain and enclose

IAQ Assessment

Location Number
 Evaluation Requested
 Evaluation Date

Apollo Middle School

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="168"/>	<input type="text" value="77.1"/>	<input type="text" value="72 - 78"/>	<input type="text" value="50.3"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="1297"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text"/>
Noticeable Odor	<input type="text" value="No"/>		Visible water damage / staining?		Visible microbial growth?		Amount of material affected
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>
Wall Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings: (Band Room)
 - Environmental parameters were acceptable at the time of the assessment.

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Location Number
 Evaluation Requested
 Evaluation Date

Apollo Middle School

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="201"/>	<input type="text" value="75.6"/>	<input type="text" value="72 - 78"/>	<input type="text" value="47.3"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="890"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings: (Hallway)
 - Environmental parameters were acceptable at the time of the assessment.

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Apollo Middle School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="2011"/>	<input type="text"/>	<input type="text" value="72 - 78"/>	<input type="text"/>	<input type="text" value="30% - 60%"/>	<input type="text"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text"/>
Noticeable Odor	<input type="text" value="No"/>		Visible water damage / staining?	Visible microbial growth?	Amount of material affected		
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="3 ceiling tiles"/>		
Wall Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Remove and replace ceiling tiles"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- Visible microbial growth on 2 ceiling tiles in room and 1 stained ceiling tile in hallway

Recommendations:

Site Based Maintenance:

- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:

- Evaluate for cause of water intrusion and repair. Remove and replace stained ceiling tiles as appropriate.

IAQ Assessment

Apollo Middle School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="201J & T"/>	<input type="text"/>	<input type="text" value="72 - 78"/>	<input type="text"/>	<input type="text" value="30% - 60%"/>	<input type="text"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text"/>
Noticeable Odor	<input type="text" value="No"/>		Visible water damage / staining?		Visible microbial growth?		Amount of material affected
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>
Wall Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:
 - Visible microbial growth on doors to both rooms

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:
 - Replace door to FISH 201J and 201T

IAQ Assessment

Apollo Middle School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="201Q"/>	<input type="text"/>	<input type="text" value="72 - 78"/>	<input type="text"/>	<input type="text" value="30% - 60%"/>	<input type="text"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text"/>
Noticeable Odor	<input type="text" value="No"/>		Visible water damage / staining?	Visible microbial growth?	Amount of material affected		
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="1 ceiling tile"/>		
Wall Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Remove and replace ceiling tile"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:
 - Visible microbial growth on ceiling tile in outside stairwell

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:
 - Evaluate for leak and repair. Remove and replace stained ceiling tiles as appropriate.

IAQ Assessment

Location Number
 Evaluation Requested
 Evaluation Date

Apollo Middle School

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="201R"/>	<input type="text" value="75.1"/>	<input type="text" value="72 - 78"/>	<input type="text" value="46.3"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="496"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings: (Principals Office)
 - Environmental parameters were acceptable at the time of the assessment.

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Apollo Middle School

Location Number 1661
 Evaluation Requested September 15, 2006
 Evaluation Date September 18, 2006

Time of Day 1:35 pm

Outdoor Conditions Temperature 97.9 Relative Humidity 40.6 Ambient CO2 505

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
P-996C		72 - 78		30% - 60%		Max 700 > Ambient	
Noticeable Odor	No		Visible water damage / staining?	Visible microbial growth?	Amount of material affected		
Ceiling Type	2 x 4 Lay In		Yes	No	Ceiling tile tracks		
Wall Type	Tackable		Yes	No	Various		
Flooring	Tile		No	No	None		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	No	Yes	Yes	Repair/replace ceiling tile track
Walls	No	Yes	Yes	Repair/replace wall material as appropriate
Flooring	Yes	No	No	
HVAC Supply Grills	Yes	No	No	
HVAC Return Grills	Yes	No	No	
Ceiling at Supply Grills	Yes	No	No	
Surfaces in Room	Yes	No	No	

Observations

Findings:

- All walls have elevated moisture content from 20-90+ %. Highest reading under A/C unit on Southwest wall.
- Walls are bulging in several place
- Elevated moisture content in ceiling insulation
- Ceiling tile tracks are rusted

Recommendations:

Site Based Maintenance:

- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:

- Evaluate for leaks and repair. Remove and replace wall material as appropriate.
- Remove and replace ceiling insulation as necessary
- Repair/replace ceiling tile tracks as appropriate