

Tools for Schools Phase II - Indoor Air Quality

Follow-up Action Plan for Site Based



Bair Middle

81.4 44.3 498

Principal: Ms. Ellen Etling

Walkthrough Date: 4/28/2005

Temp RH Co2
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
102A	2	Site Based	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
127	2	Site Based	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
147	2	Site Based	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
167	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
167	2	Site Based	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.
167	2	Site Based	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.
167	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
167	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
193	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
193	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
203	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
203	2	Site Based	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.
203	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Response	Recommendation
203	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
207	2	Site Based	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
207	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
207	3	Site Based		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.