

Coral Springs Middle

IAQ Walkthrough 4/22/2005

2561

Outside Temp RH% CO2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
102	Temp	<input type="text" value="75.1"/>	RH% <input type="text" value="50.4"/>	CO2 <input type="text" value="932"/>	Occupants: <input type="text" value="7"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		None
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		Until the past week, the temperature has been extremely uncomfortable due to being way too cold.	Temperature was acceptable at the time of assessment.	None		None
	Room is usually comfortable? (If no, please explain in the notes below.)		Until the past week, the temperature has been extremely uncomfortable due to being way too cold.	Environmental parameters were within acceptable range at the time of assessment..	None		None
	Temperature in my classroom is generally comfortable (72F-76F)?		Until the past week, the temperature has been extremely uncomfortable due to being way too cold.	Temperature was acceptable at the time of assessment.	None		None
102E	Temp	<input type="text" value="74.6"/>	RH% <input type="text" value="47.1"/>	CO2 <input type="text" value="871"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Windows/doors are operable and are kept closed?			No windows in room.	None		None
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None		None
102F	Temp	<input type="text" value="74.5"/>	RH% <input type="text" value="50.3"/>	CO2 <input type="text" value="899"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?		need to vacumn on a regular basis very dusty	General cleanliness of the room at the time of assessment was acceptable.	None		None
	Floor is cleaned on a regular basis?		need to vacumn on a regular basis very dusty	Floor was clean at the time of assessment.	None		None
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No exhaust fans in room. Identified in error.	None		None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
102F	Temp	<input type="text" value="74.5"/>	RH%	<input type="text" value="50.3"/>	CO2	<input type="text" value="899"/>	Occupants:	<input type="text"/>
THERMAL COMFORT								
Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.		None	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.		None	None		
Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was acceptable at the time of assessment.		None	None		
Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.		None	None		
102G	Temp	<input type="text" value="74.3"/>	RH%	<input type="text" value="53.6"/>	CO2	<input type="text" value="927"/>	Occupants:	<input type="text" value="2"/>
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.		None	None		
102N	Temp	<input type="text" value="73.4"/>	RH%	<input type="text" value="54.1"/>	CO2	<input type="text" value="920"/>	Occupants:	<input type="text" value="2"/>
THERMAL COMFORT								
Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.		None	None		
103A	Temp	<input type="text" value="73.4"/>	RH%	<input type="text" value="51.7"/>	CO2	<input type="text" value="1011"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Air flowing from air supply?			room is stuffy	Air flowing without obstruction at the time of assessments.		None	None	
Air is flowing without obstruction?			room is stuffy	Air flowing without obstruction at the time of assessments.		None	None	
Room is free of smell of mold or mildew?			room is stuffy	No odor detected at the time of assessment.		None	None	
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			trash is picked up daily but nothing else gets cleaned unless I do it, including pest control.	Dust observed on supply/return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?			trash is picked up daily but nothing else gets cleaned unless I do it, including pest control.	There does not appear to be a dusting issue within this room.		None	None	
Floor is cleaned on a regular basis?			trash is picked up daily but nothing else gets cleaned unless I do it, including pest control.	Floor was clean at the time of assessment.		None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
103A	Temp	<input type="text" value="73.4"/>	RH%	<input type="text" value="51.7"/>	CO2	<input type="text" value="1011"/>	Occupants:	<input type="text"/>
	Food, if any, is stored in tightly sealed containers?	trash is picked up daily but nothing else gets cleaned unless I do it, including pest control.			No unsealed food items were observed at the time of assessment.	None	None	
	Room is free of pests?	trash is picked up daily but nothing else gets cleaned unless I do it, including pest control.			No pests observed at the time of assessment.	None	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	trash is picked up daily but nothing else gets cleaned unless I do it, including pest control.			No issues identified relating to spill clean up practices at the time of assessment..	None	None	
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				No exhaust fans in room. Identified in error.	None	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None	None	
THERMAL COMFORT								
	Room is usually comfortable? (If no, please explain in the notes below.)	usually cold			Temperature was acceptable at the time of assessment.	None	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	usually cold			Temperature was acceptable at the time of assessment.	None	None	
103B	Temp	<input type="text" value="72.7"/>	RH%	<input type="text" value="54.7"/>	CO2	<input type="text" value="1024"/>	Occupants:	<input type="text" value="3"/>
GENERAL CLEANLINESS								
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	None	
103C	Temp	<input type="text" value="72.5"/>	RH%	<input type="text" value="54.8"/>	CO2	<input type="text" value="1003"/>	Occupants:	<input type="text" value="2"/>
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	None	
111C	Temp	<input type="text" value="72.5"/>	RH%	<input type="text" value="54.8"/>	CO2	<input type="text" value="1234"/>	Occupants:	<input type="text" value="29"/>
AIR CONDITIONING								
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None	
GENERAL CLEANLINESS								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
111C	Temp	72.5	RH%	54.8	CO2	1234	Occupants:	29			
	Classroom is dusted/vacuumed thoroughly and regularly?	This room contains book shelves which have not been dusted in years. It is also carpeted. The age of the carpet is not known and the vacuuming of it on a daily basis is not known. I think that if it is not vacuumed on a daily basis, the dust stays wher			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Classrooms general appearance is clean and acceptable?	This room contains book shelves which have not been dusted in years. It is also carpeted. The age of the carpet is not known and the vacuuming of it on a daily basis is not known. I think that if it is not vacuumed on a daily basis, the dust stays wher			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	Floor is cleaned on a regular basis?	This room contains book shelves which have not been dusted in years. It is also carpeted. The age of the carpet is not known and the vacuuming of it on a daily basis is not known. I think that if it is not vacuumed on a daily basis, the dust stays wher			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
111D	Temp	72.4	RH%	53.8	CO2	1040	Occupants:	1			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None				
	Windows/doors are operable and are kept closed?				Windows are not operable. Open doors and windows allow humid untreated air into occupied environment.	Physical Plant Operations to evaluate and repair as appropriate. However, site based administration to encourage staff to keep doors and windows closed.	Physical Plant Operations				3
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	None				
	THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None	None				
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	None				
113B	Temp	75.2	RH%	45.2	CO2	1144	Occupants:				
	AIR CONDITIONING										
	Windows/doors are operable and are kept closed?				No windows in room.	None	None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
113B	Temp	75.2	RH% 45.2	CO2 1144	Occupants:		
GENERAL CLEANLINESS							
Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT							
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None	None	
Walkthrough							
				There is a large amount of computer equipment in this room. Air supply vent needs to be installed directly above the computer equipment.	Physical Plant Operations to install air supply vent above the computer equipment.	Physical Plant Operations	2
121	Temp	74.8	RH% 50.9	CO2 1454	Occupants:	3	
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?				No sink in room.	None	None	
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	None	
Cold water pipes free of continuous condensation?				No pipes in room.	None	None	
Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation or signs of water intrusion identified at the time of assessment.	None	None	
Windows, windowsills and window frames free of continuous condensation?				No windows in room.	None	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate operation of HVAC system.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
121	Temp	74.8	RH% 50.9	CO2 1454	Occupants: 3		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None	None	
121B	Temp	74.5	RH% 48.9	CO2 1428	Occupants: 2		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Most of the time is excessively cold. Temperature shifts. The few days that temperature has been comfortable then a humidity odor arises.		Temperature was acceptable at the time of assessment.	None	None
	Room is usually comfortable? (If no, please explain in the notes below.)		Most of the time is excessively cold. Temperature shifts. The few days that temperature has been comfortable then a humidity odor arises.		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate operation of HVAC system.	Physical Plant Operations 2
	Temperature in my classroom is generally comfortable (72F-76F)?		Most of the time is excessively cold. Temperature shifts. The few days that temperature has been comfortable then a humidity odor arises.		Temperature was acceptable at the time of assessment.	None	None
122	Temp	74.6	RH% 51.1	CO2 1395	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
122	Temp	<input type="text" value="74.6"/>	RH%	<input type="text" value="51.1"/>	CO2	<input type="text" value="1395"/>	Occupants:	<input type="text"/>
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based		2
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate HVAC system for proper operation.	Site Based		2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations		2
122A	Temp	<input type="text" value="73.2"/>	RH%	<input type="text" value="55"/>	CO2	<input type="text" value="1584"/>	Occupants:	<input type="text"/>
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based		2
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Sometimes the room is VERY cold.	Temperature was acceptable at the time of assessment.	None		None
	Room is usually comfortable? (If no, please explain in the notes below.)			Sometimes the room is VERY cold.	Temperature was acceptable at the time of assessment.	None		None
	Temperature in my classroom is generally comfortable (72F-76F)?			Sometimes the room is VERY cold.	Temperature was acceptable at the time of assessment.	None		None
127	Temp	<input type="text" value="77.1"/>	RH%	<input type="text" value="58.1"/>	CO2	<input type="text" value="1661"/>	Occupants:	<input type="text" value="16"/>
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
	DRAIN TRAPS IN THE CLASSROOM							
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based		2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
127	Temp	77.1	RH% 58.1	CO2 1661	Occupants: 16		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.		None	None	
Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.		None	None	
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			THERE IS A SMELL IN THE ROOM WHEN YOU WALK IN		Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 2
128	Temp	75.1	RH% 62	CO2 1721	Occupants: 24		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.		Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			Room is usually extremely cold.		There does not appear to be a dusting issue within this room.	None	None
Classrooms general appearance is clean and acceptable?			Room is usually extremely cold.		General cleanliness of the room at the time of assessment was acceptable.	None	None
Floor is cleaned on a regular basis?			Room is usually extremely cold.		Floor was clean at the time of assessment.	None	None
THERMAL COMFORT							
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None	None
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)					Humidity was slightly elevated at the time of assessment - less than 10% greater than outdoors. Humidity slightly exceeded target range, however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system is dehumidifying fresh air.	Facilities serviceperson should monitor this room.	Site Based 3
Room is usually comfortable? (If no, please explain in the notes below.)					Temperature was acceptable at the time of assessment.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
128	Temp	75.1	RH% 62	CO2 1721	Occupants: 24		
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	None
129	Temp	73.6	RH% 63.9	CO2 1980	Occupants: 21		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Other than sweeping, the floor is cleaned at the beginning of the school year and then not at all. Dirt on the floor accumulates greatly.		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?		Other than sweeping, the floor is cleaned at the beginning of the school year and then not at all. Dirt on the floor accumulates greatly.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?		Other than sweeping, the floor is cleaned at the beginning of the school year and then not at all. Dirt on the floor accumulates greatly.		Floor was clean at the time of assessment.	None	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		The room temperature fluctuates from being cold to being warm and stuffy.		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates. Humidity level was slightly elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)		The room temperature fluctuates from being cold to being warm and stuffy.		Temperature was acceptable at the time of assessment.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?		The room temperature fluctuates from being cold to being warm and stuffy.		Temperature was acceptable at the time of assessment.	None	None
132	Temp	80.2	RH% 69.3	CO2 2139	Occupants:		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based
	GENERAL CLEANLINESS						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
132	Temp	80.2	RH% 69.3	CO2 2139	Occupants:		
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
141	Temp	79.4	RH% 58.9	CO2 1973	Occupants:		
	THERMAL COMFORT						
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature and humidity elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	1
	Walkthrough						
				Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
142	Temp	75.3	RH% 63.1	CO2 2136	Occupants:	2	
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Always cold	Temperature was acceptable at the time of assessment.	None	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Always cold	Humidity was slightly elevated at the time of assessment - less than 10% greater than outdoors. Humidity slightly exceeded target range, however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system is dehumidifying fresh air.	Facilities serviceperson should monitor this room.	Site Based	3
	Temperature in my classroom is generally comfortable (72F-76F)?		Always cold	Temperature was acceptable at the time of assessment.	None	None	
143	Temp	71.3	RH% 62	CO2 1409	Occupants:	26	
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
143	Temp	71.3	RH% 62	CO2 1409	Occupants: 26			
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	My classroom is very chilly; however, I would prefer a cold classroom to a warm one!			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	My classroom is very chilly; however, I would prefer a cold classroom to a warm one!			Temperature was low at the time of assessment.	None	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	My classroom is very chilly; however, I would prefer a cold classroom to a warm one!			Temperature was low at the time of assessment.	None	None	
144	Temp	69.4	RH% 63.4	CO2 1449	Occupants: 17			
AIR CONDITIONING								
	Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None	None	
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	None	
THERMAL COMFORT								
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	None	
Walkthrough								
					Temperature was low at the time of assessment and humidity was slightly elevated.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
145	Temp	69.8	RH% 58.2	CO2 1470	Occupants: 11		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
146	Temp	68.8	RH% 55.1	CO2 1875	Occupants:		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		The room is usually a little too cold. Students complain about everyday that the room is a too cold and they usually have warm clothing on as well.		Temperature was low at the time of assessment.	None	None
	Room is usually comfortable? (If no, please explain in the notes below.)		The room is usually a little too cold. Students complain about everyday that the room is a too cold and they usually have warm clothing on as well.		Temperature was low at the time of assessment.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?		The room is usually a little too cold. Students complain about everyday that the room is a too cold and they usually have warm clothing on as well.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
147	Temp	68.5	RH% 63.1	CO2 1554	Occupants: 31		
THERMAL COMFORT							
Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based		2
Walkthrough							
Dust observed on return register at the time of assessment.			Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based			2
148	Temp	59	RH% 52.3	CO2 1753	Occupants: 29		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Fume hood vent extending from ceiling leaks into room whenever it rains hard.	No leaks or signs of water intrusion identified.	None	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Floor needs to be washed occasionally. Dusting is nice too. I wash my own student desks on a bi-weekly basis.	No dust observed on supply/return registers at the time of assessment.	None	None	
Classroom is dusted/vacuumed thoroughly and regularly?			Floor needs to be washed occasionally. Dusting is nice too. I wash my own student desks on a bi-weekly basis.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?			Floor needs to be washed occasionally. Dusting is nice too. I wash my own student desks on a bi-weekly basis.	Floor was clean at the time of assessment.	None	None	
Room is free of pests?			Floor needs to be washed occasionally. Dusting is nice too. I wash my own student desks on a bi-weekly basis.	No pests observed at the time of assessment.	None	None	
Walkthrough							
Temperature was low at the time of assessment. Four supply vents were closed.			Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based			2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

149

Temp RH% CO2 Occupants:

AIR CONDITIONING

Windows/doors are operable and are kept closed?

Windows and doors are operable and are kept closed.

None

None

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

ART SUPPLIES

Industrial supplies okay?

No industrial supplies in room. Room not being used as an industrial room.

None

None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Room is free of pests?

No pests observed at the time of assessment.

None

None

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-76F)?

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

150

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

Room has a sour milk odor.

No odor detected at the time of assessment. Occupant indicated problem resolved.

None

None

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
150	Temp	69.8	RH%		CO2	1527	Occupants:	17			
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
DRAIN TRAPS IN THE CLASSROOM											
	Water poured down floor drains once per week (approx. 1 quart of water).			My sink is filled with gases and no matter how much we run it, it makes an enormous amount of noise.	No floor drain in room.	None				None	
GENERAL CLEANLINESS											
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Room is extremely dusty. The floor is swept daily, but needs to be mopped at least once a week. The room is constantly dusty no matter how much I try to clean too.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	Classroom is dusted/vacuumed thoroughly and regularly?			Room is extremely dusty. The floor is swept daily, but needs to be mopped at least once a week. The room is constantly dusty no matter how much I try to clean too.	There does not appear to be a dusting issue within this room.	None				None	
	Classrooms general appearance is clean and acceptable?			Room is extremely dusty. The floor is swept daily, but needs to be mopped at least once a week. The room is constantly dusty no matter how much I try to clean too.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Floor is cleaned on a regular basis?			Room is extremely dusty. The floor is swept daily, but needs to be mopped at least once a week. The room is constantly dusty no matter how much I try to clean too.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
LOCKER ROOM											
	Locker room and showers cleaned regularly and properly?				Issues not applicable. Room is not a locker room.	None				None	
	Soiled clothes and towels are removed regularly?				Issues not applicable. Room is not a locker room.	None				None	
THERMAL COMFORT											
	Classroom is free of significant temperature shifts?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

151

Temp RH% CO2

Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

None

Windows/doors are operable and are kept closed?

Windows and doors are operable and are kept closed.

None

None

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Room is free of pests?

No pests observed at the time of assessment.

None

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No bathroom. Identified in error.

None

152

Temp RH% CO2

Occupants:

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

Dust observed on supply/return registers at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
152	Temp	68.8	RH% 62.1	CO2 1635	Occupants: 17		
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was low at the time of assessment.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
154	Temp	69.5	RH% 61.2	CO2 1364	Occupants: 21		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
155	Temp	71.9	RH% 52.5	CO2 1967	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Classroom lavatories/water fountains free of leaks?		Teacher bathroom in planning has leaky faucets.		No lavatories/water fountains in room.	None	None
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		My classroom floor has not been mopped since the beginning of the year and the only dusting the room receives is if I clean it on teacher planning days.		No dust observed on supply/return registers at the time of assessment.	None	None
	Classroom is dusted/vacuumed thoroughly and regularly?		My classroom floor has not been mopped since the beginning of the year and the only dusting the room receives is if I clean it on teacher planning days.		There does not appear to be a dusting issue within this room.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
155	Temp	71.9	RH% 52.5	CO2 1967	Occupants:		
	Floor is cleaned on a regular basis?	My classroom floor has not been mopped since the beginning of the year and the only dusting the room receives is if I clean it on teacher planning days.			Floor was clean at the time of assessment.	None	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	None
156	Temp	72.8	RH% 58.2	CO2 1580	Occupants:	24	
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
157	Temp	69.2	RH% 50.2	CO2 1654	Occupants:	2	
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?	surface cleaning is done well. However, tops of cabinets and some equipment are covered in dust.			There does not appear to be a dusting issue within this room.	None	None
158	Temp	70.4	RH% 56.6	CO2 1255	Occupants:	2	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?	classroom is unusually cold.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Room is usually comfortable? (If no, please explain in the notes below.)	classroom is unusually cold.			Temperature was low at the time of assessment.		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority						
158	Temp	70.4	RH%	56.6	CO2	1255	Occupants:	2					
	Temperature in my classroom is generally comfortable (72F-76F)?			classroom is unusually cold.			Temperature was low at the time of assessment.						
	Walkthrough												
							Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.		Site Based	2	
159	Temp	70.5	RH%	51.6	CO2	1807	Occupants:	33					
	GENERAL CLEANLINESS												
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.			Site based administration should address general cleanliness with facility serviceperson staff.			Site Based	2		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.			Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.			Site Based	2		
160	Temp	72.3	RH%	58.9	CO2	1572	Occupants:	20					
	THERMAL COMFORT												
	Classroom is free of significant temperature shifts?			The room is sometimes very cold and other times comfortable. I would like it to stay at a comfortable temperature of 75+.			Temperature was acceptable at the time of assessment.			Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.		Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)			The room is sometimes very cold and other times comfortable. I would like it to stay at a comfortable temperature of 75+.			Temperature was acceptable at the time of assessment.			None			
	Temperature in my classroom is generally comfortable (72F-76F)?			The room is sometimes very cold and other times comfortable. I would like it to stay at a comfortable temperature of 75+.			Temperature was acceptable at the time of assessment.			Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.		Site Based	2
162	Temp	72.8	RH%	59.1	CO2	1393	Occupants:	14					
	ANIMALS IN THE CLASSROOM												
	You are informed about the potential allergies of your students?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.			Site Based	3		
	GENERAL CLEANLINESS												

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
162	Temp	72.8	RH% 59.1	CO2 1393	Occupants: 14		
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		too cold		Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Temperature in my classroom is generally comfortable (72F-76F)?		too cold		Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
163	Temp	72.3	RH% 57.2	CO2 1486	Occupants: 23		
	DRAIN TRAPS IN THE CLASSROOM						
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	None
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None	None
165	Temp	72.7	RH% 57.2	CO2 1486	Occupants: 23		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		My room has been comfortable recently, but was previously very cold (60 - 65)		Temperature was acceptable at the time of assessment.	None	None
	Room is usually comfortable? (If no, please explain in the notes below.)		My room has been comfortable recently, but was previously very cold (60 - 65)		Temperature was acceptable at the time of assessment.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
166	Temp	73.4	RH% 58.8	CO2 1375	Occupants: 22			
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Classroom is ALWAYS FILLED with dust, certain areas of the floor are rarely cleaned, sink and countertops are NEVER cleaned			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	Classroom is ALWAYS FILLED with dust, certain areas of the floor are rarely cleaned, sink and countertops are NEVER cleaned			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	Often too cold!!! Sometimes it seems to be below 65 in here!			Temperature was acceptable at the time of assessment.	None	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	Often too cold!!! Sometimes it seems to be below 65 in here!			Temperature was acceptable at the time of assessment.	None	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	Often too cold!!! Sometimes it seems to be below 65 in here!			Temperature was acceptable at the time of assessment.	None	None	
167	Temp	70.2	RH% 60.0	CO2 1461	Occupants:			
GENERAL CLEANLINESS								
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None	
168	Temp	74.5	RH% 56.2	CO2 1459	Occupants: 24			
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	floor is filthy; paper scraps cleaned, but floor is never mopped; dust bunnies rampant			No dust observed on supply/return registers at the time of assessment.	None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?	floor is filthy; paper scraps cleaned, but floor is never mopped; dust bunnies rampant			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?	floor is filthy; paper scraps cleaned, but floor is never mopped; dust bunnies rampant			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	floor is filthy; paper scraps cleaned, but floor is never mopped; dust bunnies rampant			Floor was clean at the time of assessment.	None	None	
THERMAL COMFORT								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

168

Temp RH% CO2

Occupants:

Classroom is free of significant temperature shifts?

often FREEZING in here, even MORE so in certain spots in the room; as weather gets warmer outside; the humidity in here is EXCESSIVE; some days it is OUTRIGHT HOT in here; students and teacher are NEVER comfortable in here

Temperature was acceptable at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

often FREEZING in here, even MORE so in certain spots in the room; as weather gets warmer outside; the humidity in here is EXCESSIVE; some days it is OUTRIGHT HOT in here; students and teacher are NEVER comfortable in here

Humidity was slightly elevated at the time of assessment - less than 10% greater than outdoors. Humidity slightly exceeded target range, however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system is dehumidifying fresh air.

Facilities serviceperson should monitor this room.

Site Based

3

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

often FREEZING in here, even MORE so in certain spots in the room; as weather gets warmer outside; the humidity in here is EXCESSIVE; some days it is OUTRIGHT HOT in here; students and teacher are NEVER comfortable in here

No gaps in windows or doors identified at the time of assessment.

None

None

Room is usually comfortable? (If no, please explain in the notes below.)

often FREEZING in here, even MORE so in certain spots in the room; as weather gets warmer outside; the humidity in here is EXCESSIVE; some days it is OUTRIGHT HOT in here; students and teacher are NEVER comfortable in here

Environmental parameters were not within acceptable range at the time of assessment..

Physical Plant Operations to evaluate need for test and balance.

Physical Plant Operations

2

Temperature in my classroom is generally comfortable (72F-76F)?

often FREEZING in here, even MORE so in certain spots in the room; as weather gets warmer outside; the humidity in here is EXCESSIVE; some days it is OUTRIGHT HOT in here; students and teacher are NEVER comfortable in here

Temperature was acceptable at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

169

Temp RH% CO2

Occupants:

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Room is VERY cold. Students and staff complain daily. The rooms along the outside wall are very cold while some inside rooms are warm.

Temperature was elevated at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
169	Temp	75.3	RH% 58.3	CO2 1140	Occupants:		
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is VERY cold. Students and staff complain daily. The rooms along the outside wall are very cold while some inside rooms are warm.	Temperature was elevated at the time of assessment.			
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is VERY cold. Students and staff complain daily. The rooms along the outside wall are very cold while some inside rooms are warm.	Temperature was elevated at the time of assessment.			
170	Temp	74.3	RH% 59.7	CO2 1116	Occupants:	20	
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		My room is very cold and uncomfortable. Students mention the temperature daily. My own thermometer reads 55-58 degrees.	Temperature was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		My room is very cold and uncomfortable. Students mention the temperature daily. My own thermometer reads 55-58 degrees.	No gaps in windows or doors identified at the time of assessment.	None		None
	Room is usually comfortable? (If no, please explain in the notes below.)		My room is very cold and uncomfortable. Students mention the temperature daily. My own thermometer reads 55-58 degrees.	Environmental parameters were within acceptable range at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		My room is very cold and uncomfortable. Students mention the temperature daily. My own thermometer reads 55-58 degrees.	Temperature was acceptable at the time of assessment.	None		
171	Temp	75.5	RH% 57	CO2 1131	Occupants:	25	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	None
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
171	Temp	<input type="text" value="75.5"/>	RH% <input type="text" value="57"/>	CO2 <input type="text" value="1131"/>	Occupants: <input type="text" value="25"/>		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		It is freezing in here. Once in a while it is hot and then the next day it is even colder!!!		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)		It is freezing in here. Once in a while it is hot and then the next day it is even colder!!!		Temperature was elevated at the time of assessment.			
Temperature in my classroom is generally comfortable (72F-76F)?		It is freezing in here. Once in a while it is hot and then the next day it is even colder!!!		Temperature was elevated at the time of assessment.		Site Based	
182	Temp	<input type="text" value="73.9"/>	RH% <input type="text" value="57.6"/>	CO2 <input type="text" value="1238"/>	Occupants: <input type="text" value="10"/>		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	None	
Walkthrough				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
183	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
186	Temp	75.8	RH% 56.9	CO2 1369	Occupants:	14	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			may be too hot or too cold	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?			may be too hot or too cold	Temperature was elevated at the time of assessment.			
186B	Temp	75.5	RH% 56.37	CO2 1237	Occupants:	14	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?			Had an ant problem for awhile, but it seems that has passed.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?			Had an ant problem for awhile, but it seems that has passed.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Cold water pipes free of continuous condensation?				No pipes in room.	None	None	
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
186B	Temp	75.5	RH%	56.37	CO2	1237	Occupants:	14		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		This room (actually Room #286) gets a very warm, very quick, but that may just be due to the fact that it is on the East side of the building, and a lot of sunlight pours through the window over the emergency doorway. Perhaps the window can be tinted?	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2	
	Classroom is dusted/vacuumed thoroughly and regularly?		This room (actually Room #286) gets a very warm, very quick, but that may just be due to the fact that it is on the East side of the building, and a lot of sunlight pours through the window over the emergency doorway. Perhaps the window can be tinted?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2	
	THERMAL COMFORT									
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Too hot!	Humidity was acceptable at the time of assessment.	None					
	Room is usually comfortable? (If no, please explain in the notes below.)		Too hot!	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based			2	
	Temperature in my classroom is generally comfortable (72F-76F)?		Too hot!	Temperature was elevated at the time of assessment.						
187	Temp	70.4	RH%	65.1	CO2	1275	Occupants:	2		
	GENERAL CLEANLINESS									
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None				
188	Temp	72	RH%	63	CO2	1250	Occupants:	11		
	AIR CONDITIONING									
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None				
	ART SUPPLIES									
	Art supplies okay?			No art supplies in room. Room not being used as an art room.	None	None				
	Following good handling and storage practices for art supplies?			No art supplies in room. Room not being used as an art room.	None	None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
188	Temp	72	RH% 63	CO2 1250	Occupants: 11		
DRAIN TRAPS IN THE CLASSROOM							
	Water run in sinks at least once per week (about 2 cups of water).			No sink in room.	None		None
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?			No sink in room.	None		None
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		None
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		None
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		None
	Room is free of the use of scented cleaners and air fresheners?			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		None
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		None
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		None
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			It appears that the ventilation system is adequate based on room activities.	None		None
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None		None
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		i could get very cold	Temperature was acceptable at the time of assessment.			
	Room is usually comfortable? (If no, please explain in the notes below.)		i could get very cold	Temperature was acceptable at the time of assessment.			
	Temperature in my classroom is generally comfortable (72F-76F)?		i could get very cold	Temperature was acceptable at the time of assessment.			

190A

Temp 70.9 RH% 59.5 CO2 1403 Occupants: 27

AIR CONDITIONING

Room is free of smell of mold or mildew?	Carpet is old...and there is a slight smell of mildew.	Odor detected and microbial growth identified.	Physical Plant operations to evaluate cause of microbial growth and repair and remediate as appropriate.	Physical Plant Operations	1
--	--	--	--	---------------------------	---

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
190A	Temp	70.9	RH% 59.5	CO2 1403	Occupants: 27		
ART SUPPLIES							
Science supplies okay?				No science supplies in room. Room not being used as a science room.	None	None	
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		Room is very cold - usually about 67 degrees.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?		Room is very cold - usually about 67 degrees.		Temperature was low at the time of assessment.			
193	Temp	72.2	RH% 57.2	CO2 1429	Occupants: 20		
DRAIN TRAPS IN THE CLASSROOM							
Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Floor needs to be washed periodically.		No dust observed on supply/return registers at the time of assessment.	None	None	
Classroom is dusted/vacuumed thoroughly and regularly?		Floor needs to be washed periodically.		There does not appear to be a dusting issue within this room.	None	None	
Floor is cleaned on a regular basis?		Floor needs to be washed periodically.		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		Too cold for children.		Temperature was acceptable at the time of assessment.	None	None	
Temperature in my classroom is generally comfortable (72F-76F)?		Too cold for children.		Temperature was acceptable at the time of assessment.	None	None	
194	Temp	69.9	RH% 58.8	CO2 1504	Occupants: 32		
ART SUPPLIES							
Following good handling and storage practices for art supplies?				No art supplies in room. Room not being used as an art room.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
194	Temp	69.9	RH% 58.8	CO2 1504	Occupants: 32		
	Following good handling and storage practices for industrial supplies?			No industrial supplies in room. Room not being used as an industrial room.	None	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None	None	
	Cold water pipes free of continuous condensation?			No visible condensation at the time of assessment.	None	None	
	Indoor surfaces of exterior walls free of continuous condensation?			No visible condensation at the time of assessment.	None	None	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None	None	
203	Temp	72.8	RH% 65.5	CO2 1491	Occupants: 61		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?		There are carpets on the walls that need attention, they are very dusty.	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
206	Temp	72.7	RH% 65.1	CO2	Occupants: 28		
	GENERAL CLEANLINESS						
	Room is free of pests?			No pests observed at the time of assessment.	None	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		The air goes out a lot in the room. Some days the temperature is perfectly cool, and other days the air is off and extremely hot.	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
207	Temp	72.4	RH% 65.6	CO2	Occupants: 16		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
207	Temp	72.4	RH% 65.6	CO2	Occupants: 16		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	None	
211A	Temp	70.5	RH% 68.5	CO2 654	Occupants: 2		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None	None	
Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None	None	
GENERAL CLEANLINESS							
Room is free of pests?				No pests observed at the time of assessment.	None	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
213	Temp	69.9	RH% 68.9	CO2 637	Occupants: 2		
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None	None	
EXCESS MOISTURE IN CLASSROOMS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
213	Temp	69.9	RH% 68.9	CO2 637	Occupants: 2		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	shower heads leak		Leak identified at shower head.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	shower area needs regular cleaning		No dust observed on supply/return registers at the time of assessment.	None	None	
	Floor is cleaned on a regular basis?	shower area needs regular cleaning		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None	None	
LOCKER ROOM							
	Locker room and showers cleaned regularly and properly?			General cleanliness of the locker room and showers was not acceptable at the time of assessment.	Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.	Site Based	2
Walkthrough							
				Temperature was low at the time of assessment and humidity level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to increase temperature and lower humidity level.	Physical Plant Operations	1
226	Temp	72.9	RH% 65.0	CO2 913	Occupants: 200		
AIR CONDITIONING							
	Room is free of smell of kitchen/food?			Odor detected at the time of assessment. Room is kitchen.	None	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None	None	
	Room is usually comfortable? (If no, please explain in the notes below.)			Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
227	Temp	83.7	RH% 54.0	CO2 622	Occupants: 8		
AIR CONDITIONING							
Air flowing from air supply?			Air supply/return ventilation is not functioning qualitatively.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	1	
Air is flowing without obstruction?			Air supply/return ventilation is not functioning qualitatively.				
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?			No lavatories/water fountains in room.	None	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None	None		
Other exhaust fans that may exist in the classroom are functioning properly?			No exhaust fans in room. Identified in error.	None	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			during winter months extremely cold in the other month too hot unbearable almost workers have to break to get cooled off to keep from passing out	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			during winter months extremely cold in the other month too hot unbearable almost workers have to break to get cooled off to keep from passing out	Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			during winter months extremely cold in the other month too hot unbearable almost workers have to break to get cooled off to keep from passing out	Temperature was elevated at the time of assessment.			
Temperature in my classroom is generally comfortable (72F-76F)?			during winter months extremely cold in the other month too hot unbearable almost workers have to break to get cooled off to keep from passing out	Temperature was elevated at the time of assessment.			

281 Temp 74.1 RH% 43.4 CO2 3710 Occupants: 13

AIR CONDITIONING

Room is free of smell of mold or mildew? No odor detected at the time of assessment. None None

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

281

Temp RH% CO2 Occupants:

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

None

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

None

None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

None

Room is free of pests?

No pests observed at the time of assessment.

None

None

Walkthrough

CO2 level was elevated at the time of the assessment.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.

Dust and debris on HVAC coils.

Physical Plant operations to evaluate and clean HVAC coils.

Physical Plant Operations

1

338

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Floors need to cleaned frequently with clean water, portables track a lot of dust and dirt, worst when it rains. Shelves needs to be dusted occasionally. The overall quality is poor and needs improvement.

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

Floors need to cleaned frequently with clean water, portables track a lot of dust and dirt, worst when it rains. Shelves needs to be dusted occasionally. The overall quality is poor and needs improvement.

There does not appear to be a dusting issue within this room.

None

None

Classrooms general appearance is clean and acceptable?

Floors need to cleaned frequently with clean water, portables track a lot of dust and dirt, worst when it rains. Shelves needs to be dusted occasionally. The overall quality is poor and needs improvement.

General cleanliness of the room at the time of assessment was acceptable.

None

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
338	Temp	74.8	RH%	49.9	CO2	2777	Occupants:	20			
	Floor is cleaned on a regular basis?	Floors need to cleaned frequently with clean water, portables track a lot of dust and dirt, worst when it rains. Shelves needs to be dusted occasionally. The overall quality is poor and needs improvement.			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	Room is free of pests?	Floors need to cleaned frequently with clean water, portables track a lot of dust and dirt, worst when it rains. Shelves needs to be dusted occasionally. The overall quality is poor and needs improvement.			No pests observed at the time of assessment.	None	None				
	Walkthrough				CO2 level was elevated at the time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations				1
718C	Temp	71.3	RH%	53.7	CO2	2742	Occupants:	15			
	ANIMALS IN THE CLASSROOM										
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Floors in the portables need to be mopped more frequently because there is a lot of dust and dirt tracked into the rooms especially now since there is construction going on outside.			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	Classroom is dusted/vacuumed thoroughly and regularly?	Floors in the portables need to be mopped more frequently because there is a lot of dust and dirt tracked into the rooms especially now since there is construction going on outside.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Classrooms general appearance is clean and acceptable?	Floors in the portables need to be mopped more frequently because there is a lot of dust and dirt tracked into the rooms especially now since there is construction going on outside.			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				3
	Floor is cleaned on a regular basis?	Floors in the portables need to be mopped more frequently because there is a lot of dust and dirt tracked into the rooms especially now since there is construction going on outside.			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
718C	Temp	71.3	RH% 53.7	CO2 2742	Occupants: 15		
	Room is free of pests?	Floors in the portables need to be mopped more frequently because there is a lot of dust and dirt tracked into the rooms especially now since there is construction going on outside.			No pests observed at the time of assessment.	None	None
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	Floors in the portables need to be mopped more frequently because there is a lot of dust and dirt tracked into the rooms especially now since there is construction going on outside.			There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	None
	Other exhaust fans that may exist in the classroom are functioning properly?				No exhaust fans in room. Identified in error.	None	None
Walkthrough							
					CO2 level was elevated at the time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations 1
833C	Temp		RH%	CO2	Occupants: 23		
AIR CONDITIONING							
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None	None
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
Walkthrough							
					Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.	Physical Plant Operations 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
928C	Temp	73.6	RH% 64	CO2 1893	Occupants:	20	
ART SUPPLIES							
Following good handling and storage practices for science supplies?				No science supplies in room. Room not being used as a science room.	None	None	
Science supplies okay?				No science supplies in room. Room not being used as a science room.	None	None	
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None	
Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Room is free of pests?				No pests observed at the time of assessment.	None	None	
Walkthrough							
				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
				Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.	Physical Plant Operations	1
929C	Temp	74.4	RH% 45.5	CO2 2808	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	None	
Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	None	
GENERAL CLEANLINESS							
Room is free of pests?				No pests observed at the time of assessment.	None	None	
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Walkthrough							

FISH/Room	Participant Comments				Response	Recommendation	Responsible	Priority
929C	Temp	74.4	RH%	45.5	CO2	2808	Occupants:	
					CO2 level was elevated at the time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	1
					Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.	Physical Plant Operations	1