

Driftwood Middle

IAQ Walkthrough 4/27/2005

0861

Outside Temp RH% CO2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
102AA	Temp	<input type="text" value="73"/>	RH% <input type="text" value="51"/>	CO2 <input type="text" value="1075"/>	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	Walkthrough			Live plants in room.	Facilities serviceperson should remove live plants.	Site Based	1
102M	Temp	<input type="text" value="74.2"/>	RH% <input type="text" value="51.5"/>	CO2 <input type="text" value="1082"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			there is curd bubbling from under paint.	Repair was in progress at the time of the assessment.	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			The wallboard is coming off the wall and there is "crud" bubbling from under the paint!!!	Exterior walls being sealed and repair being done at the time of the assessment.	None	
	Windows, windowsills and window frames free of continuous condensation?			The wallboard is coming off the wall and there is "crud" bubbling from under the paint!!!	Exterior walls being sealed and repair being done at the time of the assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			The room is unbearably hot from March to December. The SE exposure makes that side of the building like that in every office.	Environmental parameters were within acceptable range at the time of assessment..	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
102M	Temp	<input type="text" value="74.2"/>	RH%	<input type="text" value="51.5"/>	CO2	<input type="text" value="1082"/>	Occupants:	<input type="text"/>
	Room is usually comfortable? (If no, please explain in the notes below.)		The room is unbearably hot from March to December. The SE exposure makes that side of the building like that in every office.	Environmental parameters were within acceptable range at the time of assessment..		None		
	Temperature in my classroom is generally comfortable (72F-76F)?		The room is unbearably hot from March to December. The SE exposure makes that side of the building like that in every office.	Temperature was acceptable at the time of assessment.		None		
102S	Temp	<input type="text" value="74"/>	RH%	<input type="text" value="53"/>	CO2	<input type="text" value="1160"/>	Occupants:	<input type="text"/>
	ANIMALS IN THE CLASSROOM							
	Classroom is free of animals and pets?		N/A	No animals identified at the time of assessment.		None		
	You are informed about the potential allergies of your students?		N/A			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS							
	Windows, windowsills and window frames free of continuous condensation?		N/A.	No issues identified at the time of assessment.		None		
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?		The general quality of Driftwood Middle School is clean and conducive to learning.	General cleanliness of the room at the time of assessment was acceptable.		None		
	Food, if any, is stored in tightly sealed containers?		The general quality of Driftwood Middle School is clean and conducive to learning.	No issues identified at the time of assessment.		None		
	Room is free of pests?		The general quality of Driftwood Middle School is clean and conducive to learning.	No pests observed at the time of assessment.		None		
	LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?		N/A.	Exhaust fan is functioning properly.		None		
201A	Temp	<input type="text" value="71.1"/>	RH%	<input type="text" value="63.2"/>	CO2	<input type="text" value="813"/>	Occupants:	<input type="text"/>
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None		
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.		None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.		None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
201A	Temp	71.1	RH% 63.2	CO2 813	Occupants:			
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	The room is frequently cold..the temperature is usually 68%			Environmental parameters were within acceptable range at the time of assessment..	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	The room is frequently cold..the temperature is usually 68%			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	The room is frequently cold..the temperature is usually 68%			Temperature was slightly low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
202A	Temp	71.1	RH% 63.2	CO2 964	Occupants:			
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS								
	Indoor surfaces of exterior walls free of continuous condensation?				No issues identified at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None		
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
202A	Temp	71.1	RH%	63.2	CO2	964	Occupants:	<input type="text"/>			
	Classroom is free of significant temperature shifts?	The temperature inside my classroom ranges FROM 68 TO 69 DEGREES! (I have two thermometers in the room.) We freeze every day, despite the sweaters I myself wear and the ones I keep handy for my students. Reporting this to the maintenance staff has little			No issues identified at the time of assessment.	None					
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	The temperature inside my classroom ranges FROM 68 TO 69 DEGREES! (I have two thermometers in the room.) We freeze every day, despite the sweaters I myself wear and the ones I keep handy for my students. Reporting this to the maintenance staff has little			Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations				2
	Room is usually comfortable? (If no, please explain in the notes below.)	The temperature inside my classroom ranges FROM 68 TO 69 DEGREES! (I have two thermometers in the room.) We freeze every day, despite the sweaters I myself wear and the ones I keep handy for my students. Reporting this to the maintenance staff has little			No issues identified at the time of assessment.	None					
	Temperature in my classroom is generally comfortable (72F-76F)?	The temperature inside my classroom ranges FROM 68 TO 69 DEGREES! (I have two thermometers in the room.) We freeze every day, despite the sweaters I myself wear and the ones I keep handy for my students. Reporting this to the maintenance staff has little			Temperature was low at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations				2
216	Temp	71.9	RH%	65.6	CO2	961	Occupants:	<input type="text"/>			
	THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations				2
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was low at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations				2
	Walkthrough										
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
307	Temp	71.6	RH%	61.3	CO2	1141	Occupants:	<input type="text"/>			
	ART SUPPLIES										
	Science supplies okay?				No issues identified at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

307

Temp RH% CO2 Occupants:

DRAIN TRAPS IN THE CLASSROOM

Water poured down floor drains once per week (approx. 1 quart of water).

No issues identified at the time of assessment. None

Water run in sinks at least once per week (about 2 cups of water).

No issues identified at the time of assessment. None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment. None

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff. Site Based 2

Room is free of pests?

No pests observed at the time of assessment. None

LOCAL EXHAUST FANS

Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)

The purge fan does not work. There is no bathroom fan.

Exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair as appropriate. Physical Plant Operations 1

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

The purge fan does not work. There is no bathroom fan.

See other recommendation. None

Other exhaust fans that may exist in the classroom are functioning properly?

The purge fan does not work. There is no bathroom fan.

See other recommendation. None

THERMAL COMFORT

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

The room is often too cold for students that come to school in shorts and t shirt

Humidity was slightly elevated at the time of assessment. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level. Physical Plant Operations 2

Room is usually comfortable? (If no, please explain in the notes below.)

The room is often too cold for students that come to school in shorts and t shirt

See other recommendation. None

308

Temp RH% CO2 Occupants:

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Some old discoloration on ceiling tiles.

Stained ceiling tiles. Physical Plant Operations to evaluate for leaks and repair as appropriate. Physical Plant Operations 1

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

See previous note regarding purge fan. Not sure it is working properly. It makes noise initially but then we cannot hear it run.

Exhaust fan is functioning properly. Physical Plant Operations to evaluate and repair as appropriate. Physical Plant Operations 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

308

Temp RH% CO2

Occupants:

Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)

See previous note regarding purge fan. Not sure it is working properly. It makes noise initially but then we cannot hear it run.

See other recommendation to repair exhaust fan.

None

Other exhaust fans that may exist in the classroom are functioning properly?

See previous note regarding purge fan. Not sure it is working properly. It makes noise initially but then we cannot hear it run.

Exhaust fan is not functioning properly.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

1

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Last week the room was warmer and more humid. After being adjusted it seems better this week but it is still warmer and more humid in the room than it was in the beginning of the school year.

Environmental parameters were within acceptable range at the time of assessment..

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Last week the room was warmer and more humid. After being adjusted it seems better this week but it is still warmer and more humid in the room than it was in the beginning of the school year.

Humidity was acceptable at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

Last week the room was warmer and more humid. After being adjusted it seems better this week but it is still warmer and more humid in the room than it was in the beginning of the school year.

Environmental parameters were within acceptable range at the time of assessment..

None

Temperature in my classroom is generally comfortable (72F-76F)?

Last week the room was warmer and more humid. After being adjusted it seems better this week but it is still warmer and more humid in the room than it was in the beginning of the school year.

Temperature was acceptable at the time of assessment.

None

309

Temp RH% CO2

Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

While the floor is swept regularly, it is not regularly waxed or mopped to remove ground in dirt. Dust is a regular problem in my room, as I have a dust allergy.

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

While the floor is swept regularly, it is not regularly waxed or mopped to remove ground in dirt. Dust is a regular problem in my room, as I have a dust allergy.

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Room is free of pests?

While the floor is swept regularly, it is not regularly waxed or mopped to remove ground in dirt. Dust is a regular problem in my room, as I have a dust allergy.

No pests observed at the time of assessment.

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
309	Temp	<input type="text" value="74.4"/>	RH% <input type="text" value="63.2"/>	CO2 <input type="text" value="1000"/>	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
Other exhaust fans that may exist in the classroom are functioning properly?		The wall mounted purge fan in the front of the classroom is only partially functioning.		Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was slightly elevated at the time of assessment .	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
314	Temp	<input type="text" value="72.6"/>	RH% <input type="text" value="74"/>	CO2 <input type="text" value="1034"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None		
EXCESS MOISTURE IN CLASSROOMS							
Classroom lavatories/water fountains free of leaks?				No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
Room is free of pests?				No pests observed at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Humidity was elevated at the time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
401	Temp	<input type="text" value="71"/>	RH% <input type="text" value="62"/>	CO2 <input type="text" value="779"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
401	Temp	<input type="text" value="71"/>	RH% <input type="text" value="62"/>	CO2 <input type="text" value="779"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	Floor needs to be washed more often.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Floor needs to be washed more often.		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?	Floor needs to be washed more often.		No pests observed at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?	Floor needs to be washed more often.		No issues identified regarding trash removal practices.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	As the day progresses, room temperature drops and the room becomes very cold.		See other recommendation.			
	Room is usually comfortable? (If no, please explain in the notes below.)	As the day progresses, room temperature drops and the room becomes very cold.		See other recommendation.			
	Temperature in my classroom is generally comfortable (72F-76F)?	As the day progresses, room temperature drops and the room becomes very cold.		Temperature was low and humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
402	Temp	<input type="text" value="72"/>	RH% <input type="text" value="58.7"/>	CO2 <input type="text" value="682"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?	Smell of Mildew in closet, mold on closet walls.		No odor detected at the time of assessment. Site based staff advised that they cleaned with wexcide and growth never returned.	None		
DRAIN TRAPS IN THE CLASSROOM							
	Water run in sinks at least once per week (about 2 cups of water).			No issues identified at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
402	Temp	<input type="text" value="72"/>	RH% <input type="text" value="58.7"/>	CO2 <input type="text" value="682"/>	Occupants: <input type="text"/>		
	Room is free of pests?			No pests observed at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Environmental parameters were within acceptable range at the time of assessment..	None		
403	Temp	<input type="text" value="68.4"/>	RH% <input type="text" value="63.9"/>	CO2 <input type="text" value="686"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?		The room moderately dusty. Tables and desks ought to be cleaned more often. Everything else is fine.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		The room moderately dusty. Tables and desks ought to be cleaned more often. Everything else is fine.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?		The room moderately dusty. Tables and desks ought to be cleaned more often. Everything else is fine.	No pests observed at the time of assessment.	None		
	LOCKER ROOM						
	Locker room and showers cleaned regularly and properly?			No issues identified at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		The room is usually freezing or extremely hot.	See other recommendation.			
	Room is usually comfortable? (If no, please explain in the notes below.)		The room is usually freezing or extremely hot.	See other recommendation.			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
403	Temp	68.4	RH%	63.9	CO2	686	Occupants:				
	Temperature in my classroom is generally comfortable (72F-76F)?			The room is usually freezing or extremely hot.	Temperature was low and humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations				2
412	Temp	68.6	RH%	58.2	CO2	796	Occupants:				
	THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.)			I am the media specialist and the media center must be cooler to avoid mold, mildew, and damage to the books. We are aware that it is cooler and dress accordingly. Therefore, the media staff considers the room comfortable although others may say it is c	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
412A	Temp	65.2	RH%	64.3	CO2	723	Occupants:				
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None					
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None					
	LOCAL EXHAUST FANS Bathroom exhaust fan is functioning properly?			No exhaust present	No exhaust fans in room. Identified in error.	None					
	Other exhaust fans that may exist in the classroom are functioning properly?			No exhaust present	No exhaust fans in room. Identified in error.	None					
	Walkthrough				Live plants in room.	Facilities serviceperson should remove live plants.	Site Based				1
413	Temp	66.7	RH%	65.3	CO2	837	Occupants:				
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	ANIMALS IN THE CLASSROOM										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
413	Temp	66.7	RH%	65.3	CO2	837	Occupants:				
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	GENERAL CLEANLINESS										
	Room is free of pests?			No pests observed at the time of assessment.	None						
	THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)		The classroom is EXCESSIVELY cold!!!!!!		Temperature was low and humidity slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations				2
	Temperature in my classroom is generally comfortable (72F-76F)?		The classroom is EXCESSIVELY cold!!!!!!		See other recommendation.						
502	Temp	71	RH%	60.1	CO2	1293	Occupants:				
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Some tiles are discolored, however, they have been checked for leaks.		No issues identified at the time of assessment.	None					
	THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)		The air does not circulate properly in this building. If I am cold, everyone else is fine. My room is typically colder than all others.		See other recommendation.						
	Temperature in my classroom is generally comfortable (72F-76F)?		The air does not circulate properly in this building. If I am cold, everyone else is fine. My room is typically colder than all others.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
507	Temp	72.6	RH%	58.2	CO2	1119	Occupants:				
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?		a wall in my room has a tendency to leak		Slight odor in room at the time of the assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations				2
	ANIMALS IN THE CLASSROOM										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
507	Temp	72.6	RH% 58.2	CO2 1119	Occupants:		
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS						
	Indoor surfaces of exterior walls free of continuous condensation?			room is fine	Tackboard by window has moisture of 40%.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
509	Temp	70.5	RH% 60.5	CO2 1129	Occupants:		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			See other recommendation.			
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
510	Temp	72	RH% 62.5	CO2 1303	Occupants:		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			Not Applicable-No Bathroom or Exhaust Fans	No exhaust fans in room. Identified in error.	None	
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			Not Applicable-No Bathroom or Exhaust Fans	No exhaust fans in room. Identified in error.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			Not Applicable-No Bathroom or Exhaust Fans	No exhaust fans in room. Identified in error.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?			Not Applicable-No Bathroom or Exhaust Fans	No exhaust fans in room. Identified in error.	None	
511	Temp	71.2	RH% 56	CO2 1226	Occupants:		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			See other recommendation.			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
511	Temp	71.2	RH% 56	CO2 1226	Occupants: <input type="text"/>		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
512	Temp	72.5	RH% 61.8	CO2 1369	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			I do not have a bathroom with exhaust fans in the classroom	No exhaust fans in room. Identified in error.	None	
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			I do not have a bathroom with exhaust fans in the classroom	No exhaust fans in room. Identified in error.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			I do not have a bathroom with exhaust fans in the classroom	No exhaust fans in room. Identified in error.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?			I do not have a bathroom with exhaust fans in the classroom	No exhaust fans in room. Identified in error.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			It is comfortable during winter and fall time ONLY. It is very warm during summer and spring time.	Environmental parameters were within acceptable range at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			It is comfortable during winter and fall time ONLY. It is very warm during summer and spring time.	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			It is comfortable during winter and fall time ONLY. It is very warm during summer and spring time.	No issues identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)			It is comfortable during winter and fall time ONLY. It is very warm during summer and spring time.	See other recommendation.		
	Temperature in my classroom is generally comfortable (72F-76F)?			It is comfortable during winter and fall time ONLY. It is very warm during summer and spring time.	Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
601	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="59.3"/>	CO2 <input type="text" value="925"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		At times my room is so cold, my nose becomes frostbitten.		Environmental parameters were within acceptable range at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?		At times my room is so cold, my nose becomes frostbitten.		Temperature was acceptable at the time of assessment.	None		
604	Temp	<input type="text" value="73.3"/>	RH% <input type="text" value="60.9"/>	CO2 <input type="text" value="1329"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Indoor surfaces of exterior walls free of continuous condensation?				No issues identified at the time of assessment.	None		
Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None		
610	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No exhaust fans in room. Identified in error.	None		
614	Temp	<input type="text" value="72.4"/>	RH% <input type="text" value="66.7"/>	CO2 <input type="text" value="642"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?		overall is good		Slight dust accumulation was observed on elevated environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Walkthrough				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
616	Temp	73.1	RH% 64.5	CO2 814	Occupants:		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			temperature can be too cold at times.	Environmental parameters were within acceptable range at the time of assessment..	None		
Room is usually comfortable? (If no, please explain in the notes below.)			temperature can be too cold at times.	Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?			temperature can be too cold at times.	Temperature was acceptable at the time of assessment.	None		
618	Temp	72.6	RH% 65.3	CO2 719	Occupants:		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None		
Room is free of pests?				No pests observed at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Environmental parameters were within acceptable range at the time of assessment..	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
620	Temp	73	RH% 66	CO2 680	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
Classroom is free of animals and pets?					No animals identified at the time of assessment.	None	
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	
Classroom is dusted/vacuumed thoroughly and regularly?					General cleanliness of the room at the time of assessment was acceptable.	None	
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?					No issues identified at the time of assessment.	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			The room is usually too cold...not to an extreme, but too cold, usually just under 70 degrees		Environmental parameters were within acceptable range at the time of assessment..	None	
Room is usually comfortable? (If no, please explain in the notes below.)			The room is usually too cold...not to an extreme, but too cold, usually just under 70 degrees		Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
Temperature in my classroom is generally comfortable (72F-76F)?			The room is usually too cold...not to an extreme, but too cold, usually just under 70 degrees		Temperature was acceptable at the time of assessment.	None	

701 Temp 73 RH% 63.9 CO2 810 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
701	Temp	73	RH%	63.9	CO2	810	Occupants:				
	You are informed about the potential allergies of your students?								Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.					None		
	Classroom lavatories/water fountains free of leaks?			No issues identified at the time of assessment.					None		
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.					Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?			Environmental parameters were within acceptable range at the time of assessment..					None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.					None		
702	Temp	70.8	RH%	58.7	CO2	1452	Occupants:				
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.					None		
	THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)		AC is either off or on, not moderated, due to the age of the unit.		Physical Plant Operations was working on the A/C at the time of the assessment.				None		
	Temperature in my classroom is generally comfortable (72F-76F)?		AC is either off or on, not moderated, due to the age of the unit.		Physical Plant Operations was working on the A/C at the time of the assessment.				None		
705	Temp	71.4	RH%	55.4	CO2	1555	Occupants:				
	EXCESS MOISTURE IN CLASSROOMS										
	Classroom lavatories/water fountains free of leaks?			No issues identified at the time of assessment.					None		
	GENERAL CLEANLINESS										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
705	Temp	71.4	RH% 55.4	CO2 1555	Occupants:			
	Classroom is dusted/vacuumed thoroughly and regularly?				Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?				Our airconditioner can either go on or off. There is no in between. I have never felt heat.	Environmental parameters were within acceptable range at the time of assessment..	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Our airconditioner can either go on or off. There is no in between. I have never felt heat.	No issues identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)				Our airconditioner can either go on or off. There is no in between. I have never felt heat.	Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Our airconditioner can either go on or off. There is no in between. I have never felt heat.	Temperature was acceptable at the time of assessment.	None	
851	Temp	73.5	RH% 61.3	CO2 1292	Occupants:			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
852	Temp	72.8	RH% 59.8	CO2 1256	Occupants:			
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
852	Temp	<input type="text" value="72.8"/>	RH% <input type="text" value="59.8"/>	CO2 <input type="text" value="1256"/>	Occupants: <input type="text"/>		
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
860	Temp	<input type="text" value="73.4"/>	RH% <input type="text" value="60.2"/>	CO2 <input type="text" value="1198"/>	Occupants: <input type="text"/>		
	DRAIN TRAPS IN THE CLASSROOM						
	If not regularly used, toilets flushed once each week.			It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
861	Temp	<input type="text" value="73.5"/>	RH% <input type="text" value="60.8"/>	CO2 <input type="text" value="1283"/>	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?			The floor is dry dusted each day but mopped only twice a year. It gets rather dirty.	Floor was clean at the time of assessment.		
862	Temp	<input type="text" value="72.8"/>	RH% <input type="text" value="61.2"/>	CO2 <input type="text" value="1274"/>	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
864	Temp	<input type="text" value="73.4"/>	RH% <input type="text" value="61"/>	CO2 <input type="text" value="1290"/>	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
864	Temp	73.4	RH% 61	CO2 1290	Occupants:		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	My room does not have exhaust fans		No exhaust fans in room. Identified in error.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	My room does not have exhaust fans		No exhaust fans in room. Identified in error.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	My room does not have exhaust fans		No exhaust fans in room. Identified in error.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	My room does not have exhaust fans		No exhaust fans in room. Identified in error.	None		
865	Temp	73.4	RH% 61.2	CO2 1280	Occupants:		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
870	Temp	76.8	RH% 60.3	CO2 922	Occupants:		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Walkthrough			Water damaged wallboard from apparent window leak.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
872	Temp	73.5	RH% 54.8	CO2 1033	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?	Answers based on portable classroom.		No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
874	Temp	<input type="text" value="73.5"/>	RH% <input type="text" value="58"/>	CO2 <input type="text" value="1053"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Windows, windowsills and window frames free of continuous condensation?			No condensation observed at the time of assessment.		None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Floors need to be waxed on a more timely manner.		None		
Classroom is dusted/vacuumed thoroughly and regularly?			Floors need to be waxed on a more timely manner.		None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?			No exhaust fans exist in classroom		None		
Other exhaust fans that may exist in the classroom are functioning properly?			No exhaust fans exist in classroom		None		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			Continuous problems with a new AC unit.		None		
Temperature in my classroom is generally comfortable (72F-76F)?			Continuous problems with a new AC unit.		None		
875	Temp	<input type="text" value="72.5"/>	RH% <input type="text" value="51.5"/>	CO2 <input type="text" value="935"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.		Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
901	Temp	<input type="text" value="71.7"/>	RH% <input type="text" value="60.4"/>	CO2 <input type="text" value="610"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.		None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
902	Temp	<input type="text" value="72.3"/>	RH% <input type="text" value="62"/>	CO2 <input type="text" value="843"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
903	Temp	<input type="text" value="73.3"/>	RH% <input type="text" value="59"/>	CO2 <input type="text" value="742"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	
Classroom is dusted/vacuumed thoroughly and regularly?					General cleanliness of the room at the time of assessment was acceptable.	None	
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			usually too cold	Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?			usually too cold	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

912

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

None

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Very cold!!

Environmental parameters were within acceptable range at the time of assessment..

None

Room is usually comfortable? (If no, please explain in the notes below.)

Very cold!!

Environmental parameters were within acceptable range at the time of assessment..

None

Temperature in my classroom is generally comfortable (72F-76F)?

Very cold!!

Temperature was acceptable at the time of assessment.

None

913

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

THERMAL COMFORT

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
913	Temp	73.5	RH% 60.5	CO2 1021	Occupants:		
Classroom is free of significant temperature shifts?			room is generally hot. there is a window facing the east that warms up the room.. in summer room is unbearable at that time of the year	Environmental parameters were within acceptable range at the time of assessment..	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			room is generally hot. there is a window facing the east that warms up the room.. in summer room is unbearable at that time of the year	Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			room is generally hot. there is a window facing the east that warms up the room.. in summer room is unbearable at that time of the year	Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?			room is generally hot. there is a window facing the east that warms up the room.. in summer room is unbearable at that time of the year	Temperature was acceptable at the time of assessment.	None		
914	Temp	71.4	RH% 59.8	CO2 610	Occupants:		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
917	Temp	72	RH% 58.4	CO2 818	Occupants:		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

921C

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks or signs of water intrusion identified.

None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

General cleanliness of the room at the time of assessment was acceptable.

None

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

Room is free of pests?

No pests observed at the time of assessment.

None

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No issues identified at the time of assessment.

Other exhaust fans that may exist in the classroom are functioning properly?

No issues identified at the time of assessment.

None

Walkthrough

A/C units were not on during the time of the assessment.

None

927

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
927	Temp	<input type="text" value="71.5"/>	RH% <input type="text" value="62.8"/>	CO2 <input type="text" value="840"/>	Occupants: <input type="text"/>		
	EXCESS MOISTURE IN CLASSROOMS						
	Windows, windowsills and window frames free of continuous condensation?			No condensation observed at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
928	Temp	<input type="text" value="70.5"/>	RH% <input type="text" value="63.7"/>	CO2 <input type="text" value="708"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Windows/doors are operable and are kept closed?			No issues identified at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			I float from room to room. There are some rooms that I go to that are cleaner than others. For instance, in room 871 the floor is usually dirty.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?			I float from room to room. There are some rooms that I go to that are cleaner than others. For instance, in room 871 the floor is usually dirty.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Walkthrough						
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

955

Temp

71.7

RH%

79.8

CO2

458

Occupants:

DRAIN TRAPS IN THE CLASSROOM

Water poured down floor drains once per week (approx. 1 quart of water).

It appears as though water is poured down the floor drain at least once a week.

None

EXCESS MOISTURE IN CLASSROOMS

Classroom lavatories/water fountains free of leaks?

No leaks or signs of water intrusion identified.

None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

None

Classroom is dusted/vacuumed thoroughly and regularly?

General cleanliness of the locker room and showers was acceptable at the time of assessment.

None

Classrooms general appearance is clean and acceptable?

General cleanliness of the locker room and showers was acceptable at the time of assessment.

None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

Room is free of the use of scented cleaners and air fresheners?

No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.

None

LOCKER ROOM

Locker room and showers cleaned regularly and properly?

General cleanliness of the locker room and showers was acceptable at the time of assessment.

None