

Jeffrey S. Moquin, Director
Risk Management Department

Telephone: 754-321-3200
Facsimile: 754-321-3290

September 21, 2005

Signature on File

TO: Mr. James McDermott, Principal
Forest Glen Middle School

FROM: Aston A. Henry, Jr., Supervisor
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 803

On August 15, 2005 the IAQ Assessment Team conducted an assessment of FISH 803 at **Forest Glen Middle School**. The evaluation consisted of a walkthrough of the identified areas to assess the current condition of the location with regard to indoor air quality. This assessment included observations of the carpet, floor tile, ceiling tile, interior walls, false ceiling plenum, and accessible ventilation equipment.

Attached are the findings of this assessment along with recommendations for further assessment, remediation, or corrective actions, if needed.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Joanne Harrison, Area Superintendent
Jackie Haywood, Area Director
Jeffrey S. Moquin, Director, Risk Management
Raul Ascarrunz, Project Manager II, Facilities and Construction Management
Ruby Fitzgerald, Broward Teachers Union
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

AAH/tc
Enc.

IAQ Assessment

Forest Glen Middle School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="803"/>	<input type="text" value="69.9"/>	<input type="text" value="72 - 78"/>	<input type="text" value="70.8"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="1204"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="12"/>
Noticeable Odor	<input type="text" value="Yes"/>		Visible water damage / staining?		Visible microbial growth?		Amount of material affected
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- Noticeable odor emanating from old desk drawers. Microbial growth was identified in and on the old desk which was thrown out by the custodial staff.
- General cleanliness of the room at the time of the assessment was acceptable
- Temperature was low
- Humidity level was elevated

Recommendations:

Site Based Maintenance:

- Discard old desk drawers
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations Division:

- Evaluate and repair HVAC system to increase temperature and lower humidity level