

Tools for Schools Phase II - Indoor Air Quality

Follow-up Action Plan for Physical Plant Operations



Lauderhill Middle

1391

81.4 65.3 556

Principal: Mr. Phillip Patton

Walkthrough Date: 5/24/2005

Temp RH Co2
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
103	2	Physical Plant Operations	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
108	3	Physical Plant Operations	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
109	2	Physical Plant Operations	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
116	2	Physical Plant Operations	Signs of water intrusion.	Physical Plant Operations to evaluate for leaks and repair as appropriate.
116	3	Physical Plant Operations	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
122	1	Physical Plant Operations	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.
133A	2	Physical Plant Operations	Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.
168	1	Physical Plant Operations	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.
187	2	Physical Plant Operations	General cleanliness of the room at the time of assessment was not acceptable. Room is cluttered.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.