

Lauderhill Middle

IAQ Walkthrough 5/24/2005

1391

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
103	Temp <input type="text" value="71.7"/> RH% <input type="text" value="55.7"/> CO2 <input type="text" value="558"/>	Occupants: <input type="text"/>			
	ANIMALS IN THE CLASSROOM				
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS				
	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Physical Plant Operations	2
	LOCAL EXHAUST FANS				
	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.	None		
103E	Temp <input type="text" value="71.8"/> RH% <input type="text" value="54.5"/> CO2 <input type="text" value="547"/>	Occupants: <input type="text"/>			
	GENERAL CLEANLINESS				
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment. Room very cluttered.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
107	Temp <input type="text" value="72.1"/> RH% <input type="text" value="58.9"/> CO2 <input type="text" value="567"/>	Occupants: <input type="text"/>			
	ANIMALS IN THE CLASSROOM				
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
107	Temp	72.1	RH% 58.9	CO2 567	Occupants: <input type="text"/>		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?		b) The floor is swept and vacuumed regularly, but the shelves could be dusted a little more often. The custodians do a great job.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		It is freezing in here.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		It is freezing in here.	Temperature was acceptable at the time of assessment.	None		
108	Temp	73.7	RH% 62.5	CO2 772	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?		I have not witnessed the air supply/return registers cleaned, nor can I confirm whether they have been cleaned this year.	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
108A	Temp	76.7	RH% 56.8	CO2 805	Occupants: <input type="text"/>		
	THERMAL COMFORT						
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The room is generally cold. It is adjusted when request is made to administration.	Humidity was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
108A	Temp	<input type="text" value="76.7"/>	RH%	<input type="text" value="56.8"/>	CO2	<input type="text" value="805"/>	Occupants:	<input type="text"/>
Room is usually comfortable? (If no, please explain in the notes below.)	The room is generally cold. It is adjusted when request is made to administration.			Temperature was acceptable at the time of assessment.	None			
Temperature in my classroom is generally comfortable (72F-76F)?	The room is generally cold. It is adjusted when request is made to administration.			Temperature was acceptable at the time of assessment.	None			
109	Temp	<input type="text" value="73.2"/>	RH%	<input type="text" value="59.2"/>	CO2	<input type="text" value="826"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None			
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None			
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None			
Room is free of smell of vehicle exhaust?				No odor detected at the time of assessment.	None			
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	The floor is deplorable. Black stains are everywhere. The community school uses the room for child care daily.			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Physical Plant Operations		2
Classroom is dusted/vacuumed thoroughly and regularly?	The floor is deplorable. Black stains are everywhere. The community school uses the room for child care daily.			There does not appear to be a dusting issue within this room.	None			
Classrooms general appearance is clean and acceptable?	The floor is deplorable. Black stains are everywhere. The community school uses the room for child care daily.			General cleanliness of the room at the time of assessment was acceptable.	None			
Floor is cleaned on a regular basis?	The floor is deplorable. Black stains are everywhere. The community school uses the room for child care daily.			Floor gasket for toilet appears to be worn.	None			
Food, if any, is stored in tightly sealed containers?	The floor is deplorable. Black stains are everywhere. The community school uses the room for child care daily.			No unsealed food items were observed at the time of assessment.	None			
Room is free of pests?	The floor is deplorable. Black stains are everywhere. The community school uses the room for child care daily.			No pests observed at the time of assessment.	None			
LOCAL EXHAUST FANS								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority		
109	Temp	73.2	RH%	59.2	CO2	826	Occupants:		
	Bathroom exhaust fan is functioning properly?						No bathroom. Identified in error.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?						Exhaust fan is functioning properly.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?						It appears that the ventilation system is adequate based on room activities.	None	
	THERMAL COMFORT								
	Classroom is free of significant temperature shifts?						Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)						General cleanliness of the room at the time of assessment was not acceptable.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)						Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)						Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?						Temperature was acceptable at the time of assessment.	None	
111	Temp	73.7	RH%	59.4	CO2	1050	Occupants:		
	GENERAL CLEANLINESS								
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?						It appears that if an accident happens on one shift, the shift on duty waits until the next shift comes on to take care of the matter. A can soda exploded in my room and it took the next shift to clean and mop the mess from the floor.	No issues identified relating to spill clean up practices at the time of assessment..	None
	LOCAL EXHAUST FANS								
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)						It appears that the ventilation system is adequate based on room activities.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?						It appears that the ventilation system is adequate based on room activities.	None	
	THERMAL COMFORT								
	Classroom is free of significant temperature shifts?						My room is at a steady temperature of 60 degrees during the winter, spring and summer. The temperature is not regulated in my room; it is freezing to the point that I have a small heater to offset the cold temperatures within the classroom..	Temperature was acceptable at the time of assessment.	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
111	Temp	<input type="text" value="73.7"/>	RH%	<input type="text" value="59.4"/>	CO2	<input type="text" value="1050"/>	Occupants:	<input type="text"/>
Room is usually comfortable? (If no, please explain in the notes below.)	My room is at a steady temperature of 60 degrees during the winter, spring and summer. The temperature is not regulated in my room; it is freezing to the point that I have a small heater to offset the cold temperatures within the classroom..			Temperature was acceptable at the time of assessment.	None			
Temperature in my classroom is generally comfortable (72F-76F)?	My room is at a steady temperature of 60 degrees during the winter, spring and summer. The temperature is not regulated in my room; it is freezing to the point that I have a small heater to offset the cold temperatures within the classroom..			Temperature was acceptable at the time of assessment.	None			
115	Temp	<input type="text" value="72.6"/>	RH%	<input type="text" value="62.5"/>	CO2	<input type="text" value="1032"/>	Occupants:	<input type="text"/>
DRAIN TRAPS IN THE CLASSROOM								
Water poured down floor drains once per week (approx. 1 quart of water).				Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of drains with facility serviceperson staff.	Site Based		2
Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based		2
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?	Most of the students feel that the room is too cold!!!!			Temperature was acceptable at the time of assessment.	None			
Room is usually comfortable? (If no, please explain in the notes below.)	Most of the students feel that the room is too cold!!!!			Temperature was acceptable at the time of assessment.	None			
Temperature in my classroom is generally comfortable (72F-76F)?	Most of the students feel that the room is too cold!!!!			Temperature was acceptable at the time of assessment.	None			
116	Temp	<input type="text" value="74.9"/>	RH%	<input type="text" value="60.7"/>	CO2	<input type="text" value="1077"/>	Occupants:	<input type="text"/>
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
116	Temp	74.9	RH% 60.7	CO2 1077	Occupants:		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			Science lab with about 7 sinks. Sometimes the students use the sinks for lab experiments or to wash their hands. That is the only time that water is poured down the drains.	Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of drains with facility serviceperson staff.	2
	Water run in sinks at least once per week (about 2 cups of water).			Science lab with about 7 sinks. Sometimes the students use the sinks for lab experiments or to wash their hands. That is the only time that water is poured down the drains.	It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	2
EXCESS MOISTURE IN CLASSROOMS							
	Classroom lavatories/water fountains free of leaks?			pertaining to e). one sink in the room leaks when the faucet is turned on.	Signs of water intrusion.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	2
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			The floor is swept on a regular basis, but there are dirt stains that remain on the floor.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	2
	Room is free of pests?			The floor is swept on a regular basis, but there are dirt stains that remain on the floor.	No pests observed at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			The floor is swept on a regular basis, but there are dirt stains that remain on the floor.	There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	2
LOCAL EXHAUST FANS							
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			Science labs have ventilation fans for lab activities, but my ventilation fan is broken.	It appears that classroom/functions are not consistent with educational specifications for room use.	Site based administration to discuss with facility Project Manager.	1
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			Science labs have ventilation fans for lab activities, but my ventilation fan is broken.	It appears that classroom/functions are not consistent with educational specifications for room use.	Site based administration to discuss with facility Project Manager.	1
	Other exhaust fans that may exist in the classroom are functioning properly?			Science labs have ventilation fans for lab activities, but my ventilation fan is broken.	It appears that classroom/functions are not consistent with educational specifications for room use.	Site based administration to discuss with facility Project Manager.	1
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Even though the room is cold, when it is addressed the air is turned down for the day.	Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
116	Temp	<input type="text" value="74.9"/>	RH%	<input type="text" value="60.7"/>	CO2	<input type="text" value="1077"/>	Occupants:	<input type="text"/>
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			Even though the room is cold, when it is addressed the air is turned down for the day.	No gaps in windows or doors identified at the time of assessment.	None			
Room is usually comfortable? (If no, please explain in the notes below.)			Even though the room is cold, when it is addressed the air is turned down for the day.	Temperature was acceptable at the time of assessment.	None			
Temperature in my classroom is generally comfortable (72F-76F)?			Even though the room is cold, when it is addressed the air is turned down for the day.	Temperature was acceptable at the time of assessment.	None			
116A	Temp	<input type="text" value="72.7"/>	RH%	<input type="text" value="63.7"/>	CO2	<input type="text" value="937"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Room is free of smell of mold or mildew?			Room is too cold and students complain frequently.	No odor detected at the time of assessment.	None			
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None			
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
ART SUPPLIES								
Art supplies okay?				No art supplies in room. Room not being used as an art room.	None			
Industrial supplies okay?				No industrial supplies in room. Room not being used as an industrial room.	None			
Science supplies okay?				No science supplies in room. Room not being used as a science room.	None			
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None			
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
116A	Temp	<input type="text" value="72.7"/>	RH%	<input type="text" value="63.7"/>	CO2	<input type="text" value="937"/>	Occupants:	<input type="text"/>
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.		None	
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.		None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.		None	
	Food, if any, is stored in tightly sealed containers?				No unsealed food items were observed at the time of assessment.		None	
	Room is free of pests?				No pests observed at the time of assessment.		None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..		None	
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.		None	
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.		None	
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.		None	
LOCKER ROOM								
	Locker room and showers cleaned regularly and properly?				Issues not applicable. Room is not a locker room.		None	
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?				ROOM IS TOO COLD AT ALL TIMES., Room is too cold and the students complain frequently.		Temperature was acceptable at the time of assessment.	None
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				ROOM IS TOO COLD AT ALL TIMES., Room is too cold and the students complain frequently.		Humidity was acceptable at the time of assessment.	None
	Room is usually comfortable? (If no, please explain in the notes below.)				ROOM IS TOO COLD AT ALL TIMES., Room is too cold and the students complain frequently.		Temperature was acceptable at the time of assessment.	None
	Temperature in my classroom is generally comfortable (72F-76F)?				ROOM IS TOO COLD AT ALL TIMES., Room is too cold and the students complain frequently.		Temperature was acceptable at the time of assessment.	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

122

Temp RH% CO2

Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

There are ants in the room and that was brought to the attention of the custodians.

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

Classroom is free of animals and pets?

There are ants in the room and that was brought to the attention of the custodians.

No animals identified at the time of assessment.

None

You are informed about the potential allergies of your students?

There are ants in the room and that was brought to the attention of the custodians.

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

A tiny section of the ceiling has a leak and custodians told me the problem has been there for years and they have tried to solve it to no avail.

Signs of water intrusion. Stained ceiling tiles.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Physical Plant Operations

1

GENERAL CLEANLINESS

Room is free of pests?

No pests observed at the time of assessment.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Some days the room is too hot; other times it is too cold.

Temperature was acceptable at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

Some days the room is too hot; other times it is too cold.

Temperature was acceptable at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

Some days the room is too hot; other times it is too cold.

Temperature was acceptable at the time of assessment.

None

124

Temp RH% CO2

Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
124	Temp	76.1	RH% 52.8	CO2 975	Occupants: <input type="text"/>		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	DRAIN TRAPS IN THE CLASSROOM						
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based	2
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		
129	Temp	74.0	RH% 64.8	CO2 1106	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None		
	ART SUPPLIES						
	Industrial supplies okay?			No industrial supplies in room. Room not being used as an industrial room.	None		
	Science supplies okay?			No science supplies in room. Room not being used as a science room.	None		
	DRAIN TRAPS IN THE CLASSROOM						
	If not regularly used, toilets flushed once each week.			No issues identified at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
129	Temp	74.0	RH% 64.8	CO2 1106	Occupants:		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		
129A	Temp	74.4	RH% 60.4	CO2 998	Occupants:		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Floor is cleaned on a regular basis?		Floors are swept, but, not mopped regularly.	Floor was clean at the time of assessment.	None		
	Room is free of pests?		Floors are swept, but, not mopped regularly.	No pests observed at the time of assessment.	None		
133A	Temp	76.0	RH% 59.9	CO2 1002	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Physical Plant Operations	2
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
ART SUPPLIES							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
133A	Temp	76.0	RH% 59.9	CO2 1002	Occupants: <input type="text"/>		
	Industrial supplies okay?			No industrial supplies in room. Room not being used as an industrial room.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor. Floor needs wax.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Trash is removed daily and trash bags are changed as appropriate?			There appears to be an issue regarding daily trash removal practices.	None		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		
135	Temp	74.0	RH% 61.8	CO2 1002	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
140	Temp	73.6	RH% 63.1	CO2 1023	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
140	Temp	73.6	RH% 63.1	CO2 1023	Occupants:		
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of drains with facility serviceperson staff.	Site Based	2
Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based	2
GENERAL CLEANLINESS							
Room is free of pests?				No pests observed at the time of assessment.	None		
141	Temp	73.1	RH% 64.5	CO2 1019	Occupants:		
AIR CONDITIONING							
Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None		
Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None		
Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None		
Indoor surfaces of exterior walls free of continuous condensation?				No condensation at the time of assessment.	None		
Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None		
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
141	Temp	73.1	RH% 64.5	CO2 1019	Occupants: <input type="text"/>		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	Food, if any, is stored in tightly sealed containers?				No unsealed food items were observed at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	
142	Temp	73.5	RH% 62.6	CO2 986	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	3
	EXCESS MOISTURE IN CLASSROOMS						
	Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None	
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
142	Temp	<input type="text" value="73.5"/>	RH% <input type="text" value="62.6"/>	CO2 <input type="text" value="986"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
143	Temp	<input type="text" value="72.1"/>	RH% <input type="text" value="65.4"/>	CO2 <input type="text" value="909"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
LOCAL EXHAUST FANS							
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	1
144	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="63.5"/>	CO2 <input type="text" value="929"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None		
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
144	Temp	73.2	RH% 63.5	CO2 929	Occupants:		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Food, if any, is stored in tightly sealed containers?			No unsealed food items were observed at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		
	THERMAL COMFORT						
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Too cold ...	Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Too cold ...	Supply vents closed at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Too cold ...	Temperature was acceptable at the time of assessment.	None		
147	Temp	73.5	RH% 60.1	CO2 1174	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of chemicals?			No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	ART SUPPLIES						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
147	Temp	73.5	RH% 60.1	CO2 1174	Occupants:		
	Art supplies okay?				No art supplies in room. Room not being used as an art room.	None	
	Industrial supplies okay?				No industrial supplies in room. Room not being used as an industrial room.	None	
	Science supplies okay?				No science supplies in room. Room not being used as a science room.	None	
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).				Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of drains with facility serviceperson staff.	Site Based 2
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based 2
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?		Faculty restroom next to my classroom accumulates gaseous /chemical odors.		Bathroom exhaust fan is functioning properly.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		Temperature variances -- sometimes much too cold.		Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Temperature variances -- sometimes much too cold.		Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Temperature variances -- sometimes much too cold.		Temperature was acceptable at the time of assessment.	None	
157	Temp	74.2	RH% 65.9	CO2 670	Occupants:		
ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
157	Temp	74.2	RH% 65.9	CO2 670	Occupants:		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Food, if any, is stored in tightly sealed containers?			No unsealed food items were observed at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		
162	Temp	72.1	RH% 67.1	CO2 719	Occupants:		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		
	Wlakthrough						
				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
164	Temp		RH%	CO2	Occupants:		
	THERMAL COMFORT						
	Temperature in my classroom is generally comfortable (72F-76F)?			Supply vents closed at the time of assessment.	None		
165	Temp	71.5	RH% 59.4	CO2 1050	Occupants:		
	DRAIN TRAPS IN THE CLASSROOM						
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None		
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
168	Temp	71.7	RH% 65.3	CO2 667	Occupants:		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None		
THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
171	Temp	72.7	RH% 68.2	CO2 819	Occupants:		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
ART SUPPLIES							
	Art supplies okay?			No art supplies in room. Room not being used as an art room.	None		
	Exposure minimized for art supplies?			No art supplies in room. Room not being used as an art room.	None		
	Following good handling and storage practices for art supplies?			No art supplies in room. Room not being used as an art room.	None		
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
171	Temp	<input type="text" value="72.7"/>	RH%	<input type="text" value="68.2"/>	CO2	<input type="text" value="819"/>	Occupants:	<input type="text"/>			
	Classroom is dusted/vacuumed thoroughly and regularly?						Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?						Dust and dirt accumulation on floor.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Food, if any, is stored in tightly sealed containers?						No unsealed food items were observed at the time of assessment.		None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?						No issues identified relating to spill clean up practices at the time of assessment..		None		
	Trash is removed daily and trash bags are changed as appropriate?						No issues identified regarding trash removal practices.		None		
182	Temp	<input type="text" value="77.3"/>	RH%	<input type="text" value="54.3"/>	CO2	<input type="text" value="956"/>	Occupants:	<input type="text"/>			
	AIR CONDITIONING										
	Room is free of smell of kitchen/food?						No odor detected at the time of assessment.		None		
	ANIMALS IN THE CLASSROOM										
	You are informed about the potential allergies of your students?						This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						Dust observed on supply/return registers at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?						Temperature was elevated at the time of assessment.		Facilities serviceperson should monitor this room.	Site Based	2
	Walkthrough										
							Stained ceiling tiles.		Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
183	Temp	72.2	RH% 60.7	CO2 829	Occupants:		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor. Floor needs wax.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments				Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	--	----------	----------------	-------------	----------

187

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was not acceptable. Room is cluttered.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Physical Plant Operations

2

Floor is cleaned on a regular basis?

Dust and dirt accumulation on floor.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Spills and other such issues requiring custodial assistance are addressed in a timely manner?

No issues identified relating to spill clean up practices at the time of assessment..

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

TOO HOT FOR THE COMPUTERS (33)

Temperature was acceptable at the time of assessment.

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

TOO HOT FOR THE COMPUTERS (33)

Humidity was acceptable at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

TOO HOT FOR THE COMPUTERS (33)

Temperature was acceptable at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

TOO HOT FOR THE COMPUTERS (33)

Temperature was acceptable at the time of assessment.

None

213

Temp RH% CO2 Occupants:

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No exhaust fans in room. Identified in error.

None

Other exhaust fans that may exist in the classroom are functioning properly?

No exhaust fans in room. Identified in error.

None