

MARGATE MIDDLE

Walkthrough Date: 05/18/2006 Temp RH CO2
 Outdoor Parameters: 73.1 83.7 374

Room	Section	Question	Answer	Recommendation	Responsible
101	Inside Parameters:	Temp	RH	CO2	
		72.0	56.4	676	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
101B	Inside Parameters:	Temp	RH	CO2	
		68.2	59.7	675	
	AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error. Office is very cold.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site

Room	Section	Question	Answer	Recommendation	Responsible
102A	Inside Parameters:	Temp	RH	CO2	
		70.8	59.4	658	
	GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceworker staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
102E	Inside Parameters:	Temp	RH	CO2	
		72.2	58.3	771	

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceworker to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.		

AIR
CONDITIONING

Air is flowing without obstruction?

Air flowing without obstruction at the time of assessments.

AIR
CONDITIONING

Room is free of smell of mold or mildew?

No microbial growth identified. No odor identified at the time of assessment.

LOCAL EXHAUST
FANS

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

No exhaust system/ventilation in room. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
105	Inside Parameters:	Temp 69.5	RH 63.2	CO2 650	

GENERAL
CLEANLINESS

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

GENERAL
CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

GENERAL
CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

GENERAL
CLEANLINESS

Room is free of pests?

No pests observed at the time of assessment. Media Center was very cold at the time of the assessment.

GENERAL
CLEANLINESS

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
107	Inside Parameters:	Temp 72.0	RH 58.5	CO2 735	

EXCESS
MOISTURE IN
CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks or signs of water intrusion identified.

THERMAL
COMFORT

Temperature in my classroom is generally comfortable (72F-78F)?

Temperature was acceptable at the time of assessment.

THERMAL
COMFORT

Classroom is free of significant temperature shifts?

Temperature was acceptable at the time of assessment.

THERMAL
COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
112	Inside Parameters:	Temp 72.2	RH 58.5	CO2 717	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water). It appears as though water is poured down the floor drain at least once a week.

DRAIN TRAPS IN THE CLASSROOM Water run in sinks at least once per week (about 2 cups of water). It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.

EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? Signs of water intrusion. Stained ceiling tiles. Physical Plant Operations to evaluate for leaks and repair PPO as appropriate and replace ceiling tiles as appropriate.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

AIR CONDITIONING Air flowing from air supply? Air supply/return ventilation is functioning.

AIR CONDITIONING Air is flowing without obstruction? Air flowing without obstruction at the time of assessments.

Room	Section	Question	Answer	Recommendation	Responsible
113	Inside Parameters:	Temp	RH	CO2	
		71.9	56.8	816	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water). It appears as though water is poured down the floor drain at least once a week.

DRAIN TRAPS IN Water run in sinks at least once per week It appears as though sink is utilized regularly. No sewer

THE CLASSROOM (about 2 cups of water). gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.

EXCESS MOISTURE IN CLASSROOMS Area around and under classroom sinks free of leaks? No leaks or signs of water intrusion identified.

EXCESS MOISTURE IN CLASSROOMS Classroom lavatories/water fountains free of leaks? No lavatories/water fountains in room.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

AIR CONDITIONING Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
115	Inside Parameters:	Temp 69.9	RH 63.0	CO2 629	

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water). It appears as though water is poured down the floor drain at least once a week.

DRAIN TRAPS IN THE CLASSROOM Water run in sinks at least once per week (about 2 cups of water). It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.

THERMAL COMFORT Room is free of the introduction of outdoor air? (Gaps in window/door frames.) Room is self contained with no access to outdoor untreated air.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Temperature was low at the time of the assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site

Room	Section	Question	Answer	Recommendation	Responsible
117	Inside Parameters:	Temp 71.3	RH 58.2	CO2 831	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

GENERAL Room is free of pests? No pests observed at the time of assessment.

CLEANLINESS

GENERAL CLEANLINESS

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

EXCESS MOISTURE IN CLASSROOMS

Windows, windowsills and window frames free of continuous condensation?

No windows in room.

EXCESS MOISTURE IN CLASSROOMS

Cold water pipes free of continuous condensation?

No pipes in room.

EXCESS MOISTURE IN CLASSROOMS

Indoor surfaces of exterior walls free of continuous condensation?

No visible condensation or signs of water intrusion identified at the time of assessment.

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks or signs of water intrusion identified.

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-78F)?

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Temperature was acceptable at the time of assessment.

THERMAL COMFORT

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Humidity was acceptable at the time of assessment.

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Environmental parameters were within acceptable range at the time of assessment..

AIR CONDITIONING

Air flowing from air supply?

Air supply/return ventilation is functioning.

AIR CONDITIONING

Air is flowing without obstruction?

Air flowing without obstruction at the time of assessments.

AIR CONDITIONING

Room is free of smell of mold or mildew?

No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
------	---------	----------	--------	----------------	-------------

119	Inside Parameters:	Temp	RH	CO2	
		70.1	58.7	855	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.			
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.			
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.			
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Classroom is free of animals and pets?	No animals identified at the time of assessment.			
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.			
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.			
AIR CONDITIONING	Air is flowing without obstruction?	Air flowing without obstruction at the time of assessments.			
AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.			
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.			
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust system/ventilation in room. Identified in error.			
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	No exhaust system/ventilation in room. Identified in error.			
LOCAL EXHAUST	Other exhaust fans that may exist in the	No exhaust fans in room. Identified in error.			

FANS classroom are functioning properly?

Room	Section	Question	Answer	Recommendation	Responsible
120A	Inside Parameters:	Temp 68.7	RH 60.8	CO2 726	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment. Humidity slightly exceeded target range however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system is dehumidifying fresh air.	Site based facilities serviceperson should monitor this room.	Site
	LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		
	ART SUPPLIES	Following good handling and storage practices for industrial supplies?	No industrial supplies in room. Room not being used as an industrial room.		
	LOCKER ROOM	Locker room and showers cleaned regularly and properly?	Issues not applicable. Room is not a locker room.		
Room	Section	Question	Answer	Recommendation	Responsible
120D	Inside Parameters:	Temp	RH	CO2	

	69.4	591	804	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair PPO as appropriate and replace ceiling tiles as appropriate.	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
120E	Inside Parameters:	Temp 69.8	RH 59.2	CO2 768	

GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if	Humidity was acceptable at the time of assessment.		

lower than 30% RH.)

AIR
CONDITIONING

Room is free of smell of mold or mildew?

No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
123	Inside Parameters:	Temp 68.5	RH 52.6	CO2 889	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	No floor drain in room.		
	EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
125	Inside Parameters:	Temp	RH	CO2	
		70.7	62.0	925	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Food, if any, is stored in tightly sealed containers? No unsealed food items were observed at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
126	Inside Parameters:	Temp	RH	CO2	
		69.9	61.4	957	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

AIR CONDITIONING Air is flowing without obstruction? Air flowing without obstruction at the time of assessments.

Room	Section	Question	Answer	Recommendation	Responsible
133	Inside Parameters:	Temp	RH	CO2	
		71.8	61.6	686	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
136	Inside Parameters:	Temp	RH	CO2	
		69.1	62.4	845	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel Site

THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	in order to modify classroom activities/conditions when necessary. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.		
LOCKER ROOM	Soiled clothes and towels are removed regularly?	Issues not applicable. Room is not a locker room.		

Room	Section	Question	Answer	Recommendation	Responsible
143	Inside Parameters:	Temp 72.0	RH 59.8	CO2 1043	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No windows in room.		

Room	Section	Question	Answer	Recommendation	Responsible
150	Inside Parameters:	Temp 67.3	RH 54.8	CO2 1071	

THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
-----------------	--	--	--	------

Room	Section	Question	Answer	Recommendation	Responsible
151	Inside Parameters:	Temp	RH	CO2	

		72.3	57.0	1065	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.			
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.			
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..			

Room	Section	Question	Answer	Recommendation	Responsible
155	Inside Parameters:	Temp	RH	CO2	

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.			
---------------------	---	--	--	--	--