

McNicol Middle

IAQ Walkthrough 5/4/2005

0481

Outside Temp RH% CO2

| FISH/Room | Participant Comments | Response | Recommendation | Responsible | Priority |
|-------------|---|--|--|-------------|----------|
| <i>101J</i> | Temp <input type="text" value="71.4"/> RH% <input type="text" value="51.7"/> CO2 <input type="text" value="661"/> | Occupants: <input type="text"/> | | | |
| | AIR CONDITIONING | | | | |
| | Room is free of smell of mold or mildew? | No odor detected at the time of assessment. | None | | |
| | DRAIN TRAPS IN THE CLASSROOM | | | | |
| | If not regularly used, toilets flushed once each week. | No issues identified at the time of assessment. | None | | |
| | EXCESS MOISTURE IN CLASSROOMS | | | | |
| | Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? | No leaks or signs of water intrusion identified. | None | | |
| | GENERAL CLEANLINESS | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Classrooms general appearance is clean and acceptable? | General cleanliness of the room at the time of assessment was not acceptable. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Floor is cleaned on a regular basis? | Minor stains on carpet. | Facilities serviceperson to thoroughly clean and sanitize carpet. | Site Based | 2 |
| | Room is free of pests? | No pests observed at the time of assessment. | None | | |
| | LOCKER ROOM | | | | |
| | Locker room and showers cleaned regularly and properly? | Issues not applicable. Room is not a locker room. | None | | |
| | THERMAL COMFORT | | | | |
| | Classroom is free of significant temperature shifts? | Temperature was acceptable at the time of assessment. | None | | |
| | Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) | Humidity was acceptable at the time of assessment. | None | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | Temperature was acceptable at the time of assessment. | None | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | |
|-----------|---|------|----------|--|---|--|------------|---|
| 101J | Temp | 71.4 | RH% 51.7 | CO2 661 | Occupants: _____ | | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | Temperature was acceptable at the time of assessment. | None | | | |
| 102 | Temp | 70.8 | RH% 49.5 | CO2 589 | Occupants: _____ | | | |
| | DRAIN TRAPS IN THE CLASSROOM | | | | | | | |
| | Water poured down floor drains once per week (approx. 1 quart of water). | | | No floor drain in room. | None | | | |
| | EXCESS MOISTURE IN CLASSROOMS | | | | | | | |
| | Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? | | | Signs of water intrusion. Stained ceiling tiles. | Physical Plant Operations to evaluate for leaks and repair as appropriate. | Physical Plant Operations | 1 | |
| | Indoor surfaces of exterior walls free of continuous condensation? | | | No visible condensation at the time of assessment. | None | | | |
| | Windows, windowsills and window frames free of continuous condensation? | | | No visible condensation at the time of assessment. | None | | | |
| | GENERAL CLEANLINESS | | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 | |
| | Classrooms general appearance is clean and acceptable? | | | General cleanliness of the room at the time of assessment was acceptable. | None | | | |
| | Floor is cleaned on a regular basis? | | | Minor stains on carpet. | Facilities serviceperson to thoroughly clean and sanitize carpet. | Site Based | 2 | |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | | | There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 | |
| | THERMAL COMFORT | | | | | | | |
| | Classroom is free of significant temperature shifts? | | | Media center is too cold-- often uncomfortable | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) | | | Media center is too cold-- often uncomfortable | Humidity was acceptable at the time of assessment. | None | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | | Media center is too cold-- often uncomfortable | Temperature was low at the time of assessment. | See other recommendation. | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|----------------------------|--|------|--|---|--|-------------|----------|
| 102 | Temp | 70.8 | RH% 49.5 | CO2 589 | Occupants: _____ | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | Media center is too cold-- often uncomfortable | Temperature was low at the time of assessment. | See other recommendation. | | |
| 102A | Temp | 71.6 | RH% 48.3 | CO2 614 | Occupants: _____ | | |
| GENERAL CLEANLINESS | | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | The back area of the media center is in constant use.I have to make a special request for the area to be mopped. | No dust observed on supply/return registers at the time of assessment. | None | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | The back area of the media center is in constant use.I have to make a special request for the area to be mopped. | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Classrooms general appearance is clean and acceptable? | | The back area of the media center is in constant use.I have to make a special request for the area to be mopped. | There are boxes and equipment on the floor making it difficult for the Facilities Serviceperson Staff to clean. | Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their cleaning efforts | Site Based | 2 |
| | Floor is cleaned on a regular basis? | | The back area of the media center is in constant use.I have to make a special request for the area to be mopped. | Floor was clean at the time of assessment. | None | | |
| | Room is free of pests? | | The back area of the media center is in constant use.I have to make a special request for the area to be mopped. | No pests observed at the time of assessment. However, room is being used as a lunch room and there is food debris on the tables and counters. | Facilities serviceperson should clean up food debris. | Site Based | 2 |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | | The back area of the media center is in constant use.I have to make a special request for the area to be mopped. | No issues identified at the time of assessment. | None | | |
| LOCAL EXHAUST FANS | | | | | | | |
| | My classroom has sufficient exhaust systems based on the activities/functionality of the room? | | | No exhaust fans in room. Identified in error. | None | | |
| | Other exhaust fans that may exist in the classroom are functioning properly? | | | No exhaust fans in room. Identified in error. | None | | |
| THERMAL COMFORT | | | | | | | |
| | Classroom is free of significant temperature shifts? | | Area is too cold | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | Area is too cold | Temperature was low at the time of assessment. | See other recommendation. | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|--|--|--|---|--|--|-------------|----------|
| 102A | Temp <input type="text" value="71.6"/> | RH% <input type="text" value="48.3"/> | CO2 <input type="text" value="614"/> | Occupants: <input type="text"/> | | | |
| Temperature in my classroom is generally comfortable (72F-76F)? | Area is too cold | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| 102G | Temp <input type="text" value="70.4"/> | RH% <input type="text" value="48.7"/> | CO2 <input type="text" value="633"/> | Occupants: <input type="text"/> | | | |
| ANIMALS IN THE CLASSROOM | Activities and/or room conditions are modified to address student allergies? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| You are informed about the potential allergies of your students? | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| 102H | Temp <input type="text" value="70.7"/> | RH% <input type="text" value="49.1"/> | CO2 <input type="text" value="650"/> | Occupants: <input type="text"/> | | | |
| THERMAL COMFORT | Room is usually comfortable? (If no, please explain in the notes below.) | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| Temperature in my classroom is generally comfortable (72F-76F)? | very cold | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| 104 | Temp <input type="text" value="69.5"/> | RH% <input type="text" value="53"/> | CO2 <input type="text" value="723"/> | Occupants: <input type="text"/> | | | |
| ANIMALS IN THE CLASSROOM | Activities and/or room conditions are modified to address student allergies? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| You are informed about the potential allergies of your students? | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|----------------------------|---|--|----------|--|--|-------------|----------|
| 104 | Temp | 69.5 | RH% 53 | CO2 723 | Occupants: | | |
| GENERAL CLEANLINESS | | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | My office is never dusted. Under the desk is not cleaned in a timely manner. | | No dust observed on supply/return registers at the time of assessment. | None | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | My office is never dusted. Under the desk is not cleaned in a timely manner. | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Floor is cleaned on a regular basis? | My office is never dusted. Under the desk is not cleaned in a timely manner. | | Stains on carpet. | Facilities serviceperson to thoroughly clean and sanitize carpet. | Site Based | 2 |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | My office is never dusted. Under the desk is not cleaned in a timely manner. | | There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| THERMAL COMFORT | | | | | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | My office is always extremely cold. | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Temperature in my classroom is generally comfortable (72F-76F)? | My office is always extremely cold. | | Temperature was low at the time of assessment. | See other recommendation. | | |
| 108 | Temp | 67.8 | RH% 49.3 | CO2 709 | Occupants: | | |
| THERMAL COMFORT | | | | | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | Temperature averages 80 degrees. | | Room is not designed as a classroom - for communication equipment only. | None | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | Temperature averages 80 degrees. | | Room is not designed as a classroom - for communication equipment only. | None | | |
| 113A | Temp | 69.5 | RH% 56.6 | CO2 694 | Occupants: | | |
| AIR CONDITIONING | | | | | | | |
| | Room is free of smell of mold or mildew? | Sometimes there is a smell of mold present. | | No odor detected at the time of assessment. | None | | |
| GENERAL CLEANLINESS | | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|--------------------------------------|---|------|----------|--|--|--|--------------|
| 113A | Temp | 69.5 | RH% 56.6 | CO2 694 | Occupants: _____ | | |
| | Floor is cleaned on a regular basis? | | | Carpet was stained and dirty. | Facilities serviceperson to thoroughly clean and sanitize carpet. | Site Based | 2 |
| THERMAL COMFORT | | | | | | | |
| | Classroom is free of significant temperature shifts? | | | Office is hot and humid many days when the temperature is warm outside. | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based 2 |
| | Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) | | | Office is hot and humid many days when the temperature is warm outside. | Humidity was acceptable at the time of assessment. | None | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | | Office is hot and humid many days when the temperature is warm outside. | Temperature was low at the time of assessment. | See other recommendation. | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | Office is hot and humid many days when the temperature is warm outside. | Temperature was low at the time of assessment. | See other recommendation. | |
| 114 | Temp | 67.9 | RH% 63.3 | CO2 958 | Occupants: 24 | | |
| AIR CONDITIONING | | | | | | | |
| | Room is free of smell of kitchen/food? | | | No odor detected at the time of assessment. | None | | |
| ANIMALS IN THE CLASSROOM | | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| EXCESS MOISTURE IN CLASSROOMS | | | | | | | |
| | Area around and under classroom sinks free of leaks? | | | Faucet on art sink should be removed. It is too close to the edge of the sink and there is water on the counter, table and floor. Other faucets over center of sink can be used. | Physical Plant Operations to evaluate and repair/replace as appropriate. | Physical Plant Operations | 1 |
| GENERAL CLEANLINESS | | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | Recommended increase in custodial staff. Maintenance of a clean classroom requires a continuous and repeated effort. Without appropriate manpower, maintenance is reduced to only what is necessary, not what is superior or beneficial. | slight dust accumulation was observed on environmental surfaces at the time of assessment. Newspapers stacked around room. | Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts | Site Based 2 |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | | | | |
|---------------------------------|---|--|------------|----------|--|--|-------------------|----|--|--|---|
| 114 | Temp | 67.9 | RH% | 63.3 | CO2 | 958 | Occupants: | 24 | | | |
| | Classrooms general appearance is clean and acceptable? | Recommended increase in custodial staff. Maintenance of a clean classroom requires a continuous and repeated effort. Without appropriate manpower, maintenance is reduced to only what is necessary, not what is superior or beneficial. | | | General cleanliness of the room at the time of assessment was not acceptable. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | | | | 2 |
| | Floor is cleaned on a regular basis? | Recommended increase in custodial staff. Maintenance of a clean classroom requires a continuous and repeated effort. Without appropriate manpower, maintenance is reduced to only what is necessary, not what is superior or beneficial. | | | Floor was clean at the time of assessment. However, there was standing water on the floor that could create a slip hazard. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | | | | 2 |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | Recommended increase in custodial staff. Maintenance of a clean classroom requires a continuous and repeated effort. Without appropriate manpower, maintenance is reduced to only what is necessary, not what is superior or beneficial. | | | There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | | | | 2 |
| THERMAL COMFORT | | | | | | | | | | | |
| | Classroom is free of significant temperature shifts? | | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | | | | 2 |
| 116 | Temp | 69 | RH% | 57.7 | CO2 | 1172 | Occupants: | 2 | | | |
| AIR CONDITIONING | | | | | | | | | | | |
| | Room is free of smell of mold or mildew? | | | | No odor detected at the time of assessment. | None | | | | | |
| ANIMALS IN THE CLASSROOM | | | | | | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | | | | 3 |
| | You are informed about the potential allergies of your students? | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | | | | 3 |
| GENERAL CLEANLINESS | | | | | | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|---------------------------|---|----|--|--|--|-------------|----------|
| 116 | Temp | 69 | RH% 57.7 | CO2 1172 | Occupants: 2 | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | Floor is dusted with a dry dustmop every day, but is washed only at the beginning of the year. I do dusting, sweeping at the end of the day. | No dust observed on supply/return registers at the time of assessment. | None | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | Floor is dusted with a dry dustmop every day, but is washed only at the beginning of the year. I do dusting, sweeping at the end of the day. | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Floor is cleaned on a regular basis? | | Floor is dusted with a dry dustmop every day, but is washed only at the beginning of the year. I do dusting, sweeping at the end of the day. | Dust and dirt accumulation on floor. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based | 2 |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | | Floor is dusted with a dry dustmop every day, but is washed only at the beginning of the year. I do dusting, sweeping at the end of the day. | There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| LOCAL EXHAUST FANS | | | | | | | |
| | Bathroom exhaust fan is functioning properly? | | | No bathroom. Identified in error. | None | | |
| | Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) | | | No issues identified at the time of assessment. | None | | |
| THERMAL COMFORT | | | | | | | |
| | Classroom is free of significant temperature shifts? | | The room is exceptionally cold; requires multiple layers of shirts and a jacket every day. Papers become wet. | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) | | The room is exceptionally cold; requires multiple layers of shirts and a jacket every day. Papers become wet. | Humidity was acceptable at the time of assessment. | None | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | The room is exceptionally cold; requires multiple layers of shirts and a jacket every day. Papers become wet. | Temperature was low at the time of assessment. | See other recommendation. | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | The room is exceptionally cold; requires multiple layers of shirts and a jacket every day. Papers become wet. | Temperature was low at the time of assessment. | See other recommendation. | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|--|----------------------|---|----------|--|--|-------------|----------|
| 117 | Temp | 68.1 | RH% 67.5 | CO2 989 | Occupants: 30 | | |
| AIR CONDITIONING | | | | | | | |
| Room is free of smell of mold or mildew? | | | | No odor detected at the time of assessment. | None | | |
| ANIMALS IN THE CLASSROOM | | | | | | | |
| You are informed about the potential allergies of your students? | | Floors do not look like they have been cleaned since the beginning of school. Dead lizards are found regularly on the floor and big black feathers are found on different counters. | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| DRAIN TRAPS IN THE CLASSROOM | | | | | | | |
| Water run in sinks at least once per week (about 2 cups of water). | | | | No issues identified at the time of assessment. | None | | |
| EXCESS MOISTURE IN CLASSROOMS | | | | | | | |
| Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? | | | | No leaks or signs of water intrusion identified. | None | | |
| Indoor surfaces of exterior walls free of continuous condensation? | | | | No visible condensation at the time of assessment. | None | | |
| GENERAL CLEANLINESS | | | | | | | |
| Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | | | No dust observed on supply/return registers at the time of assessment. | None | | |
| Classroom is dusted/vacuumed thoroughly and regularly? | | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| Floor is cleaned on a regular basis? | | | | Floor was clean at the time of assessment. | None | | |
| Food, if any, is stored in tightly sealed containers? | | | | No issues identified at the time of assessment. | None | | |
| Room is free of pests? | | | | No pests observed at the time of assessment. | | | |
| LOCAL EXHAUST FANS | | | | | | | |
| My classroom has sufficient exhaust systems based on the activities/functionality of the room? | | | | No exhaust fans in room. Identified in error. | None | | |
| THERMAL COMFORT | | | | | | | |
| Classroom is free of significant temperature shifts? | | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|------------|---|--|-------------------|--|--|---------------------------|----------|
| 117 | Temp 68.1 | RH% 67.5 | CO2 989 | Occupants: 30 | | | |
| | Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) | | | Humidity was slightly elevated at the time of assessment. | Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level. | Physical Plant Operations | 2 |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| 118 | Temp 69.4 | RH% 60.6 | CO2 1269 | Occupants: 24 | | | |
| | GENERAL CLEANLINESS | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | The top of the desks are rarely dusted | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | THERMAL COMFORT | | | | | | |
| | Classroom is free of significant temperature shifts? | | | Humidity was slightly elevated at the time of assessment and temperature was low. | Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level. | Physical Plant Operations | 2 |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| 122 | Temp 70.7 | RH% 57.4 | CO2 1069 | Occupants: 25 | | | |
| | ANIMALS IN THE CLASSROOM | | | | | | |
| | You are informed about the potential allergies of your students? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | THERMAL COMFORT | | | | | | |
| | Classroom is free of significant temperature shifts? | Nearly 3/4 of the time, my room is too warm. | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Room is usually comfortable? (If no, please explain in the notes below.) | Nearly 3/4 of the time, my room is too warm. | | Temperature was low at the time of assessment. | See other recommendation. | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | | | | |
|-----------|--|------|-----|--|--|--|------------|------------|--|--|---|
| 122 | Temp | 70.7 | RH% | 57.4 | CO2 | 1069 | Occupants: | 25 | | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | Nearly 3/4 of the time, my room is too warm. | Temperature was low at the time of assessment. | See other recommendation. | | | | | |
| 128 | Temp | 69.5 | RH% | 60.1 | CO2 | 857 | Occupants: | | | | |
| | ANIMALS IN THE CLASSROOM | | | | | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | | Site Based | | | 3 |
| | You are informed about the potential allergies of your students? | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | | Site Based | | | 3 |
| | GENERAL CLEANLINESS | | | | | | | | | | |
| | Food, if any, is stored in tightly sealed containers? | | | | No issues identified at the time of assessment. | None | | | | | |
| | LOCAL EXHAUST FANS | | | | | | | | | | |
| | Bathroom exhaust fan is functioning properly? | | n/a | | No bathroom. Identified in error. | None | | | | | |
| | Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) | | n/a | | No issues identified at the time of assessment. | None | | | | | |
| | Other exhaust fans that may exist in the classroom are functioning properly? | | n/a | | No exhaust fans in room. Identified in error. | None | | | | | |
| | Walkthrough | | | | | | | | | | |
| | | | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | | Site Based | | | 2 |
| 129 | Temp | 69.9 | RH% | 55.5 | CO2 | 874 | Occupants: | | | | |
| | EXCESS MOISTURE IN CLASSROOMS | | | | | | | | | | |
| | Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? | | | | No leaks or signs of water intrusion identified. | None | | | | | |
| | THERMAL COMFORT | | | | | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | |
|-----------|---|---|----------|----------|--|--|------------|---|
| 129 | Temp | 69.9 | RH% 55.5 | CO2 874 | Occupants: _____ | | | |
| | Classroom is free of significant temperature shifts? | The temperature is not consistent. It regulates to extremely hot or cold. | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) | The temperature is not consistent. It regulates to extremely hot or cold. | | | Humidity was acceptable at the time of assessment. | None | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | The temperature is not consistent. It regulates to extremely hot or cold. | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | The temperature is not consistent. It regulates to extremely hot or cold. | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| 131 | Temp | 69.9 | RH% 53.7 | CO2 812 | Occupants: _____ | | | |
| | DRAIN TRAPS IN THE CLASSROOM | | | | | | | |
| | Water run in sinks at least once per week (about 2 cups of water). | | | | No sink in room. | None | | |
| | EXCESS MOISTURE IN CLASSROOMS | | | | | | | |
| | Classroom lavatories/water fountains free of leaks? | | | | No lavatories/water fountains in room. | None | | |
| | LOCAL EXHAUST FANS | | | | | | | |
| | Bathroom exhaust fan is functioning properly? | | | | No bathroom. Identified in error. | None | | |
| | Walkthrough | | | | | | | |
| | | | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| 133 | Temp | 69.8 | RH% 54.2 | CO2 796 | Occupants: _____ | | | |
| | GENERAL CLEANLINESS | | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Walkthrough | | | | | | | |

| FISH/Room | Participant Comments | Response | Recommendation | Responsible | Priority |
|-----------|--|--|--|-------------|----------|
| 133 | Temp <input type="text" value="69.8"/> RH% <input type="text" value="54.2"/> CO2 <input type="text" value="796"/> | Occupants: _____ Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| 135 | Temp <input type="text" value="69.9"/> RH% <input type="text" value="55.5"/> CO2 <input type="text" value="874"/> | Occupants: _____ Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Walkthrough | | | | |
| 136 | Temp <input type="text" value="68.9"/> RH% <input type="text" value="55.8"/> CO2 <input type="text" value="1049"/> | Occupants: _____ No issues identified at the time of assessment. | None | | |
| | GENERAL CLEANLINESS Food, if any, is stored in tightly sealed containers? | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Walkthrough | | | | |
| 137 | Temp <input type="text" value="69.8"/> RH% <input type="text" value="50.1"/> CO2 <input type="text" value="1154"/> | Occupants: _____ No odor detected at the time of assessment. | None | | |
| | AIR CONDITIONING Room is free of smell of chemicals? | | | | |
| | GENERAL CLEANLINESS | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|---------------------------|--|------|----------|----------|--|--|-----------------------------|
| 137 | Temp | 69.8 | RH% 50.1 | CO2 1154 | Occupants: _____ | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | | | No dust observed on supply/return registers at the time of assessment. | None | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | | Slight dust accumulation was observed on environmental surfaces in FISH 134 (wood shop inside of 137) at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based 2 |
| | Room is free of pests? | | | | No pests observed at the time of assessment. | None | |
| LOCAL EXHAUST FANS | | | | | | | |
| | Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) | | | | Exhaust fan is not functioning properly. | Physical Plant Operations to evaluate and repair/replace as appropriate. | Physical Plant Operations 1 |
| | My classroom has sufficient exhaust systems based on the activities/functionality of the room? | | | | Exhaust fan is not functioning properly. | See other recommendation. | |
| | Walkthrough | | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based 2 |
| 141 | Temp | 71 | RH% 57.1 | CO2 1255 | Occupants: _____ | | |
| AIR CONDITIONING | | | | | | | |
| | Air flowing from air supply? | | | | Air flowing without obstruction at the time of assessments. | None | |
| | Air is flowing without obstruction? | | | | Air flowing without obstruction at the time of assessments. | None | |
| THERMAL COMFORT | | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | | | | |
|-----------|---|------|-----|---|--|-------------|------------|----|--|--|---|
| 141 | Temp | 71 | RH% | 57.1 | CO2 | 1255 | Occupants: | 17 | | | |
| | Classroom is free of significant temperature shifts? | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | | | | | 2 |
| | Room is free of the introduction of outdoor air? (Gaps in window/door frames.) | | | No windows in room. | None | | | | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | | Temperature was low at the time of assessment. | See other recommendation. | | | | | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | Temperature was low at the time of assessment. | See other recommendation. | | | | | | |
| 202C | Temp | 76 | RH% | 48.7 | CO2 | 680 | Occupants: | | | | |
| | GENERAL CLEANLINESS | | | | | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts | Site Based | | | | | 2 |
| | Walkthrough | | | | | | | | | | |
| | | | | Windows and/or doors were open at the time of assessment. Open doors and windows allow humid untreated air into occupied environment. | Site based administration to encourage staff to keep doors and windows closed. Open doors and windows allow humid untreated air into occupied environment. | Site Based | | | | | 1 |
| 208 | Temp | 70.1 | RH% | 54.3 | CO2 | 1075 | Occupants: | 26 | | | |
| | GENERAL CLEANLINESS | | | | | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | | Dust observed on supply/return registers at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based | | | | | 2 |
| | LOCAL EXHAUST FANS | | | | | | | | | | |
| | Bathroom exhaust fan is functioning properly? | | | No bathroom. Identified in error. | None | | | | | | |
| | THERMAL COMFORT | | | | | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | | | | |
|-----------|--|------|-----|--|--|--|------------|----|--|--|---|
| 208 | Temp | 70.1 | RH% | 54.3 | CO2 | 1075 | Occupants: | 26 | | | |
| | Classroom is free of significant temperature shifts? | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | | | | | 2 |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | Temperature was low at the time of assessment. | See other recommendation. | | | | | | |
| 209 | Temp | 70.7 | RH% | 53.8 | CO2 | 1070 | Occupants: | | | | |
| | LOCAL EXHAUST FANS | | | | | | | | | | |
| | My classroom has sufficient exhaust systems based on the activities/functionality of the room? | | | my class does not have an exhaust system | No exhaust fans in room. Identified in error. | None | | | | | |
| | Other exhaust fans that may exist in the classroom are functioning properly? | | | my class does not have an exhaust system | No exhaust fans in room. Identified in error. | None | | | | | |
| 213 | Temp | 71 | RH% | 54 | CO2 | 1379 | Occupants: | | | | |
| | ANIMALS IN THE CLASSROOM | | | | | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | | | | 3 |
| | You are informed about the potential allergies of your students? | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | | | | 3 |
| | LOCAL EXHAUST FANS | | | | | | | | | | |
| | My classroom has sufficient exhaust systems based on the activities/functionality of the room? | | | | No exhaust fans in room. Identified in error. | None | | | | | |
| 218 | Temp | 70.3 | RH% | 51.5 | CO2 | 1430 | Occupants: | | | | |
| | ANIMALS IN THE CLASSROOM | | | | | | | | | | |
| | Classroom is free of animals and pets? | | | | No animals identified at the time of assessment. | None | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|-----------|--|------|--|--|--|-------------|----------|
| 218 | Temp | 70.3 | RH% 51.5 | CO2 1430 | Occupants: | | |
| | You are informed about the potential allergies of your students? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | GENERAL CLEANLINESS | | | | | | |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | | | No issues identified relating to spill clean up practices at the time of assessment.. | None | | |
| | Trash is removed daily and trash bags are changed as appropriate? | | | No issues identified regarding trash removal practices. | None | | |
| 227 | Temp | 71.1 | RH% 50.3 | CO2 1501 | Occupants: | | |
| | ANIMALS IN THE CLASSROOM | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | Allergies of student are unknown. | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | You are informed about the potential allergies of your students? | | Allergies of student are unknown. | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | DRAIN TRAPS IN THE CLASSROOM | | | | | | |
| | Water run in sinks at least once per week (about 2 cups of water). | | | It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors. | Site based administration should address maintenance of sinks with facility serviceperson staff. | Site Based | 2 |
| | LOCAL EXHAUST FANS | | | | | | |
| | Bathroom exhaust fan is functioning properly? | | | No bathroom. Identified in error. | None | | |
| | My classroom has sufficient exhaust systems based on the activities/functionality of the room? | | | No exhaust fans in room. Identified in error. | None | | |
| | THERMAL COMFORT | | | | | | |
| | Classroom is free of significant temperature shifts? | | On Mondays, the air temperature is hot and unbearable. When the air does flow properly, it becomes too cold as the week progresses. Extreme temperatures make the room uncomfortable most of the time. | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|-----------|---|------|--|--|--|-------------|----------|
| 227 | Temp | 71.1 | RH% 50.3 | CO2 1501 | Occupants: _____ | | |
| | Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) | | On Mondays, the air temperature is hot and unbearable. When the air does flow properly, it becomes too cold as the week progresses. Extreme temperatures make the room uncomfortable most of the time. | Humidity was acceptable at the time of assessment. | None | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | On Mondays, the air temperature is hot and unbearable. When the air does flow properly, it becomes too cold as the week progresses. Extreme temperatures make the room uncomfortable most of the time. | Temperature was low at the time of assessment. | See other recommendation. | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | On Mondays, the air temperature is hot and unbearable. When the air does flow properly, it becomes too cold as the week progresses. Extreme temperatures make the room uncomfortable most of the time. | Temperature was low at the time of assessment. | See other recommendation. | | |
| 228 | Temp | 69.4 | RH% 52.1 | CO2 1490 | Occupants: _____ | | |
| | ANIMALS IN THE CLASSROOM | | | | | | |
| | You are informed about the potential allergies of your students? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | DRAIN TRAPS IN THE CLASSROOM | | | | | | |
| | Water poured down floor drains once per week (approx. 1 quart of water). | | | No issues identified at the time of assessment. | None | | |
| | Water run in sinks at least once per week (about 2 cups of water). | | | It appears as though sink is not utilized regularly. By running water regularly it eliminates the potential for sewer gas odors. | Site based administration should address maintenance of sinks with facility serviceperson staff. | Site Based | 2 |
| | GENERAL CLEANLINESS | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | | Dust observed on supply/return registers at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based | 2 |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Classrooms general appearance is clean and acceptable? | | | General cleanliness of the room at the time of assessment was acceptable. | None | | |
| | Floor is cleaned on a regular basis? | | | Floor was clean at the time of assessment. | None | | |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | | | No issues identified relating to spill clean up practices at the time of assessment.. | None | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|-----------|--|------|----------|---|--|--|--------------|
| 228 | Temp | 69.4 | RH% 52.1 | CO2 1490 | Occupants: _____ | | |
| | Trash is removed daily and trash bags are changed as appropriate? | | | No issues identified regarding trash removal practices. | None | | |
| | THERMAL COMFORT | | | | | | |
| | Classroom is free of significant temperature shifts? | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Walkthrough | | | Faucets on sink are spinning around and not over sinks. | Physical Plant Operations to evaluate and repair/replace as appropriate. | Physical Plant Operations | 1 |
| 229 | Temp | 70.3 | RH% 54 | CO2 1142 | Occupants: _____ | | |
| | GENERAL CLEANLINESS | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | General cleanliness of the room at the time of assessment was acceptable. | None | | |
| 233 | Temp | 70.9 | RH% 55 | CO2 1162 | Occupants: _____ | | |
| | THERMAL COMFORT | | | | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | | Classroom is always too cold. | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based 2 |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | Classroom is always too cold. | Temperature was low at the time of assessment. | See other recommendation. | |
| 238 | Temp | 68.2 | RH% 51.4 | CO2 1455 | Occupants: _____ | | |
| | ANIMALS IN THE CLASSROOM | | | | | | |
| | You are informed about the potential allergies of your students? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | THERMAL COMFORT | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|-----------|---|---|----------|--|--|-------------|----------|
| 238 | Temp | 68.2 | RH% 51.4 | CO2 1455 | Occupants: | | |
| | Classroom is free of significant temperature shifts? | The classroom temperature is way too cold for student comfort. | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Room is usually comfortable? (If no, please explain in the notes below.) | The classroom temperature is way too cold for student comfort. | | Temperature was low at the time of assessment. | See other recommendation. | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | The classroom temperature is way too cold for student comfort. | | Temperature was low at the time of assessment. | See other recommendation. | | |
| 239 | Temp | 70.2 | RH% 52.9 | CO2 1641 | Occupants: | | |
| | ANIMALS IN THE CLASSROOM | | | | | | |
| | Classroom is free of animals and pets? | | | Fish tanks in room | None | | |
| | GENERAL CLEANLINESS | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | floor is swept but not mop... | | Dust observed on supply/return registers at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based | 2 |
| | Classroom is dusted/vacuumed thoroughly and regularly? | floor is swept but not mop... | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Floor is cleaned on a regular basis? | floor is swept but not mop... | | Floor was clean at the time of assessment. | None | | |
| | Food, if any, is stored in tightly sealed containers? | floor is swept but not mop... | | No issues identified at the time of assessment. | None | | |
| | Room is free of the use of scented cleaners and air fresheners? | floor is swept but not mop... | | No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment. | None | | |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | floor is swept but not mop... | | No issues identified relating to spill clean up practices at the time of assessment.. | None | | |
| | Trash is removed daily and trash bags are changed as appropriate? | floor is swept but not mop... | | No issues identified regarding trash removal practices. | None | | |
| | THERMAL COMFORT | | | | | | |
| | Classroom is free of significant temperature shifts? | Drastic temperature changes from 60 F to 80 F most of the time... | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | | |
|-----------|--|------|---|--|--|-------------|------------------|--|---|
| 239 | Temp | 70.2 | RH% | 52.9 | CO2 | 1641 | Occupants: _____ | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | Drastic temperature changes from 60 F to 80 F most of the time... | Temperature was low at the time of assessment. | See other recommendation. | | | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | Drastic temperature changes from 60 F to 80 F most of the time... | Temperature was low at the time of assessment. | See other recommendation. | | | | |
| 241 | Temp | 70.4 | RH% | 51.3 | CO2 | 1429 | Occupants: _____ | | |
| | DRAIN TRAPS IN THE CLASSROOM | | | | | | | | |
| | Water run in sinks at least once per week (about 2 cups of water). | | | It appears as though sink is not utilized regularly. By running water regularly it eliminates the potential for sewer gas odors. | Site based administration should address maintenance of sinks with facility serviceperson staff. | Site Based | | | 2 |
| | THERMAL COMFORT | | | | | | | | |
| | Classroom is free of significant temperature shifts? | | The room has been very hot for a period of time as well as cold. Recently it seems to be well regulated. | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | | | 2 |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | The room has been very hot for a period of time as well as cold. Recently it seems to be well regulated. | Temperature was low at the time of assessment. | See other recommendation. | | | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | The room has been very hot for a period of time as well as cold. Recently it seems to be well regulated. | Temperature was low at the time of assessment. | See other recommendation. | | | | |
| 242 | Temp | 71.2 | RH% | 54.8 | CO2 | 1228 | Occupants: _____ | | |
| | ANIMALS IN THE CLASSROOM | | | | | | | | |
| | You are informed about the potential allergies of your students? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | | | 3 |
| | LOCAL EXHAUST FANS | | | | | | | | |
| | Bathroom exhaust fan is functioning properly? | | I do not have a room bathroom, however my room is close to one and it generally has a very foul urine smell which extends well into the hallway. Proper exhaust my not be the problem but the order is overwhelming most of the time. | No bathroom. Identified in error. | None | | | | |
| | THERMAL COMFORT | | | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | |
|-----------|---|--|----------|----------|---|--|------------|---|
| 242 | Temp | 71.2 | RH% 54.8 | CO2 1228 | Occupants: _____ | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | I indicated Yes for item A because I do not know the exact temperature. However, my students and I are always quite chilly in the room, it seems to be below 72 degrees. However, in an effort to keep the germ levels down, the colder room may be necessary. | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| 248 | Temp | 68.2 | RH% 53.7 | CO2 964 | Occupants: _____ | | | |
| | AIR CONDITIONING | | | | | | | |
| | Windows/doors are operable and are kept closed? | | | | Windows and doors are operable and are not kept closed. | Site based administration to encourage staff to keep doors and windows closed. Open doors and windows allow humid untreated air into occupied environment. | Site Based | 1 |
| | Walkthrough | | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| 252 | Temp | 64.3 | RH% 54.7 | CO2 1192 | Occupants: _____ | | | |
| | DRAIN TRAPS IN THE CLASSROOM | | | | | | | |
| | Water poured down floor drains once per week (approx. 1 quart of water). | | | | Water is not poured down floor drain at least once a week and drains are full of paper, pens and pencils. | Site based administration should address maintenance of drains with facility serviceperson staff. | Site Based | 1 |
| | GENERAL CLEANLINESS | | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | | | No dust observed on supply/return registers at the time of assessment. | None | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Floor is cleaned on a regular basis? | | | | Floor was clean at the time of assessment. | None | | |
| | THERMAL COMFORT | | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | |
|-----------|---|--|----------|----------|--|--|------------|---|
| 252 | Temp | 64.3 | RH% 54.7 | CO2 1192 | Occupants: _____ | | | |
| | Classroom is free of significant temperature shifts? | the teperature is extremely cold. heavy sweaters and jackets are usual attire. | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Room is usually comfortable? (If no, please explain in the notes below.) | the teperature is extremely cold. heavy sweaters and jackets are usual attire. | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | the teperature is extremely cold. heavy sweaters and jackets are usual attire. | | | Temperature was low at the time of assessment. | See other recommendation. | | |
| 257 | Temp | 69.5 | RH% 60.1 | CO2 878 | Occupants: _____ | | | |
| | GENERAL CLEANLINESS | | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | THERMAL COMFORT | | | | | | | |
| | Room is free of the introduction of outdoor air? (Gaps in window/door frames.) | | | | Windows and doors are operable and are not kept closed. | Site based administration to encourage staff to keep doors and windows closed. Open doors and windows allow humid untreated air into occupied environment. | Site Based | 1 |
| | Walkthrough | | | | | | | |
| | | | | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| 262 | Temp | 70.4 | RH% 59.9 | CO2 992 | Occupants: _____ | | | |
| | GENERAL CLEANLINESS | | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | rooms should be mopped weekly, with a disinfectant | | | Dust observed on supply/return registers at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based | 2 |
| | Classroom is dusted/vacuumed thoroughly and regularly? | rooms should be mopped weekly, with a disinfectant | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Floor is cleaned on a regular basis? | rooms should be mopped weekly, with a disinfectant | | | Floor was clean at the time of assessment. | None | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|----------------------------|--|--|----------|---|--|---------------------------|----------|
| 262 | Temp | 70.4 | RH% 59.9 | CO2 992 | Occupants: | | |
| LOCAL EXHAUST FANS | | | | | | | |
| | Bathroom exhaust fan is functioning properly? | bathroom is down the hall | | No bathroom. Identified in error. | None | | |
| THERMAL COMFORT | | | | | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | this room is too cold. (other rooms are hot) | | Windows and/or doors were open at the time of assessment. Open doors and windows allow humid untreated air into occupied environment. | Site based administration to encourage staff to keep doors and windows closed. Open doors and windows allow humid untreated air into occupied environment. | Site Based | 1 |
| | Temperature in my classroom is generally comfortable (72F-76F)? | this room is too cold. (other rooms are hot) | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| 263 | Temp | 69.4 | RH% 50.3 | CO2 1185 | Occupants: | | |
| GENERAL CLEANLINESS | | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | | Dust observed on supply/return registers at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based | 2 |
| | Room is free of pests? | | | No pests observed at the time of assessment. | None | | |
| LOCAL EXHAUST FANS | | | | | | | |
| | Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) | there are no exhaust hoods or fans in my room and if there is a bad odor it lingers for awhile. | | Exhaust fan is needed - science lab. | Physical Plant operations to evaluate and install exhaust fan. | Physical Plant Operations | 1 |
| | My classroom has sufficient exhaust systems based on the activities/functionality of the room? | there are no exhaust hoods or fans in my room and if there is a bad odor it lingers for awhile. | | No exhaust fans in room. | See other recommendation. | | |
| | Other exhaust fans that may exist in the classroom are functioning properly? | there are no exhaust hoods or fans in my room and if there is a bad odor it lingers for awhile. | | No exhaust fans in room. | None | | |
| THERMAL COMFORT | | | | | | | |
| | Classroom is free of significant temperature shifts? | My room is frequently way too cold. The air conditioning is on too early in the morning and I have to wear a coat and the children complain that they are freezing. When it is off, it gets very warm and they complain that it is hot. For the most part, howev | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|---|----------------------|------|----------|----------|--|--|--------------|
| 263 | Temp | 69.4 | RH% 50.3 | CO2 1185 | Occupants: _____ | | |
| Room is usually comfortable? (If no, please explain in the notes below.) | | | | | Temperature was low at the time of assessment. | See other recommendation. | |
| Temperature in my classroom is generally comfortable (72F-76F)? | | | | | Temperature was low at the time of assessment. | See other recommendation. | |
| 264 | Temp | 69.3 | RH% 62.7 | CO2 927 | Occupants: _____ | | |
| ANIMALS IN THE CLASSROOM | | | | | | | |
| Activities and/or room conditions are modified to address student allergies? | | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based 3 |
| ART SUPPLIES | | | | | | | |
| Art supplies okay? | | | | | No art supplies in room. Room not being used as an art room. | None | |
| Industrial supplies okay? | | | | | No industrial supplies in room. Room not being used as an industrial room. | None | |
| Science supplies okay? | | | | | No science supplies in room. Room not being used as a science room. | None | |
| DRAIN TRAPS IN THE CLASSROOM | | | | | | | |
| Water run in sinks at least once per week (about 2 cups of water). | | | | | It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors. | None | |
| GENERAL CLEANLINESS | | | | | | | |
| Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | | | | Dust observed on supply/return registers at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based 2 |
| Classroom is dusted/vacuumed thoroughly and regularly? | | | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based 2 |
| Floor is cleaned on a regular basis? | | | | | Floor was clean at the time of assessment. | None | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|-----------|---|------|---|----------|--|--|--------------|
| 264 | Temp | 69.3 | RH% 62.7 | CO2 927 | Occupants: _____ | | |
| | Room is free of pests? | | | | No pests observed at the time of assessment. | None | |
| | THERMAL COMFORT | | | | | | |
| | Room is free of the introduction of outdoor air? (Gaps in window/door frames.) | | Freezing most of the tiime. Even when the temperature drops, the inside temperature stays at freezing. Hence, my students must wear gloves and heavy clothing almost every day. | | No gaps in windows or doors identified at the time of assessment. | None | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | Freezing most of the tiime. Even when the temperature drops, the inside temperature stays at freezing. Hence, my students must wear gloves and heavy clothing almost every day. | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based 2 |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | Freezing most of the tiime. Even when the temperature drops, the inside temperature stays at freezing. Hence, my students must wear gloves and heavy clothing almost every day. | | Temperature was low at the time of assessment. | See other recommendation. | |
| 265 | Temp | 70 | RH% 49.2 | CO2 1211 | Occupants: _____ | | |
| | ANIMALS IN THE CLASSROOM | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | In general,the upkeep is very good in my classroom and my students and I assist in making sure the janitor is not overly taxed and can perform efficiently where his attention is needed most. More attention however, should be directed to the accumulation o | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based 3 |
| | DRAIN TRAPS IN THE CLASSROOM | | | | | | |
| | Water poured down floor drains once per week (approx. 1 quart of water). | | | | Water is not poured down floor drain at least once a week and drains are full of paper, pens and pencils. | Site based administration should address maintenance of drains with facility serviceperson staff. | Site Based 1 |
| | Water run in sinks at least once per week (about 2 cups of water). | | | | It appears as though sink is not utilized regularly. By running water regularly it eliminates the potential for sewer gas odors. | Site based administration should address maintenance of sinks with facility serviceperson staff. | Site Based 2 |
| | GENERAL CLEANLINESS | | | | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | | | | Dust observed on supply/return registers at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based 2 |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based 2 |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|--------------------------------------|--|--|----------|--|--|-------------|----------|
| 265 | Temp | 70 | RH% 49.2 | CO2 1211 | Occupants: | | |
| THERMAL COMFORT | | | | | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | My room is very uncomfortable most of the time because it is too cold. The students also complain about the temperature. | | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| | Temperature in my classroom is generally comfortable (72F-76F)? | My room is very uncomfortable most of the time because it is too cold. The students also complain about the temperature. | | Temperature was low at the time of assessment. | See other recommendation. | | |
| Walkthrough | | | | | | | |
| | | | | Occupant has heater under desk because room is too cold. | Occupant to remove heater. | Site Based | 2 |
| 301 | Temp | 73.4 | RH% 62 | CO2 988 | Occupants: | | |
| AIR CONDITIONING | | | | | | | |
| | Windows/doors are operable and are kept closed? | | | Windows and doors are operable and are kept closed. | None | | |
| ANIMALS IN THE CLASSROOM | | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | You are informed about the potential allergies of your students? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| EXCESS MOISTURE IN CLASSROOMS | | | | | | | |
| | Classroom lavatories/water fountains free of leaks? | | | No issues identified at the time of assessment. | None | | |
| GENERAL CLEANLINESS | | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Floor is cleaned on a regular basis? | | | Floor was clean at the time of assessment. | None | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority |
|-----------|--|------|----------|--|--|---------------------------|----------|
| 301 | Temp | 73.4 | RH% 62 | CO2 988 | Occupants: _____ | | |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | | | No issues identified relating to spill clean up practices at the time of assessment.. | None | | |
| | LOCAL EXHAUST FANS | | | | | | |
| | Bathroom exhaust fan is functioning properly? | | | No bathroom. Identified in error. | None | | |
| | Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) | | | Room is not designed to be used as a classroom. | None | | |
| | My classroom has sufficient exhaust systems based on the activities/functionality of the room? | | | Room is not designed to be used as a classroom. | None | | |
| | THERMAL COMFORT | | | | | | |
| | Room is free of the introduction of outdoor air? (Gaps in window/door frames.) | | | No gaps in windows or doors identified at the time of assessment. | None | | |
| 303A | Temp | 73.3 | RH% 47.4 | CO2 885 | Occupants: _____ | | |
| | ANIMALS IN THE CLASSROOM | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | You are informed about the potential allergies of your students? | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | GENERAL CLEANLINESS | | | | | | |
| | Classroom is dusted/vacuumed thoroughly and regularly? | | | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. | Site Based | 2 |
| | Room is free of pests? | | | No pests observed at the time of assessment. | None | | |
| | LOCAL EXHAUST FANS | | | | | | |
| | Bathroom exhaust fan is functioning properly? | | | Exhaust fan is not functioning properly. | Physical Plant Operations to evaluate and repair/replace as appropriate. | Physical Plant Operations | 1 |
| | My classroom has sufficient exhaust systems based on the activities/functionality of the room? | | | No other exhaust fans in room. | None | | |
| | Other exhaust fans that may exist in the classroom are functioning properly? | | | No other exhaust fans in room. | None | | |
| | THERMAL COMFORT | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | | | | |
|-----------|--|------|-----|----------|----------------|-------------|--|--|--|------------|---|
| 303A | Temp | 73.3 | RH% | 47.4 | CO2 | 885 | Occupants: | | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | | | | | Environmental parameters were within acceptable range at the time of assessment. | | None | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | | | | | | Temperature was acceptable at the time of assessment. | | None | | |
| 314D | Temp | 76.3 | RH% | 49.3 | CO2 | 1012 | Occupants: | | | | |
| | GENERAL CLEANLINESS | | | | | | | | | | |
| | Room is free of pests? | | | | | | No pests observed at the time of assessment. | | None | | |
| | THERMAL COMFORT | | | | | | | | | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | | | | | | Temperature was slightly elevated at the time of assessment. | | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. | Site Based | 2 |
| 315 | Temp | 72.2 | RH% | 52 | CO2 | 916 | Occupants: | | | | |
| | THERMAL COMFORT | | | | | | | | | | |
| | Room is free of the introduction of outdoor air? (Gaps in window/door frames.) | | | | | | No gaps in windows or doors identified at the time of assessment. | | None | | |
| 325 | Temp | 74.1 | RH% | 53.8 | CO2 | 650 | Occupants: | | | | |
| | ANIMALS IN THE CLASSROOM | | | | | | | | | | |
| | Activities and/or room conditions are modified to address student allergies? | | | | | | | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. | Site Based | 3 |
| | GENERAL CLEANLINESS | | | | | | | | | | |

| FISH/Room | Participant Comments | | | Response | Recommendation | Responsible | Priority | |
|------------------------|---|---|----------|----------|---|--|---------------------------|---|
| 325 | Temp | 74.1 | RH% 53.8 | CO2 650 | Occupants: _____ | | | |
| | Air supply/return registers are cleaned regularly and free of dust and debris accumulation? | I have been diagnosed with severe allergies; I get shots every ten days. My worst attacks take place once I enter my classroom. I personally feel that the Custodial Cleaning Procedure Manual should include daily dusting and bi-weekly cleaning of the ven | | | Dust observed on supply/return registers at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based | 2 |
| | Classroom is dusted/vacuumed thoroughly and regularly? | I have been diagnosed with severe allergies; I get shots every ten days. My worst attacks take place once I enter my classroom. I personally feel that the Custodial Cleaning Procedure Manual should include daily dusting and bi-weekly cleaning of the ven | | | Dust and debris on ceiling tiles. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. | Site Based | 2 |
| | Floor is cleaned on a regular basis? | I have been diagnosed with severe allergies; I get shots every ten days. My worst attacks take place once I enter my classroom. I personally feel that the Custodial Cleaning Procedure Manual should include daily dusting and bi-weekly cleaning of the ven | | | Floor was clean at the time of assessment. | None | | |
| | Spills and other such issues requiring custodial assistance are addressed in a timely manner? | I have been diagnosed with severe allergies; I get shots every ten days. My worst attacks take place once I enter my classroom. I personally feel that the Custodial Cleaning Procedure Manual should include daily dusting and bi-weekly cleaning of the ven | | | No issues identified relating to spill clean up practices at the time of assessment.. | None | | |
| LOCKER ROOM | | | | | | | | |
| | Locker room and showers cleaned regularly and properly? | Neither of our two locke rooms are cleaned properly! Floors are not swept daily and very rarely are the floors mopped! No dusting of lockers... | | | Dust and debris identified in locker room and showers at the time of assessment. | Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff. | Site Based | 2 |
| THERMAL COMFORT | | | | | | | | |
| | Classroom is free of significant temperature shifts? | Room is often times too cold, creating discomfort for my students and me. | | | Temperature was acceptable at the time of assessment. | None | | |
| | Room is usually comfortable? (If no, please explain in the notes below.) | Room is often times too cold, creating discomfort for my students and me. | | | Environmental parameters were within acceptable range at the time of assessment.. | None | | |
| | Temperature in my classroom is generally comfortable (72F-76F)? | Room is often times too cold, creating discomfort for my students and me. | | | Temperature was acceptable at the time of assessment. | None | | |
| Walkthrough | | | | | | | | |
| | | | | | Dust and debris identified in HVAC return duct. | Physical Plant operations to evaluate and clean HVAC ducts. | Physical Plant Operations | 2 |